

General Insights from Analysis of Common-Cause Failure Data at U.S. Nuclear Power Plants

1980–2003

The common-cause failure (CCF) study uses operating experience to characterize the frequency and nature of component failure data from operating U.S. commercial nuclear power plants. The evaluation is based on the operating experience from 1980 through 2003. The data sources for this report include:

- License Event Reports (LERs), 1980 to 2003
- Nuclear Plant Reliability Data System (NPRDS), 1980 to 1996
- Equipment Performance and Information Exchange (EPIX), 1997 to 2003

The CCF database is a rich source of information on various aspects of CCF. Exploring the full potential of the database merits a dedicated activity and is outside the scope of the current effort, which has focused on building the infrastructure for such analyses. Nevertheless, some general observations have been made on the character of CCF events, including their causes and shared cause factors, and frequency of occurrence. Some of these insights are summarized in this section.

[Table 1](#) lists the systems, component types, and failure modes for which CCF events have been collected and entered into the database. It also contains the number of CCF events for each system and component combination and the number of independent failure events. [Table 1](#) shows the event counts for failure modes that are relevant to PRA studies. Other failure modes, such as failure to close for reactor trip breakers, were found in the source data; these events were coded and entered into the CCF database, although they are not likely to be used in PRA studies.

Basic information about the nature of CCF events is displayed in [Figure 1](#) and [Figure 2](#). These figures illustrate the distribution of CCF event proximate causes and shared cause factors, respectively. This information provides a general picture of the types of events that may be expected to occur, and what design features might be most susceptible to CCF events. These figures also illustrate the different characteristics of partial CCF events and complete CCF events (events with timing factor, shared cause factor, and component degradation values for each component in the common-cause component group (CCCG) = 1.0). [Figure 3](#) and [Figure 4](#) display the number of CCF events by year of occurrence.

A general review of the actual events and the distributions provided in [Figure 1](#) and [Figure 2](#), reveals the following insights regarding CCF events:

- Human errors related to procedures caused a small percentage of the total events, but the impact of the individual events is usually greater, since human errors have overridden the programmatic controls. This is illustrated by comparing [Figure 1](#), the All case with the Complete case, which shows that human error causes a larger portion of complete CCF events than all CCF events. The examples of events caused by human error are all EDG day tanks simultaneously drained for chemistry surveillance, and two pump breakers racked out as the plant changed modes from shutdown to power.

- A vast majority of All CCF events are not due to multiple failures in response to an operational demand, but result from a “condition of equipment.” The most common is inspection or surveillance test of one component revealing a deficiency that prompts the licensee to inspect/test the redundant component, resulting in the discovery that the same defective condition exists on both components. This demonstrates that detection of failures during the testing and surveillance program prevents CCF events from occurring during demand situations.
- A major contributor to CCF events is programmatic maintenance practices. The frequency of scheduling has been a factor in the numerous wear-caused and aging-caused events. Additionally, the quality of the maintenance, both in the procedures and in performance of the maintenance activities, is an essential factor. Similar events have occurred at different plants—lubrication of circuit breakers (too much, too little, or too long between lubrications), improperly set torque and limit switches on MOVs that are reported as mis-adjustments and not setpoint drift. This indicates that there are maintenance practices that need to be reviewed to reduce CCF potential. However, the maintenance issue generally does not cause complete CCF events.
- Among complete CCF events, design problems are an important contributor. Many of the design-related events resulted from a design modification, indicating that perhaps the modification review processes were not rigorous and resulted in CCF susceptibilities.
- The CCF database contains several examples where both CCF and independent events recur at some, but not all, plants, perhaps indicating ineffective root cause analysis and corrective action. Examples of repeated events are water in compressed air systems, pump seal wear-out, and turbine governor mis-adjustments. Additionally, not all plants experience the same type of recurring event. This indicates that plant-to-plant variability exists in the CCF parameters that might cause the CCF parameter estimates for some plants to be higher than the industry average, for some component and system combinations. Thus, it is very important to perform plant-specific CCF parameter estimations for plant-specific PRAs and reliability studies.

With respect to quantification of CCFs, the overall conclusion is that, based on the evaluation of over 20 years of operating experience data, CCF parameters for similar components vary among systems and failure modes.


Table 1. Component types and systems analyzed for CCF events (1980–2003).

Component Type	Systems Analyzed for Component Types	PRA-relevant Failure Mode	No. of Events for System and Component Type		Total No. of Events for Component Type	
			CCF	Independent	CCF	Independent
Air-Operated Valves	Auxiliary Feedwater (PWR)	Fail to Open	12	137	52	361
		Fail to Remain Closed	8	37		
		Spurious Operation	7	11		
		Fail to Close	17	111		
	Emergency/Essential Service Water	Fail to Open	2	23		
	High Pressure Safety Injection (PWR)	Fail to Close	1	6		
	Isolation Condenser	Spurious Operation	2	2		
	Main Steam	Fail to Open	1	4		
	Residual Heat Removal	Fail to Close	1	17		
		Fail to Open	1	13		
Batteries/Chargers	DC Power Distribution	High Output	7	46	66	1355
		No Output	59	1309		
Check Valves	Auxiliary Feedwater (PWR)	Fail to Close	16	72	172	763
		Fail to Open	5	24		
		Fail to Remain Closed	43	141		
	Containment Spray	Fail to Remain Closed	3	7		
	Containment Vacuum Relief	Fail to Open	2	11		
	Emergency/Essential Service Water	Fail to Close	5	25		
		Fail to Open	2	12		
		Fail to Remain Closed	1	10		
	High Pressure Coolant Injection (BWR)	Fail to Close	2	46		
	High Pressure Coolant Injection (BWR)	Fail to Open	7	21		
		Fail to Remain Closed	14	36		
	High Pressure Safety Injection (PWR)	Fail to Remain Closed	15	88		
Fail to Close		2	60			
Fail to Open		5	29			


Component Type	Systems Analyzed for Component Types	PRA-relevant Failure Mode	No. of Events for System and Component Type		Total No. of Events for Component Type	
			CCF	Independent	CCF	Independent
Circuit Breakers	Main Steam	Fail to Close	3	6	171	1890
	Reactor Core Isolation Cooling	Fail to Remain Closed	1	6		
	Residual Heat Removal	Fail to Close	9	86		
		Fail to Open	4	20		
	AC Power Distribution	Fail to Remain Closed	33	63		
		Fail to Close	47	571		
		Fail to Open	29	222		
	DC Power Distribution	Spurious Operation	28	443		
		Fail to Close	4	45		
		Fail to Open	4	69		
	Reactor Protection	Spurious Operation	3	70		
		Fail to Open	26	135		
Spurious Operation		5	80			
Emergency Diesel Generators	Fail to Close	25	255			
	Emergency Power	Fail to Start	63	1152	157	2099
	Fail to Stop	3	34			
Fail to Run	91	913				
Heat Exchangers	Containment Spray	No Flow/Plugged	13	17	22	50
	Isolation Condenser	No Flow/Plugged	1	3		
	Residual Heat Removal	No Flow/Plugged	8	30		
Main Steam Isolation Valves	Main Steam	Fail to Close	81	271	204	694
		Fail to Open	13	124		
		Fail to Remain Closed	72	141		
		Spurious Operation	38	158		
Motor-Operated Valves	Auxiliary Feedwater (PWR)	Spurious Operation	2	8	208	3121
		Fail to Close	10	136		
		Fail to Open	14	310		
		Fail to Remain Closed	4	55		

Component Type	Systems Analyzed for Component Types	PRA-relevant Failure Mode	No. of Events for System and Component Type		Total No. of Events for Component Type	
			CCF	Independent	CCF	Independent
Pumps	Containment Spray	Fail to Close	2	23	319	4539
		Fail to Open	12	32		
		Fail to Remain Closed	1	10		
	Emergency/Essential Service Water	Fail to Close	2	26		
		Fail to Open	2	25		
		Fail to Remain Closed	1	6		
	High Pressure Coolant Injection (BWR)	Fail to Close	2	119		
		Fail to Open	4	193		
		Fail to Remain Closed	3	55		
	High Pressure Safety Injection (PWR)	Fail to Remain Closed	6	40		
		Fail to Close	11	135		
		Fail to Open	23	283		
	Isolation Condenser	Fail to Close	1	15		
	Isolation Condenser	Fail to Open	1	32		
	Main Steam	Fail to Close	1	15		
	Reactor Coolant	Fail to Close	5	108		
		Fail to Open	1	62		
		Fail to Remain Closed	2	16		
	Reactor Core Isolation Cooling	Fail to Close	4	33		
		Fail to Open	2	54		
	Residual Heat Removal	Fail to Close	27	392		
Fail to Open		42	831			
Fail to Remain Closed		22	69			
Auxiliary Feedwater (PWR)	Spurious Operation	1	38			
	Fail to Start	29	588			
	Fail to Run	26	572			
	Fail to Start	3	48			
Emergency/Essential Service Water	Fail to Open	1	11			

Component Type	Systems Analyzed for Component Types	PRA-relevant Failure Mode	No. of Events for System and Component Type		Total No. of Events for Component Type		
			CCF	Independent	CCF	Independent	
Safety and Relief Valves	High Pressure Coolant Injection (BWR)	Fail to Run	83	1080	226	2037	
		Fail to Start	68	503			
		Fail to Stop	1	44			
		Fail to Run	1	138			
		Fail to Start	2	155			
		Fail to Stop	1	28			
		High Pressure Safety Injection (PWR)	Fail to Run	27			362
			Fail to Start	19			250
		Low Pressure Core Spray	Fail to Start	1			21
		Residual Heat Removal	Fail to Start	21			220
	Fail to Stop		2	35			
	Fail to Run		22	383			
	Standby Liquid Control	Fail to Start	3	26			
		Fail to Stop	1	8			
	Main Steam	Fail to Run	8	67			
		Fail to Close	12	147			
		Fail to Open	135	585			
Fail to Remain Closed		20	364				
Spurious Operation		18	108				
Reactor Coolant		Fail to Close	2	104			
		Fail to Open	24	286			
	Fail to Remain Closed	12	360				
	Spurious Operation	3	83				
Emergency/Essential Service Water	No Flow/Plugged	55	279	57	281		
	Residual Heat Removal	No Flow/Plugged	2			2	
			Total Events		1654	17190	




Distribution of causes of complete and partial CCF events




Distribution of causes of only the complete CCF events.

Figure 1. Distribution of CCF events by proximate cause.



Distribution of shared cause factors for both complete and partial events.



Distribution of shared cause factors for only the complete CCF events.

Figure 2. Distribution of CCF events by shared cause factor.




Figure 3. Distribution of all CCF events by year.




Figure 4. Distribution of complete CCF events by year.

