



CCF Parameter Estimations 2010

U.S. Nuclear Regulatory Commission, "CCF Parameter
Estimations, 2010 Update"

This report documents the quantitative results of the common-cause failure (CCF) data collection effort and summarizes the results of the parameter estimation quantification process, performed on CCF data in the U.S. NRC CCF database.

2010

CCF Parameter Estimations 2010

This report documents the quantitative results of the common-cause failure (CCF) data collection effort and summarizes the results of the parameter estimation quantification process, performed on CCF data in the U.S. NRC CCF database.

These results are appropriate for use in Probabilistic Risk Assessment studies of commercial nuclear power plants in the U.S.

Included in these results are the applications to be used in the SPAR Version greater than 3.45 models. This is the 2010 update to NUREG/CR-5496, updating data and parameter estimations.

This release, CCF Parameter Estimation for 2010, reflects the CCF data contained within the CCF database, Version 4.5.2010. This version of the CCF database contains data from 1997 to 2010.

The applications contained within were created with a starting date of 1/1/1997. This date was selected in order to use as much of the CCF data as possible, but to avoid using the large number of CCF events in the 1980 to 1996 period since the trend is decreasing significantly from 1980 to 1996.

The way to provide a reference for this update is:

U.S. Nuclear Regulatory Commission, "CCF Parameter Estimations, 2010 Update",
<http://nrcoe.inl.gov/results/CCF/ParamEst2010/ccfparamest.htm>, January 2012.

2010

TABLE OF CONTENTS

1 INDUSTRY COMPONENT CCF INTRODUCTION.....	9
1.1 Motor Driven Pumps	11
1.1.1 Pooled Motor Driven Pump Distributions	11
1.1.2 Pooled Pump Volutes	19
1.1.3 Pooled Clean System Motor Driven Pump Distributions.....	21
1.1.4 PWR Containment Spray Pumps.....	29
1.1.5 BWR Residual Heat Removal Pumps	33
1.1.6 AFW Motor-Driven Pumps.....	41
1.1.7 AFW Pump Volutes	49
1.1.8 Emergency Service Water Pump	51
1.1.9 PWR High Pressure Safety Injection Pump	63
1.1.10 PWR Residual Heat Removal Pump.....	71
1.1.11 BWR Standby Liquid Control Pump	79
1.1.12 Component Cooling Water Pumps.....	82
1.1.13 Positive Displacement Pumps	84
1.2 Turbine Driven Pumps	88
1.2.1 Pooled Turbine Driven Pumps	88
1.2.2 AFW Turbine-Driven Pumps	96
1.2.3 BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Pumps..	104
1.3 Motor Operated Valves.....	108
1.3.1 Pooled Motor Operated Valve Distributions	108
1.3.2 PWR Containment Spray Motor Operated Valves	119
1.3.3 BWR Residual Heat Removal Motor-Operated Valves.....	125
1.3.4 BWR Isolation Condenser Motor-Operated Valves.....	134
1.3.5 PWR Auxiliary Feedwater Motor-Operated Valves	140
1.3.6 PWR High Pressure Safety Injection Motor-Operated Valves	149
1.3.7 PWR Residual Heat Removal Motor-Operated Valves.....	158
1.3.8 BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Motor-Operated Valves	167
1.3.9 Pressurizer PORV Motor-Operated Block Valves	173
1.4 Air Operated Valves.....	177
1.4.1 Pooled Air Operated Valves	177
1.4.2 BWR Isolation Condenser Air-Operated Valves	186
1.4.3 PWR Auxiliary Feedwater Air-Operated Valves	192
1.4.4 High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated Valves	201
1.5 Check Valves.....	207
1.5.1 Pooled Check Valves	207
1.5.2 BWR Residual Heat Removal Check Valves	219
1.5.3 PWR Auxiliary Feedwater Check Valves	225
1.5.4 PWR High Pressure Safety Injection Check Valves	231
1.5.5 PWR Residual Heat Removal Check Valves	235
1.5.6 BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check Valves	241
1.6 Strainers, Trash Racks, and Filters.....	245
1.6.1 Pooled Strainers (Non-ESW)	245

1.6.2	Emergency Service Water Strainers	247
1.6.3	Pooled Sump Strainers.....	255
1.6.4	PWR Containment Sump Strainers.....	257
1.6.5	BWR Suppression Pool Strainers	258
1.6.6	Extreme Environmental Event CCF Distributions	260
1.7	Heat Exchangers	268
1.7.1	PWR HEAT EXCHANGER LOSS OF HEAT TRANSFER.....	268
1.7.2	Pooled Heat Exchanger Plugged or Failure to Transfer Heat.....	270
1.7.3	Containment Spray Heat Exchanger.....	272
1.7.4	BWR Residual Heat Removal Heat Exchanger	273
1.7.5	BWR Isolation Condenser Heat Exchanger	275
1.7.6	Component Cooling Heat Exchanger.....	277
1.8	Safety and Relief Valves.....	279
1.8.1	Pooled Safety Valves	279
1.8.2	PWR Steam Generator Safety Valves	285
1.8.3	BWR Safety Relief Valves	290
1.8.4	PWR Pressurizer Safety Valve.....	296
1.9	PORVs	301
1.9.1	Pooled PORVs	301
1.9.2	PWR Steam Generator PORV	307
1.9.3	PWR Pressurizer Power Operated Relief Valves	313
1.10	Main Steam Isolation Valves	317
1.10.1	PWR Main Steam Isolation Valves.....	317
1.10.2	BWR Main Steam Isolation Valves.....	323
1.11	Generators	329
1.11.1	Emergency Diesel Generators	329
1.12	Vacuum Breakers.....	335
1.12.1	BWR Pressure Suppression Vacuum Breakers	335
1.13	AC Power Distribution Breakers	337
1.13.1	480 Vac Circuit Breakers.....	337
1.13.2	4160 vac and 6.9Kva Distribution Circuit Breakers	346
1.14	DC Power System - Batteries, Chargers, and Breakers.....	355
1.14.1	Batteries	355
1.14.2	Battery Chargers	357
1.14.3	DC Power Distribution Circuit Breakers	361
1.15	Reactor Protection System, Reactor Trip Breakers	370
1.15.1	Reactor Trip Breakers	370
1.16	Air Compressors.....	373
1.16.1	Motor-Driven Air Compressors.....	373
2	NO DATA (PRIOR ONLY).....	377
2.2	Generic Distributions	378
2.2.1	Generic Demand CCF Distribution.....	378
2.2.2	Generic Rate CCF Distribution.....	380
2.2.3	CCF Prior Distribution.....	382
3	GLOSSARY.....	384

General CCF Information

A general conclusion from probabilistic risk assessments (PRAs) of commercial nuclear power plants is that common cause failures (CCFs) are significant contributors to the unavailability of safety systems. A CCF event consists of component failures that meet the following four criteria: (1) two or more components fail or are degraded at the same plant and in the same system, (2) component failures occur within a selected period of time such that success of the PRA mission would be uncertain, (3) the component failures result from a single shared cause and are linked by a coupling mechanism such that other components in the group are susceptible to the same cause and failure mode and, (4) the equipment failures are not caused by the failure of equipment outside the established component boundary.

In response to these deficiencies, the Idaho National Laboratory (INL) staff and the Nuclear Regulatory Commission's (NRC) Office of Nuclear Regulatory Research have developed a CCF data collection and analysis system that includes a method for identifying CCF events, coding and classifying those events for use in CCF studies, and a computer system for storing and analyzing the data. The system is based, in part, on previous CCF methods and models and is designed to run on a personal computer (PC). The data collection effort has collected CCF events from 1980 through 2010 for use in CCF analyses. The current data collection effort has separated the data by system. The principal products of this CCF data collection and analysis system (CCF database) are the method for identifying and classifying CCF events, the CCF database containing both CCF events and independent failure counts, and the CCF parameter estimation software.

Three data sources are used to select equipment failure reports to be reviewed for CCF event identification: the Nuclear Plant Reliability Data System (NPRDS), which contained component failure information prior to 1997; the Equipment Performance and Information Exchange (EPIX), which contains component failure information since 1997; and the Sequence Coding and Search System (SCSS), which contains Licensee Event Reports (LERs). All events that meet the above criteria are identified as CCF events and included in the CCF database.

2010

1 Industry Component CCF Introduction

This section contains CCF applications created for components pooled at various levels. The first level presented is the industry-wide component specific pooled distribution. The pooled distribution represents the pooling of the more specific distributions shown under the pooled distribution. Typically, the pooling takes place across systems.

It is up to the user to decide the level of pooling that is appropriate to the intended use. If data exist at the system/component level most appropriate to the intended use, and are not sparse, it is recommended to use the more specific data. Otherwise, it is recommended to use the industry level pooled component data. If no pooled components are listed that are similar to the intended use, the use of the Generic Demand, Generic Rate, or the No Data (Prior Only) pooled distribution may be appropriate.

This update to the parameter estimation report includes the SPAR alpha factor basic event name to facilitate the cross reference of this report to the SPAR models. The SPAR basic event name can be found in the title of the application report and in the topic text if SPAR uses the parameter estimate.

2010

1.1 Motor Driven Pumps

1.1.1 Pooled Motor Driven Pump Distributions

1.1.1.1 MOTOR DRIVEN PUMP FAIL TO START ALL SYSTEMS SPAR: MDP-FS

Component : Motor Driven Pump
Failure Mode : Fail to start
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 557.40

Total Number of Common-Cause Failure Events: 23

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9608200	0.9750580	0.9758710	0.9865300	0.9755030	3.7868E+02	9.6868E+00
α_2	1.35E-02	2.49E-02	2.41E-02	3.92E-02	2.45E-02	9.6868E+00	3.7868E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9650900	0.9762240	0.9767570	0.9855350	0.9768880	5.7666E+02	1.4045E+01
α_2	7.22E-03	1.42E-02	1.36E-02	2.30E-02	1.35E-02	8.3706E+00	5.8233E+02
α_3	4.08E-03	9.61E-03	9.06E-03	1.70E-02	9.65E-03	5.6739E+00	5.8503E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9667980	0.9763300	0.9767290	0.9844910	0.9773010	7.7044E+02	1.8678E+01
α_2	7.37E-03	1.33E-02	1.29E-02	2.06E-02	1.25E-02	1.0495E+01	7.7862E+02
α_3	2.72E-03	6.68E-03	6.26E-03	1.20E-02	6.56E-03	5.2679E+00	7.8385E+02
α_4	9.84E-04	3.69E-03	3.28E-03	7.81E-03	3.63E-03	2.9155E+00	7.8620E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9710010	0.9788930	0.9792070	0.9857150	0.9804490	1.0000E+03	2.1563E+01
α_2	4.88E-03	9.18E-03	8.86E-03	1.46E-02	7.88E-03	9.3749E+00	1.0122E+03
α_3	2.99E-03	6.51E-03	6.19E-03	1.11E-02	6.16E-03	6.6546E+00	1.0149E+03
α_4	1.41E-03	4.03E-03	3.71E-03	7.74E-03	4.06E-03	4.1161E+00	1.0174E+03
α_5	1.48E-04	1.39E-03	1.08E-03	3.68E-03	1.46E-03	1.4170E+00	1.0201E+03

Pooled Motor Driven Pump Distributions

MOTOR DRIVEN PUMP FAIL TO START ALL SYSTEMS SPAR: MDP-FS

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9739920	0.9808480	0.9811070	0.9868090	0.9826230	1.2002E+03	2.3435E+01
α_2	3.48E-03	6.85E-03	6.58E-03	1.11E-02	5.57E-03	8.3787E+00	1.2153E+03
α_3	2.48E-03	5.41E-03	5.14E-03	9.25E-03	4.97E-03	6.6207E+00	1.2170E+03
α_4	1.57E-03	4.02E-03	3.76E-03	7.38E-03	3.93E-03	4.9226E+00	1.2187E+03
α_5	5.70E-04	2.25E-03	1.99E-03	4.84E-03	2.30E-03	2.7582E+00	1.2209E+03
α_6	1.40E-05	6.17E-04	3.75E-04	2.04E-03	6.10E-04	7.5524E-01	1.2229E+03

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9755030	0.9768880	0.9773010	0.9804490	0.9826230
α_2	2.45E-02	1.35E-02	1.25E-02	7.88E-03	5.57E-03
α_3		9.65E-03	6.56E-03	6.16E-03	4.97E-03
α_4			3.63E-03	4.06E-03	3.93E-03
α_5				1.46E-03	2.30E-03
α_6					6.10E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.76E-01	9.77E-01	9.77E-01	9.80E-01	9.83E-01
Beta	2.45E-02	2.31E-02	2.27E-02	1.96E-02	1.74E-02
Gamma		4.18E-01	4.49E-01	5.97E-01	6.80E-01
Delta			3.56E-01	4.73E-01	5.79E-01
Epsilon				2.64E-01	4.26E-01
Mu					2.09E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	356.17	534.25	712.33	890.42	1068.50
N₁	12.2620	12.8561	11.9692	13.4597	14.7926
N₂	9.2523	7.5369	9.2664	7.2607	6.1395
N₃		5.4067	4.8636	5.6772	5.4789
N₄			2.6928	3.7417	4.3304
N₅				1.3447	2.5360
N₆					0.6720

1.1.1.2 MOTOR DRIVEN PUMP FTR LESS THAN 1H ALL SYSTEMS

Component : Motor Driven Pump
Failure Mode : Fail to Run less than 1 Hour
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 42.80

Total Number of Common-Cause Failure Events: 4

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8985690	0.9573340	0.9641160	0.9928560	0.9566930	4.1909E+01	1.8678E+00
α_2	7.15E-03	4.27E-02	3.59E-02	1.01E-01	4.33E-02	1.8678E+00	4.1909E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9147280	0.9572930	0.9610980	0.9868490	0.9529990	7.5785E+01	3.3809E+00
α_2	8.00E-03	3.29E-02	2.90E-02	7.10E-02	3.65E-02	2.6037E+00	7.6562E+01
α_3	2.48E-04	9.82E-03	6.11E-03	3.20E-02	1.05E-02	7.7722E-01	7.8389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9145520	0.9517650	0.9544500	0.9798040	0.9445280	1.0612E+02	5.3781E+00
α_2	1.23E-02	3.56E-02	3.28E-02	6.82E-02	4.31E-02	3.9641E+00	1.0753E+02
α_3	3.72E-04	8.43E-03	5.73E-03	2.57E-02	8.44E-03	9.4031E-01	1.1056E+02
α_4	1.25E-05	4.25E-03	1.85E-03	1.66E-02	3.95E-03	4.7367E-01	1.1102E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9316870	0.9587200	0.9604300	0.9799160	0.9513600	1.7077E+02	7.3529E+00
α_2	8.76E-03	2.41E-02	2.24E-02	4.56E-02	2.79E-02	4.3015E+00	1.7382E+02
α_3	2.24E-03	1.18E-02	1.00E-02	2.74E-02	1.43E-02	2.1001E+00	1.7602E+02
α_4	9.59E-05	4.23E-03	2.58E-03	1.40E-02	4.84E-03	7.5389E-01	1.7737E+02
α_5	9.40E-10	1.11E-03	1.11E-04	5.73E-03	1.60E-03	1.9738E-01	1.7793E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9368060	0.9607400	0.9621630	0.9798080	0.9555920	2.0608E+02	8.4212E+00
α_2	6.91E-03	1.95E-02	1.80E-02	3.71E-02	2.07E-02	4.1747E+00	2.1033E+02
α_3	2.53E-03	1.13E-02	9.83E-03	2.52E-02	1.38E-02	2.4265E+00	2.1207E+02
α_4	4.38E-04	5.60E-03	4.16E-03	1.57E-02	6.53E-03	1.2016E+00	2.1330E+02
α_5	6.41E-06	2.20E-03	9.55E-04	8.63E-03	2.69E-03	4.7270E-01	2.1403E+02
α_6	3.47E-12	6.79E-04	2.54E-05	3.76E-03	6.70E-04	1.4574E-01	2.1436E+02

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9566930	0.9529990	0.9445280	0.9513600	0.9555920
α_2	4.33E-02	3.65E-02	4.31E-02	2.79E-02	2.07E-02
α_3		1.05E-02	8.44E-03	1.43E-02	1.38E-02
α_4			3.95E-03	4.84E-03	6.53E-03
α_5				1.60E-03	2.69E-03
α_6					6.70E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.57E-01	9.53E-01	9.45E-01	9.51E-01	9.56E-01
Beta	4.33E-02	4.70E-02	5.55E-02	4.86E-02	4.44E-02
Gamma		2.24E-01	2.23E-01	4.27E-01	5.33E-01
Delta			3.19E-01	3.10E-01	4.18E-01
Epsilon				2.48E-01	3.39E-01
Mu					2.00E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	28.53	42.80	57.07	71.33	85.60
N ₁	3.1333	3.4300	2.9160	3.2805	3.5429
N ₂	1.4333	1.7700	2.7360	2.1873	1.9355
N ₃		0.5100	0.5360	1.1227	1.2847
N ₄			0.2510	0.3795	0.6094
N ₅				0.1251	0.2505
N ₆					0.0625

1.1.1.3 MOTOR DRIVEN PUMP FAIL TO RUN >1H ALL SYSTEMS**Component :**

Motor Driven Pump

Failure Mode :

Fail to Run >1 Hour (Standby equipment)

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 128.20

Total Number of Common-Cause Failure Events: 8

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9340410	0.9687610	0.9721660	0.9918260	0.9700320	8.7273E+01	2.8142E+00
α_2	8.18E-03	3.12E-02	2.78E-02	6.60E-02	3.00E-02	2.8142E+00	8.7273E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9320010	0.9611610	0.9632330	0.9832490	0.9603910	1.4173E+02	5.7271E+00
α_2	1.23E-02	3.19E-02	2.98E-02	5.87E-02	3.31E-02	4.7035E+00	1.4275E+02
α_3	3.80E-04	6.94E-03	4.88E-03	2.06E-02	6.48E-03	1.0236E+00	1.4643E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9370740	0.9615800	0.9630990	0.9808990	0.9616540	1.9399E+02	7.7510E+00
α_2	8.88E-03	2.32E-02	2.17E-02	4.29E-02	2.25E-02	4.6842E+00	1.9706E+02
α_3	3.08E-03	1.29E-02	1.13E-02	2.80E-02	1.42E-02	2.5933E+00	1.9915E+02
α_4	6.89E-06	2.35E-03	1.02E-03	9.18E-03	1.63E-03	4.7347E-01	2.0127E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9476420	0.9665910	0.9676550	0.9818990	0.9676800	2.8065E+02	9.7003E+00
α_2	5.97E-03	1.58E-02	1.47E-02	2.95E-02	1.30E-02	4.5989E+00	2.8575E+02
α_3	3.15E-03	1.09E-02	9.85E-03	2.25E-02	1.15E-02	3.1788E+00	2.8717E+02
α_4	8.69E-04	5.94E-03	4.85E-03	1.47E-02	7.09E-03	1.7252E+00	2.8863E+02
α_5	5.76E-10	6.80E-04	6.82E-05	3.52E-03	6.56E-04	1.9738E-01	2.9015E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9528690	0.9693930	0.9702890	0.9828700	0.9718920	3.3805E+02	1.0673E+01
α_2	4.13E-03	1.18E-02	1.09E-02	2.26E-02	8.25E-03	4.1164E+00	3.4461E+02
α_3	2.66E-03	9.18E-03	8.26E-03	1.88E-02	9.05E-03	3.2010E+00	3.4552E+02
α_4	1.20E-03	6.16E-03	5.25E-03	1.43E-02	6.84E-03	2.1495E+00	3.4657E+02
α_5	1.80E-04	3.04E-03	2.16E-03	8.91E-03	3.69E-03	1.0608E+00	3.4766E+02
α_6	2.13E-12	4.18E-04	1.56E-05	2.31E-03	2.75E-04	1.4574E-01	3.4858E+02

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9700320	0.9603910	0.9616540	0.9676800	0.9718920
α_2	3.00E-02	3.31E-02	2.25E-02	1.30E-02	8.25E-03
α_3		6.48E-03	1.42E-02	1.15E-02	9.05E-03
α_4			1.63E-03	7.09E-03	6.84E-03
α_5				6.56E-04	3.69E-03
α_6					2.75E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.70E-01	9.60E-01	9.62E-01	9.68E-01	9.72E-01
Beta	3.00E-02	3.96E-02	3.83E-02	3.23E-02	2.81E-02
Gamma		1.64E-01	4.14E-01	5.97E-01	7.06E-01
Delta			1.03E-01	4.01E-01	5.44E-01
Epsilon				8.48E-02	3.67E-01
Mu					6.94E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	73.26	109.89	146.51	183.14	219.77
N ₁	3.7673	2.2812	1.3486	1.3532	1.3444
N ₂	2.3797	3.8698	3.4561	2.4847	1.8772
N ₃		0.7564	2.1890	2.2014	2.0592
N ₄			0.2508	1.3508	1.5573
N ₅				0.1251	0.8386
N ₆					0.0625

1.1.1.4 MOTOR DRIVEN PUMP FAIL TO RUN ALL SYSTEMS SPAR: MDP-FR**Component :**

Motor Driven Pump

Failure Mode :

Fail to Run >1 Hour (Standby equipment)

Fail to Run less than 1 Hour

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 171.00

Total Number of Common-Cause Failure Events: 12

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9354480	0.9657730	0.9682500	0.9876320	0.9663800	1.1985E+02	4.2475E+00
α_2	1.24E-02	3.42E-02	3.18E-02	6.46E-02	3.36E-02	4.2475E+00	1.1985E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9340330	0.9594220	0.9609680	0.9795370	0.9585630	1.8932E+02	8.0071E+00
α_2	1.50E-02	3.28E-02	3.12E-02	5.60E-02	3.38E-02	6.4735E+00	1.9085E+02
α_3	9.51E-04	7.77E-03	6.18E-03	2.00E-02	7.60E-03	1.5336E+00	1.9579E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9358230	0.9577890	0.9589260	0.9758660	0.9570100	2.5581E+02	1.1274E+01
α_2	1.35E-02	2.78E-02	2.66E-02	4.61E-02	2.83E-02	7.4202E+00	2.5966E+02
α_3	3.33E-03	1.17E-02	1.05E-02	2.42E-02	1.24E-02	3.1293E+00	2.6395E+02
α_4	5.35E-05	2.71E-03	1.61E-03	9.11E-03	2.29E-03	7.2447E-01	2.6636E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9463100	0.9635780	0.9644110	0.9780160	0.9632360	3.5755E+02	1.3515E+01
α_2	8.51E-03	1.83E-02	1.74E-02	3.10E-02	1.72E-02	6.7862E+00	3.6428E+02
α_3	4.18E-03	1.16E-02	1.07E-02	2.20E-02	1.22E-02	4.3015E+00	3.6676E+02
α_4	1.08E-03	5.67E-03	4.81E-03	1.32E-02	6.38E-03	2.1047E+00	3.6896E+02
α_5	1.76E-07	8.69E-04	2.38E-04	3.88E-03	9.22E-04	3.2248E-01	3.7074E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9516120	0.9666870	0.9673830	0.9793760	0.9674300	4.2994E+02	1.4816E+01
α_2	5.98E-03	1.36E-02	1.29E-02	2.37E-02	1.18E-02	6.0520E+00	4.3870E+02
α_3	3.73E-03	1.01E-02	9.36E-03	1.89E-02	1.03E-02	4.4857E+00	4.4027E+02
α_4	1.57E-03	6.20E-03	5.48E-03	1.33E-02	6.70E-03	2.7589E+00	4.4200E+02
α_5	2.73E-04	2.95E-03	2.25E-03	8.03E-03	3.37E-03	1.3114E+00	4.4344E+02
α_6	8.35E-10	4.68E-04	5.40E-05	2.39E-03	3.86E-04	2.0824E-01	4.4455E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9663800	0.9585630	0.9570100	0.9632360	0.9674300
α_2	3.36E-02	3.38E-02	2.83E-02	1.72E-02	1.18E-02
α_3		7.60E-03	1.24E-02	1.22E-02	1.03E-02
α_4			2.29E-03	6.38E-03	6.70E-03
α_5				9.22E-04	3.37E-03
α_6					3.86E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.66E-01	9.59E-01	9.57E-01	9.63E-01	9.67E-01
Beta	3.36E-02	4.14E-02	4.30E-02	3.68E-02	3.26E-02
Gamma		1.83E-01	3.43E-01	5.32E-01	6.38E-01
Delta			1.56E-01	3.73E-01	5.03E-01
Epsilon				1.26E-01	3.59E-01
Mu					1.03E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	102.70	154.05	205.41	256.76	308.11
N ₁	6.9007	5.7112	4.2646	4.6337	4.8873
N ₂	3.8130	5.6398	6.1921	4.6720	3.8128
N ₃		1.2664	2.7250	3.3241	3.3439
N ₄			0.5018	1.7303	2.1667
N ₅				0.2502	1.0892
N ₆					0.1250

1.1.2 Pooled Pump Volutes

1.1.2.1 CLEAN SYSTEM PUMP VOLUTES FAIL TO RUN SPAR: PMP-FR

System :	Chemical and volume control Component cooling water Auxiliary feedwater Containment spray recirculation Low pressure core spray Residual Heat Removal (LCI in BWRs, LPI in PWRs) Standby liquid control
Component :	Motor Driven Pump
Failure Mode :	Fail to Run (Normally running equipment) Fail to Run >1 Hour (Standby equipment) Fail to Run less than 1 Hour
Subcomponent :	Pump
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 97.00

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9575160	0.9818490	0.9846320	0.9966690	0.9842210	1.1005E+02	2.0345E+00
α_2	3.33E-03	1.82E-02	1.54E-02	4.25E-02	1.58E-02	2.0345E+00	1.1005E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9624930	0.9813850	0.9831210	0.9943370	0.9848970	1.7824E+02	3.3809E+00
α_2	2.81E-03	1.30E-02	1.12E-02	2.91E-02	1.01E-02	2.3537E+00	1.7927E+02
α_3	3.12E-04	5.66E-03	3.98E-03	1.67E-02	5.03E-03	1.0272E+00	1.8059E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9647320	0.9808580	0.9821320	0.9926260	0.9855330	2.4355E+02	4.7531E+00
α_2	2.73E-03	1.09E-02	9.65E-03	2.35E-02	7.42E-03	2.7141E+00	2.4559E+02
α_3	6.38E-04	5.80E-03	4.54E-03	1.53E-02	5.17E-03	1.4403E+00	2.4686E+02
α_4	2.25E-05	2.41E-03	1.27E-03	8.67E-03	1.88E-03	5.9867E-01	2.4770E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9842210	0.9848970	0.9855330
α_2	1.58E-02	1.01E-02	7.42E-03
α_3		5.03E-03	5.17E-03
α_4			1.88E-03

CLEAN SYSTEM PUMP VOLUTES FAIL TO RUN SPAR: PMP-FR

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.84E-01	9.85E-01	9.86E-01
Beta	1.58E-02	1.51E-02	1.45E-02
Gamma		3.33E-01	4.87E-01
Delta			2.66E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	97.00	145.50	194.00
N ₁	2.8000	3.1800	3.4160
N ₂	1.6000	1.5200	1.4860
N ₃		0.7600	1.0360
N ₄			0.3760

1.1.3 Pooled Clean System Motor Driven Pump Distributions

1.1.3.1 CLEAN SYSTEM MOTOR DRIVEN PUMPS FAIL TO START SPAR: MDP-FS

System :	Chemical and volume control Component cooling water Auxiliary feedwater Containment spray recirculation High pressure core spray High pressure coolant injection High pressure injection Low pressure core spray Reactor core isolation Residual Heat Removal (LCI in BWRs, LPI in PWRs) Standby liquid control
Component :	
Failure Mode :	Motor Driven Pump
Start Date :	Fail to start
Data Version :	1997/01/01
	2010/12/31

Total Number of Independent Failure Events: 381.00

Total Number of Common-Cause Failure Events: 15

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9552730	0.9721350	0.9731390	0.9855530	0.9725900	3.0228E+02	8.6645E+00
α_2	1.44E-02	2.79E-02	2.69E-02	4.47E-02	2.74E-02	8.6645E+00	3.0228E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9639610	0.9764120	0.9770780	0.9866010	0.9772600	4.6476E+02	1.1228E+01
α_2	5.07E-03	1.19E-02	1.13E-02	2.11E-02	1.09E-02	5.6787E+00	4.7031E+02
α_3	4.89E-03	1.17E-02	1.10E-02	2.07E-02	1.19E-02	5.5489E+00	4.7044E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9670490	0.9774790	0.9779790	0.9862160	0.9787930	6.2324E+02	1.4359E+01
α_2	5.16E-03	1.10E-02	1.05E-02	1.85E-02	9.77E-03	6.9894E+00	6.3061E+02
α_3	2.63E-03	7.08E-03	6.58E-03	1.33E-02	6.97E-03	4.5167E+00	6.3308E+02
α_4	1.17E-03	4.47E-03	3.97E-03	9.51E-03	4.46E-03	2.8530E+00	6.3475E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9711420	0.9797600	0.9801400	0.9870710	0.9818320	8.1651E+02	1.6868E+01
α_2	3.69E-03	8.02E-03	7.63E-03	1.37E-02	6.23E-03	6.6839E+00	8.2669E+02
α_3	2.44E-03	6.11E-03	5.72E-03	1.11E-02	5.60E-03	5.0884E+00	8.2829E+02
α_4	1.44E-03	4.45E-03	4.06E-03	8.79E-03	4.55E-03	3.7099E+00	8.2967E+02
α_5	1.70E-04	1.66E-03	1.29E-03	4.44E-03	1.79E-03	1.3857E+00	8.3199E+02

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9740970	0.9815920	0.9819100	0.9879940	0.9839250	9.8042E+02	1.8386E+01
α_2	2.73E-03	6.17E-03	5.84E-03	1.07E-02	4.47E-03	6.1598E+00	9.9265E+02
α_3	1.90E-03	4.88E-03	4.55E-03	8.97E-03	4.25E-03	4.8699E+00	9.9394E+02
α_4	1.42E-03	4.08E-03	3.76E-03	7.86E-03	3.97E-03	4.0769E+00	9.9473E+02
α_5	5.93E-04	2.54E-03	2.22E-03	5.60E-03	2.64E-03	2.5395E+00	9.9627E+02
α_6	1.57E-05	7.41E-04	4.45E-04	2.47E-03	7.48E-04	7.3964E-01	9.9807E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9725900	0.9772600	0.9787930	0.9818320	0.9839250
α_2	2.74E-02	1.09E-02	9.77E-03	6.23E-03	4.47E-03
α_3		1.19E-02	6.97E-03	5.60E-03	4.25E-03
α_4			4.46E-03	4.55E-03	3.97E-03
α_5				1.79E-03	2.64E-03
α_6					7.48E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.73E-01	9.77E-01	9.79E-01	9.82E-01	9.84E-01
Beta	2.74E-02	2.27E-02	2.12E-02	1.82E-02	1.61E-02
Gamma		5.22E-01	5.39E-01	6.57E-01	7.22E-01
Delta			3.90E-01	5.31E-01	6.34E-01
Epsilon				2.83E-01	4.60E-01
Mu					2.21E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	285.39	428.09	570.79	713.48	856.18
N₁	6.6400	7.1150	6.3171	6.8643	7.3041
N₂	8.2300	4.8450	5.7613	4.5697	3.9206
N₃		5.2817	4.1124	4.1110	3.7281
N₄			2.6303	3.3355	3.4847
N₅				1.3134	2.3173
N₆					0.6564

1.1.3.2 CLEAN SYSTEM MDP-FTR LESS THAN 1 HOUR**System :**

Chemical and volume control
 Component cooling water
 Auxiliary feedwater
 Containment spray recirculation
 High pressure core spray
 High pressure coolant injection
 High pressure injection
 Low pressure core spray
 Reactor core isolation
 Residual Heat Removal (LCI in BWRs, LPI in PWRs)
 Standby liquid control

Component :

Failure Mode : Fail to Run less than 1 Hour
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 23.20

Total Number of Common-Cause Failure Events: 3

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8696580	0.9464930	0.9556130	0.9920580	0.9400050	3.0093E+01	1.7012E+00
α_2	7.94E-03	5.35E-02	4.44E-02	1.30E-01	6.00E-02	1.7012E+00	3.0093E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9022760	0.9531070	0.9579560	0.9873490	0.9421700	5.8555E+01	2.8809E+00
α_2	6.62E-03	3.42E-02	2.93E-02	7.87E-02	4.13E-02	2.1037E+00	5.9332E+01
α_3	3.20E-04	1.27E-02	7.89E-03	4.12E-02	1.66E-02	7.7722E-01	6.0659E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9075840	0.9503560	0.9537340	0.9815800	0.9372370	8.3812E+01	4.3781E+00
α_2	9.23E-03	3.36E-02	3.01E-02	6.99E-02	4.32E-02	2.9641E+00	8.5226E+01
α_3	4.72E-04	1.07E-02	7.26E-03	3.25E-02	1.33E-02	9.4031E-01	8.7250E+01
α_4	1.59E-05	5.37E-03	2.34E-03	2.10E-02	6.24E-03	4.7367E-01	8.7716E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9272970	0.9574330	0.9594610	0.9806310	0.9431910	1.4289E+02	6.3529E+00
α_2	7.85E-03	2.44E-02	2.23E-02	4.80E-02	3.07E-02	3.6349E+00	1.4561E+02
α_3	1.80E-03	1.18E-02	9.74E-03	2.91E-02	1.59E-02	1.7667E+00	1.4748E+02
α_4	1.15E-04	5.05E-03	3.08E-03	1.67E-02	7.66E-03	7.5389E-01	1.4849E+02
α_5	1.12E-09	1.32E-03	1.33E-04	6.84E-03	2.52E-03	1.9738E-01	1.4905E+02

Pooled Clean System Motor Driven Pump Distributions

CLEAN SYSTEM MDP-FTR LESS THAN 1 HOUR

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9319160	0.9587780	0.9604700	0.9798640	0.9465690	1.7261E+02	7.4212E+00
α_2	6.80E-03	2.07E-02	1.90E-02	4.06E-02	2.54E-02	3.7303E+00	1.7630E+02
α_3	1.95E-03	1.10E-02	9.26E-03	2.61E-02	1.43E-02	1.9820E+00	1.7805E+02
α_4	3.84E-04	6.06E-03	4.35E-03	1.75E-02	8.47E-03	1.0905E+00	1.7894E+02
α_5	7.64E-06	2.63E-03	1.14E-03	1.03E-02	4.26E-03	4.7270E-01	1.7956E+02
α_6	4.14E-12	8.10E-04	3.02E-05	4.48E-03	1.06E-03	1.4574E-01	1.7989E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9400050	0.9421700	0.9372370	0.9431910	0.9465690
α_2	6.00E-02	4.13E-02	4.32E-02	3.07E-02	2.54E-02
α_3		1.66E-02	1.33E-02	1.59E-02	1.43E-02
α_4			6.24E-03	7.66E-03	8.47E-03
α_5				2.52E-03	4.26E-03
α_6					1.06E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.40E-01	9.42E-01	9.37E-01	9.43E-01	9.47E-01
Beta	6.00E-02	5.78E-02	6.28E-02	5.68E-02	5.34E-02
Gamma		2.87E-01	3.12E-01	4.60E-01	5.26E-01
Delta			3.19E-01	3.90E-01	4.91E-01
Epsilon				2.48E-01	3.86E-01
Mu					2.00E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	17.38	26.07	34.76	43.45	52.13
N₁	2.4667	2.9300	2.9160	3.2805	3.5429
N₂	1.2667	1.2700	1.7360	1.5207	1.4911
N₃		0.5100	0.5360	0.7893	0.8402
N₄			0.2510	0.3795	0.4983
N₅				0.1251	0.2505
N₆					0.0625

1.1.3.3 CLEAN SYSTEM MDP-FTR LESS THAN AND > 1 HOUR SPAR: MDP-FR

System :

Chemical and volume control
 Component cooling water
 Auxiliary feedwater
 Containment spray recirculation
 High pressure core spray
 High pressure coolant injection
 High pressure injection
 Low pressure core spray
 Reactor core isolation
 Residual Heat Removal (LCI in BWRs, LPI in PWRs)
 Standby liquid control

Component :

Motor Driven Pump

Failure Mode :

Fail to Run (Normally running equipment)
 Fail to Run >1 Hour (Standby equipment)
 Fail to Run less than 1 Hour

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 246.60

Total Number of Common-Cause Failure Events: 11

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9530200	0.9739780	0.9755720	0.9895000	0.9748200	1.9157E+02	5.1182E+00
α_2	1.05E-02	2.60E-02	2.44E-02	4.70E-02	2.52E-02	5.1182E+00	1.9157E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9546770	0.9717820	0.9728020	0.9853900	0.9726390	2.9727E+02	8.6319E+00
α_2	8.83E-03	2.00E-02	1.89E-02	3.46E-02	1.91E-02	6.1047E+00	2.9980E+02
α_3	1.92E-03	8.26E-03	7.22E-03	1.82E-02	8.21E-03	2.5272E+00	3.0337E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9593140	0.9734890	0.9742500	0.9850600	0.9750900	4.0105E+02	1.0922E+01
α_2	6.32E-03	1.45E-02	1.37E-02	2.53E-02	1.30E-02	5.9661E+00	4.0601E+02
α_3	2.79E-03	8.76E-03	7.97E-03	1.74E-02	8.80E-03	3.6070E+00	4.0836E+02
α_4	3.20E-04	3.27E-03	2.51E-03	8.83E-03	3.09E-03	1.3487E+00	4.1062E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9639460	0.9756190	0.9761890	0.9853440	0.9780670	5.3872E+02	1.3463E+01
α_2	4.69E-03	1.08E-02	1.02E-02	1.89E-02	8.48E-03	5.9530E+00	5.4623E+02
α_3	2.89E-03	7.93E-03	7.34E-03	1.50E-02	7.52E-03	4.3779E+00	5.4780E+02
α_4	1.04E-03	4.52E-03	3.94E-03	1.00E-02	4.69E-03	2.4970E+00	5.4969E+02
α_5	1.37E-05	1.15E-03	6.30E-04	4.05E-03	1.24E-03	6.3488E-01	5.5155E+02

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9671180	0.9773650	0.9778460	0.9859820	0.9802020	6.4708E+02	1.4986E+01
α_2	3.58E-03	8.49E-03	8.00E-03	1.51E-02	6.25E-03	5.6206E+00	6.5645E+02
α_3	2.29E-03	6.41E-03	5.92E-03	1.22E-02	5.74E-03	4.2444E+00	6.5782E+02
α_4	1.40E-03	4.84E-03	4.35E-03	9.95E-03	4.83E-03	3.2027E+00	6.5886E+02
α_5	2.92E-04	2.35E-03	1.87E-03	6.04E-03	2.46E-03	1.5538E+00	6.6051E+02
α_6	2.96E-07	5.51E-04	1.78E-04	2.36E-03	5.20E-04	3.6454E-01	6.6170E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9748200	0.9726390	0.9750900	0.9780670	0.9802020
α_2	2.52E-02	1.91E-02	1.30E-02	8.48E-03	6.25E-03
α_3		8.21E-03	8.80E-03	7.52E-03	5.74E-03
α_4			3.09E-03	4.69E-03	4.83E-03
α_5				1.24E-03	2.46E-03
α_6					5.20E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.75E-01	9.73E-01	9.75E-01	9.78E-01	9.80E-01
Beta	2.52E-02	2.74E-02	2.49E-02	2.19E-02	1.98E-02
Gamma		3.00E-01	4.77E-01	6.13E-01	6.84E-01
Delta			2.60E-01	4.41E-01	5.76E-01
Epsilon				2.10E-01	3.82E-01
Mu					1.74E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	174.89	262.34	349.79	437.23	524.68
N₁	6.4327	5.3780	5.1231	5.3317	5.4585
N₂	4.6837	5.2710	4.7380	3.8388	3.3814
N₃		2.2600	3.2027	3.4005	3.1026
N₄			1.1260	2.1226	2.6105
N₅				0.5626	1.3316
N₆					0.2813

Motor Driven Pumps
 Pooled Clean System Motor Driven Pump Distributions
 CLEAN SYSTEM MDP-FTR > 1 HOUR

2010

1.1.3.4 CLEAN SYSTEM MDP-FTR > 1 HOUR

System :	Chemical and volume control Component cooling water Auxiliary feedwater Containment spray recirculation High pressure core spray High pressure coolant injection High pressure injection Low pressure core spray Reactor core isolation Residual Heat Removal (LCI in BWRs, LPI in PWRs) Standby liquid control
Component :	Motor Driven Pump
Failure Mode :	Fail to Run > 1 Hour (Standby equipment)
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 46.50

Total Number of Common-Cause Failure Events: 4

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040790	0.9592390	0.9655290	0.9928640	0.9592160	4.5532E+01	1.9348E+00
α_2	7.14E-03	4.08E-02	3.45E-02	9.59E-02	4.08E-02	1.9348E+00	4.5532E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9164040	0.9574170	0.9609770	0.9862360	0.9536240	8.0983E+01	3.6019E+00
α_2	8.84E-03	3.35E-02	2.99E-02	7.05E-02	3.71E-02	2.8347E+00	8.1750E+01
α_3	2.19E-04	9.07E-03	5.60E-03	2.97E-02	9.27E-03	7.6722E-01	8.3818E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9295320	0.9619860	0.9645480	0.9856740	0.9624210	1.1448E+02	4.5238E+00
α_2	4.79E-03	2.08E-02	1.82E-02	4.59E-02	1.76E-02	2.4801E+00	1.1652E+02
α_3	1.69E-03	1.32E-02	1.06E-02	3.37E-02	1.64E-02	1.5710E+00	1.1743E+02
α_4	1.16E-05	3.97E-03	1.73E-03	1.55E-02	3.52E-03	4.7267E-01	1.1853E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9420430	0.9661470	0.9677880	0.9846360	0.9679990	1.8141E+02	6.3565E+00
α_2	4.32E-03	1.58E-02	1.42E-02	3.31E-02	9.76E-03	2.9740E+00	1.8479E+02
α_3	2.19E-03	1.13E-02	9.66E-03	2.63E-02	1.31E-02	2.1302E+00	1.8564E+02
α_4	3.30E-04	5.62E-03	3.99E-03	1.65E-02	7.73E-03	1.0550E+00	1.8671E+02
α_5	8.85E-10	1.05E-03	1.05E-04	5.44E-03	1.42E-03	1.9728E-01	1.8757E+02

Pooled Clean System Motor Driven Pump Distributions

CLEAN SYSTEM MDP-FTR > 1 HOUR

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9468510	0.9680880	0.9694560	0.9846480	0.9719910	2.1908E+02	7.2218E+00
α_2	3.36E-03	1.27E-02	1.13E-02	2.69E-02	6.06E-03	2.8761E+00	2.2343E+02
α_3	1.78E-03	9.33E-03	7.93E-03	2.17E-02	9.24E-03	2.1125E+00	2.2419E+02
α_4	7.43E-04	6.50E-03	5.12E-03	1.70E-02	8.37E-03	1.4718E+00	2.2483E+02
α_5	2.87E-05	2.72E-03	1.46E-03	9.69E-03	3.74E-03	6.1570E-01	2.2569E+02
α_6	3.29E-12	6.44E-04	2.40E-05	3.57E-03	5.95E-04	1.4574E-01	2.2616E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9592160	0.9536240	0.9624210	0.9679990	0.9719910
α_2	4.08E-02	3.71E-02	1.76E-02	9.76E-03	6.06E-03
α_3		9.27E-03	1.64E-02	1.31E-02	9.24E-03
α_4			3.52E-03	7.73E-03	8.37E-03
α_5				1.42E-03	3.74E-03
α_6					5.95E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.59E-01	9.54E-01	9.62E-01	9.68E-01	9.72E-01
Beta	4.08E-02	4.64E-02	3.76E-02	3.20E-02	2.80E-02
Gamma		2.00E-01	5.31E-01	6.95E-01	7.84E-01
Delta			1.76E-01	4.11E-01	5.79E-01
Epsilon				1.55E-01	3.41E-01
Mu					1.37E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	33.82	50.73	67.64	84.55	101.45
N₁	1.4660	0.6980	0.7071	0.6971	0.6864
N₂	1.5003	2.0010	1.2520	0.8598	0.6369
N₃		0.5000	1.1667	1.1528	0.9707
N₄			0.2500	0.6806	0.8796
N₅				0.1250	0.3935
N₆					0.0625

1.1.4 PWR Containment Spray Pumps

1.1.4.1 CONTAINMENT SPRAY MDP-FS

System :	Containment spray recirculation
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 29.00

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8766840	0.9430560	0.9497220	0.9865860	0.9377850	4.1146E+01	2.4845E+00
α_2	1.34E-02	5.69E-02	5.03E-02	1.23E-01	6.22E-02	2.4845E+00	4.1146E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	0.9377850
α_2	6.22E-02

MGL Parameter	CCCG=2
1-Beta	9.38E-01
Beta	6.22E-02

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	29.00
N_1	1.9000
N_2	2.0500

1.1.4.2 CONTAINMENT SPRAY FTR LESS THAN 1H MDP-FH

System : Containment spray recirculation
Component : Motor Driven Pump
Failure Mode : Fail to Run less than 1 Hour
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 7.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9017830	0.9754240	0.9898730	0.9999510	1.0000000	1.7246E+01	4.3452E-01
α_2	4.52E-05	2.46E-02	1.01E-02	9.82E-02	0.00E+00	4.3452E-01	1.7246E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	7.00
N_1	0.0000
N_2	0.0000

1.1.4.3 CONTAINMENT SPRAY MDP-FTR LESS THAN AND > 1 HOUR

System :	Containment spray recirculation
Component :	Motor Driven Pump
Failure Mode :	Fail to Run >1 Hour (Standby equipment) Fail to Run less than 1 Hour
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 12.60

Total Number of Common-Cause Failure Events: 0

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9252160	0.9813350	0.9923820	0.9999630	1.0000000	2.2846E+01	4.3452E-01
α_2	3.40E-05	1.87E-02	7.62E-03	7.48E-02	0.00E+00	4.3452E-01	2.2846E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	12.60
N_1	0.0000
N_2	0.0000

1.1.4.4 CONTAINMENT SPRAY >1H MDP-FR

System : Containment spray recirculation
Component : Motor Driven Pump
Failure Mode : Fail to Run >1 Hour (Standby equipment)
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 5.60

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8934440	0.9733100	0.9889680	0.9999470	1.0000000	1.5846E+01	4.3452E-01
α_2	4.93E-05	2.67E-02	1.10E-02	1.07E-01	0.00E+00	4.3452E-01	1.5846E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	5.60
N_1	0.0000
N_2	0.0000

1.1.5 BWR Residual Heat Removal Pumps

1.1.5.1 BWR RHR MDP FAIL TO START

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 30.00

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9089010	0.9719230	0.9823640	0.9993020	0.9800020	2.6579E+01	7.6782E-01
α_2	6.95E-04	2.81E-02	1.76E-02	9.11E-02	2.00E-02	7.6782E-01	2.6579E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9125190	0.9619090	0.9673600	0.9926310	0.9591840	5.3055E+01	2.1009E+00
α_2	5.40E-03	3.32E-02	2.78E-02	7.98E-02	4.08E-02	1.8337E+00	5.3322E+01
α_3	1.69E-07	4.84E-03	9.75E-04	2.30E-02	0.00E+00	2.6722E-01	5.4889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9072690	0.9518060	0.9555360	0.9835910	0.9375000	7.6136E+01	3.8551E+00
α_2	1.20E-02	4.04E-02	3.66E-02	8.17E-02	6.25E-02	3.2281E+00	7.6763E+01
α_3	5.68E-06	5.05E-03	1.87E-03	2.09E-02	0.00E+00	4.0431E-01	7.9587E+01
α_4	1.20E-08	2.78E-03	3.80E-04	1.39E-02	0.00E+00	2.2267E-01	7.9768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9800020	0.9591840	0.9375000
α_2	2.00E-02	4.08E-02	6.25E-02
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.80E-01	9.59E-01	9.38E-01
Beta	2.00E-02	4.08E-02	6.25E-02
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	15.00	22.50	30.00
N ₁	1.3333	1.0000	0.0000
N ₂	0.3333	1.0000	2.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.1.5.2 BWR RHR MDP FTR LESS THAN 1H

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to Run less than 1 Hour
Op. Mode :	
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
α_2	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
α_2	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
α_3	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
α_2	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
α_3	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
α_4	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	2.00	2.00	2.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

Motor Driven Pumps
 BWR Residual Heat Removal Pumps
 BWR RHR MDP FAIL TO RUN

2010

1.1.5.3 BWR RHR MDP FAIL TO RUN

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to Run (Normally running equipment) Fail to Run >1 Hour (Standby equipment) Fail to Run less than 1 Hour
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 8.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9093850	0.9773460	0.9906920	0.9999550	1.0000000	1.8746E+01	4.3452E-01
α_2	4.16E-05	2.27E-02	9.31E-03	9.06E-02	0.00E+00	4.3452E-01	1.8746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9197350	0.9718850	0.9794540	0.9981430	1.0000000	3.8055E+01	1.1009E+00
α_2	6.78E-04	2.13E-02	1.39E-02	6.73E-02	0.00E+00	8.3366E-01	3.8322E+01
α_3	2.40E-07	6.82E-03	1.38E-03	3.24E-02	0.00E+00	2.6722E-01	3.8889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9214020	0.9671620	0.9725130	0.9945900	1.0000000	5.4636E+01	1.8551E+00
α_2	1.80E-03	2.17E-02	1.64E-02	6.00E-02	0.00E+00	1.2281E+00	5.5263E+01
α_3	8.07E-06	7.16E-03	2.66E-03	2.96E-02	0.00E+00	4.0431E-01	5.6087E+01
α_4	1.70E-08	3.94E-03	5.40E-04	1.97E-02	0.00E+00	2.2267E-01	5.6268E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	8.50	8.50	8.50
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.1.5.4 BWR RHR MDP FAIL TO RUN >1H

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to Run >1 Hour (Standby equipment)
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 5.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8927940	0.9731450	0.9888970	0.9999460	1.0000000	1.5746E+01	4.3452E-01
α_2	4.96E-05	2.69E-02	1.11E-02	1.07E-01	0.00E+00	4.3452E-01	1.5746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9131810	0.9695520	0.9777180	0.9979800	1.0000000	3.5055E+01	1.1009E+00
α_2	7.35E-04	2.31E-02	1.50E-02	7.28E-02	0.00E+00	8.3366E-01	3.5322E+01
α_3	2.60E-07	7.39E-03	1.50E-03	3.51E-02	0.00E+00	2.6722E-01	3.5889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9170660	0.9653200	0.9709530	0.9942790	1.0000000	5.1636E+01	1.8551E+00
α_2	1.91E-03	2.30E-02	1.73E-02	6.33E-02	0.00E+00	1.2281E+00	5.2263E+01
α_3	8.53E-06	7.56E-03	2.81E-03	3.12E-02	0.00E+00	4.0431E-01	5.3087E+01
α_4	1.80E-08	4.16E-03	5.71E-04	2.09E-02	0.00E+00	2.2267E-01	5.3268E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	5.50	5.50	5.50
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.1.6 AFW Motor-Driven Pumps

1.1.6.1 AFW MOTOR DRIVEN PUMP FAIL TO START SPAR: AFW-MDP-FS

System :	Auxiliary feedwater
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 32.70

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8847320	0.9508270	0.9582900	0.9913360	0.9476620	3.7406E+01	1.9345E+00
α_2	8.66E-03	4.92E-02	4.17E-02	1.15E-01	5.23E-02	1.9345E+00	3.7406E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9127180	0.9573150	0.9614560	0.9877510	0.9523700	6.9545E+01	3.1009E+00
α_2	2.84E-03	2.18E-02	1.76E-02	5.52E-02	1.79E-02	1.5837E+00	7.1062E+01
α_3	2.54E-03	2.09E-02	1.67E-02	5.37E-02	2.98E-02	1.5172E+00	7.1129E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9227900	0.9590050	0.9619400	0.9851810	0.9569710	9.8956E+01	4.2301E+00
α_2	3.40E-03	1.92E-02	1.62E-02	4.52E-02	1.36E-02	1.9781E+00	1.0121E+02
α_3	1.44E-03	1.36E-02	1.06E-02	3.60E-02	1.81E-02	1.4043E+00	1.0178E+02
α_4	2.71E-04	8.21E-03	5.33E-03	2.60E-02	1.13E-02	8.4767E-01	1.0234E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9476620	0.9523700	0.9569710
α_2	5.23E-02	1.79E-02	1.36E-02
α_3		2.98E-02	1.81E-02
α_4			1.13E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.48E-01	9.52E-01	9.57E-01
Beta	5.23E-02	4.76E-02	4.30E-02
Gamma		6.25E-01	6.84E-01
Delta			3.85E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	26.16	39.24	52.32
N ₁	1.0000	0.7500	0.5000
N ₂	1.5000	0.7500	0.7500
N ₃		1.2500	1.0000
N ₄			0.6250

AFW MOTOR DRIVEN PUMP FTR LESS THAN 1H SPAR: AFW-MDP-FH

1.1.6.2 AFW MOTOR DRIVEN PUMP FTR LESS THAN 1H SPAR: AFW-MDP-FH

System : Auxiliary feedwater
Component : Motor Driven Pump
Failure Mode : Fail to Run less than 1 Hour
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 6.50

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8683400	0.9604820	0.9761100	0.9992710	0.9622420	1.7043E+01	7.0122E-01
α_2	7.26E-04	3.95E-02	2.39E-02	1.32E-01	3.78E-02	7.0122E-01	1.7043E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8909990	0.9539730	0.9612000	0.9922030	0.9236040	3.8985E+01	1.8809E+00
α_2	5.28E-03	3.92E-02	3.20E-02	9.81E-02	7.54E-02	1.6037E+00	3.9262E+01
α_3	3.46E-07	6.78E-03	1.47E-03	3.18E-02	9.79E-04	2.7722E-01	4.0589E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8901110	0.9447120	0.9495170	0.9828820	0.8838200	5.7722E+01	3.3781E+00
α_2	1.13E-02	4.44E-02	3.95E-02	9.43E-02	1.13E-01	2.7141E+00	5.8386E+01
α_3	1.40E-05	7.21E-03	2.93E-03	2.89E-02	2.75E-03	4.4031E-01	6.0660E+01
α_4	1.67E-08	3.66E-03	5.07E-04	1.83E-02	7.63E-05	2.2367E-01	6.0876E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9622420	0.9236040	0.8838200
α_2	3.78E-02	7.54E-02	1.13E-01
α_3		9.79E-04	2.75E-03
α_4			7.63E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.62E-01	9.24E-01	8.84E-01
Beta	3.78E-02	7.64E-02	1.16E-01
Gamma		1.28E-02	2.43E-02
Delta			2.70E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	4.33	6.50	8.67
N ₁	2.4667	2.9300	2.9160
N ₂	0.2667	0.7700	1.4860
N ₃		0.0100	0.0360
N ₄			0.0010

AFW MOTOR DRIVEN PUMP FAIL TO RUN SPAR: AFW-MDP-FR

1.1.6.3 AFW MOTOR DRIVEN PUMP FAIL TO RUN SPAR: AFW-MDP-FR

System : Auxiliary feedwater
Component : Motor Driven Pump
Failure Mode : Fail to Run >1 Hour (Standby equipment)
Start Date : Fail to Run less than 1 Hour
Data Version : 1997/01/01
Start Date : 2010/12/31

Total Number of Independent Failure Events: 14.20

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8974100	0.9693580	0.9816310	0.9994410	0.9781450	2.2183E+01	7.0122E-01
α_2	5.56E-04	3.06E-02	1.84E-02	1.03E-01	2.19E-02	7.0122E-01	2.2183E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9079610	0.9612710	0.9674320	0.9934740	0.9564490	4.6685E+01	1.8809E+00
α_2	4.42E-03	3.30E-02	2.68E-02	8.28E-02	4.30E-02	1.6037E+00	4.6962E+01
α_3	2.91E-07	5.71E-03	1.23E-03	2.68E-02	5.58E-04	2.7722E-01	4.8289E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9056260	0.9526620	0.9568380	0.9853980	0.9348280	6.7982E+01	3.3781E+00
α_2	9.66E-03	3.80E-02	3.38E-02	8.09E-02	6.36E-02	2.7141E+00	6.8646E+01
α_3	1.19E-05	6.17E-03	2.51E-03	2.47E-02	1.54E-03	4.4031E-01	7.0920E+01
α_4	1.43E-08	3.13E-03	4.33E-04	1.57E-02	4.28E-05	2.2367E-01	7.1136E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9781450	0.9564490	0.9348280
α_2	2.19E-02	4.30E-02	6.36E-02
α_3		5.58E-04	1.54E-03
α_4			4.28E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.78E-01	9.56E-01	9.35E-01
Beta	2.19E-02	4.36E-02	6.52E-02
Gamma		1.28E-02	2.43E-02
Delta			2.70E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	9.47	14.20	18.93
N ₁	2.4667	2.9300	2.9160
N ₂	0.2667	0.7700	1.4860
N ₃		0.0100	0.0360
N ₄			0.0010

1.1.6.4 AFW MOTOR DRIVEN PUMP FAIL TO RUN >1H**System :**

Auxiliary feedwater

Component :

Motor Driven Pump

Failure Mode :

Fail to Run >1 Hour (Standby equipment)

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 7.70

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9054820	0.9763600	0.9902730	0.9999530	1.0000000	1.7946E+01	4.3452E-01
α_2	4.34E-05	2.36E-02	9.73E-03	9.45E-02	0.00E+00	4.3452E-01	1.7946E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9180860	0.9712980	0.9790180	0.9981030	1.0000000	3.7255E+01	1.1009E+00
α_2	6.92E-04	2.17E-02	1.41E-02	6.87E-02	0.00E+00	8.3366E-01	3.7522E+01
α_3	2.45E-07	6.97E-03	1.41E-03	3.30E-02	0.00E+00	2.6722E-01	3.8089E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9202950	0.9666900	0.9721130	0.9945110	1.0000000	5.3836E+01	1.8551E+00
α_2	1.83E-03	2.21E-02	1.66E-02	6.08E-02	0.00E+00	1.2281E+00	5.4463E+01
α_3	8.19E-06	7.26E-03	2.70E-03	3.00E-02	0.00E+00	4.0431E-01	5.5287E+01
α_4	1.73E-08	4.00E-03	5.48E-04	2.00E-02	0.00E+00	2.2267E-01	5.5468E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	7.70	7.70	7.70
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.1.7 AFW Pump Volutes

1.1.7.1 AFW PUMP VOLUTES (MDP,TDP,EDP) FAIL TO RUN SPAR: AFW-PMP-FR

System :	Auxiliary feedwater
Component :	Motor Driven Pump
Failure Mode :	Turbine Driven Pump Fail to Run >1 Hour (Standby equipment)
	Fail to Run less than 1 Hour
Subcomponent :	Pump
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 17.10

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9330100	0.9819910	0.9911350	0.9999000	0.9947370	2.9146E+01	5.3452E-01
α_2	1.02E-04	1.80E-02	8.86E-03	6.70E-02	5.26E-03	5.3452E-01	2.9146E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9380380	0.9766010	0.9817430	0.9975760	0.9901270	5.7635E+01	1.3809E+00
α_2	1.23E-03	1.87E-02	1.36E-02	5.36E-02	9.52E-03	1.1037E+00	5.7912E+01
α_3	2.39E-07	4.70E-03	1.01E-03	2.20E-02	3.53E-04	2.7722E-01	5.8739E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9382970	0.9722280	0.9758250	0.9938590	0.9861050	8.3252E+01	2.3781E+00
α_2	2.93E-03	2.00E-02	1.64E-02	4.94E-02	1.29E-02	1.7141E+00	8.3916E+01
α_3	9.93E-06	5.14E-03	2.09E-03	2.06E-02	9.56E-04	4.4031E-01	8.5190E+01
α_4	1.19E-08	2.61E-03	3.61E-04	1.31E-02	2.66E-05	2.2367E-01	8.5406E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9947370	0.9901270	0.9861050
α_2	5.26E-03	9.52E-03	1.29E-02
α_3		3.53E-04	9.56E-04
α_4			2.66E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.95E-01	9.90E-01	9.86E-01
Beta	5.26E-03	9.87E-03	1.39E-02
Gamma		3.57E-02	7.07E-02
Delta			2.70E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	17.10	25.65	34.20
N ₁	1.8000	2.4300	2.9160
N ₂	0.1000	0.2700	0.4860
N ₃		0.0100	0.0360
N ₄			0.0010

1.1.8 Emergency Service Water Pump

1.1.8.1 NORMALLY RUNNING SERVICE WATER MDP FAIL TO START

System :	Normally operating service water
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 73.70

Total Number of Common-Cause Failure Events: 5

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9506320	0.9836610	0.9887650	0.9992430	0.9891160	5.7392E+01	9.5332E-01
α_2	7.54E-04	1.63E-02	1.12E-02	4.94E-02	1.09E-02	9.5332E-01	5.7392E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9474110	0.9762850	0.9793440	0.9947050	0.9815620	9.9098E+01	2.4072E+00
α_2	3.61E-03	1.99E-02	1.68E-02	4.66E-02	1.67E-02	2.0150E+00	9.9490E+01
α_3	3.53E-06	3.86E-03	1.38E-03	1.61E-02	1.76E-03	3.9222E-01	1.0111E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9443140	0.9706920	0.9728830	0.9895900	0.9754800	1.3754E+02	4.1527E+00
α_2	6.63E-03	2.27E-02	2.05E-02	4.63E-02	2.12E-02	3.2119E+00	1.3848E+02
α_3	6.31E-05	4.63E-03	2.60E-03	1.61E-02	2.68E-03	6.5561E-01	1.4104E+02
α_4	1.34E-07	2.01E-03	4.52E-04	9.35E-03	6.67E-04	2.8517E-01	1.4141E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9505580	0.9713290	0.9727740	0.9871780	0.9771660	2.0996E+02	6.1974E+00
α_2	5.98E-03	1.78E-02	1.64E-02	3.47E-02	1.49E-02	3.8528E+00	2.1230E+02
α_3	1.14E-03	7.91E-03	6.45E-03	1.97E-02	6.29E-03	1.7103E+00	2.1445E+02
α_4	1.31E-05	2.46E-03	1.18E-03	9.22E-03	1.34E-03	5.3069E-01	2.1563E+02
α_5	7.77E-16	4.79E-04	3.51E-06	2.78E-03	2.69E-04	1.0358E-01	2.1605E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9534900	0.9720600	0.9732580	0.9865290	0.9784690	2.5310E+02	7.2748E+00
α_2	4.92E-03	1.47E-02	1.35E-02	2.87E-02	1.15E-02	3.8351E+00	2.5654E+02
α_3	1.49E-03	7.96E-03	6.74E-03	1.86E-02	6.69E-03	2.0731E+00	2.5830E+02
α_4	1.66E-04	3.66E-03	2.49E-03	1.11E-02	2.58E-03	9.5172E-01	2.5942E+02
α_5	2.07E-07	1.21E-03	3.22E-04	5.46E-03	6.74E-04	3.1600E-01	2.6006E+02
α_6	1.60E-16	3.80E-04	2.10E-06	2.21E-03	1.12E-04	9.8837E-02	2.6028E+02

Motor Driven Pumps
 Emergency Service Water Pump
 NORMALLY RUNNING SERVICE WATER MDP FAIL TO START
ALPHA FACTOR and MGL PARAMETERS

2010

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9891160	0.9815620	0.9754800	0.9771660	0.9784690
α_2	1.09E-02	1.67E-02	2.12E-02	1.49E-02	1.15E-02
α_3		1.76E-03	2.68E-03	6.29E-03	6.69E-03
α_4			6.67E-04	1.34E-03	2.58E-03
α_5				2.69E-04	6.74E-04
α_6					1.12E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.89E-01	9.82E-01	9.75E-01	9.77E-01	9.78E-01
Beta	1.09E-02	1.84E-02	2.45E-02	2.28E-02	2.15E-02
Gamma		9.57E-02	1.37E-01	3.46E-01	4.67E-01
Delta			1.99E-01	2.04E-01	3.35E-01
Epsilon				1.67E-01	2.33E-01
Mu					1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	43.35	65.03	86.71	108.38	130.06
N ₁	3.7958	4.5125	4.6950	5.4168	6.0957
N ₂	0.5188	1.1813	1.9838	1.7386	1.5959
N ₃		0.1250	0.2513	0.7329	0.9313
N ₄			0.0625	0.1563	0.3595
N ₅				0.0313	0.0938
N ₆					0.0156

1.1.8.2 NORMALLY RUNNING SERVICE WATER MDP FAIL TO RUN

System : Normally operating service water
Component : Motor Driven Pump
Failure Mode : Fail to Run (Normally running equipment)
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 54.60

Total Number of Common-Cause Failure Events: 6

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8947800	0.9557440	0.9627810	0.9926080	0.9545300	4.0229E+01	1.8628E+00
α_2	7.39E-03	4.43E-02	3.72E-02	1.05E-01	4.55E-02	1.8628E+00	4.0229E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9121510	0.9560180	0.9599380	0.9864810	0.9506370	7.3263E+01	3.3705E+00
α_2	5.24E-03	2.73E-02	2.33E-02	6.32E-02	2.74E-02	2.0955E+00	7.4538E+01
α_3	1.48E-03	1.66E-02	1.27E-02	4.54E-02	2.19E-02	1.2750E+00	7.5358E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9183780	0.9550630	0.9578450	0.9822520	0.9500640	1.0342E+02	4.8661E+00
α_2	7.48E-03	2.73E-02	2.45E-02	5.70E-02	2.87E-02	2.9611E+00	1.0532E+02
α_3	8.28E-04	1.09E-02	8.08E-03	3.07E-02	1.29E-02	1.1813E+00	1.0710E+02
α_4	1.32E-04	6.68E-03	3.99E-03	2.24E-02	8.31E-03	7.2367E-01	1.0756E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9302890	0.9578900	0.9596360	0.9795310	0.9490200	1.6680E+02	7.3327E+00
α_2	8.88E-03	2.46E-02	2.28E-02	4.64E-02	2.91E-02	4.2769E+00	1.6986E+02
α_3	1.59E-03	1.03E-02	8.48E-03	2.52E-02	1.09E-02	1.7910E+00	1.7234E+02
α_4	2.39E-04	5.41E-03	3.67E-03	1.65E-02	7.63E-03	9.4229E-01	1.7319E+02
α_5	3.77E-07	1.85E-03	5.07E-04	8.27E-03	3.36E-03	3.2248E-01	1.7381E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9326490	0.9576840	0.9591360	0.9777710	0.9480590	2.0074E+02	8.8698E+00
α_2	8.84E-03	2.28E-02	2.13E-02	4.19E-02	2.88E-02	4.7844E+00	2.0483E+02
α_3	1.92E-03	1.01E-02	8.55E-03	2.34E-02	1.09E-02	2.1090E+00	2.0750E+02
α_4	3.96E-04	5.51E-03	4.04E-03	1.56E-02	6.36E-03	1.1543E+00	2.0846E+02
α_5	3.05E-05	2.93E-03	1.57E-03	1.04E-02	4.43E-03	6.1390E-01	2.0900E+02
α_6	1.77E-09	9.93E-04	1.15E-04	5.07E-03	1.41E-03	2.0824E-01	2.0940E+02

Motor Driven Pumps
 Emergency Service Water Pump
 NORMALLY RUNNING SERVICE WATER MDP FAIL TO RUN
ALPHA FACTOR and MGL PARAMETERS

2010

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9545300	0.9506370	0.9500640	0.9490200	0.9480590
α_2	4.55E-02	2.74E-02	2.87E-02	2.91E-02	2.88E-02
α_3		2.19E-02	1.29E-02	1.09E-02	1.09E-02
α_4			8.31E-03	7.63E-03	6.36E-03
α_5				3.36E-03	4.43E-03
α_6					1.41E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.55E-01	9.51E-01	9.50E-01	9.49E-01	9.48E-01
Beta	4.55E-02	4.94E-02	4.99E-02	5.10E-02	5.19E-02
Gamma		4.44E-01	4.24E-01	4.30E-01	4.46E-01
Delta			3.92E-01	5.01E-01	5.27E-01
Epsilon				3.06E-01	4.79E-01
Mu					2.42E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	26.19	39.28	52.37	65.47	78.56
N ₁	3.7933	4.4283	4.9157	5.1654	5.2422
N ₂	1.4283	1.2618	1.7330	2.1627	2.5452
N ₃		1.0078	0.7770	0.8136	0.9672
N ₄			0.5010	0.5679	0.5621
N ₅				0.2502	0.3917
N ₆					0.1250

1.1.8.3 STANDBY SERVICE WATER MDP FAIL TO START

System : Standby service water
Component : Motor Driven Pump
Failure Mode : Fail to start
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 69.20

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9301870	0.9769450	0.9841820	0.9989710	0.9832190	3.9752E+01	9.3812E-01
α_2	1.03E-03	2.31E-02	1.58E-02	6.98E-02	1.68E-02	9.3812E-01	3.9752E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9248970	0.9651390	0.9692040	0.9914850	0.9658670	7.2304E+01	2.6116E+00
α_2	6.83E-03	3.13E-02	2.72E-02	6.97E-02	3.41E-02	2.3444E+00	7.2571E+01
α_3	1.24E-07	3.57E-03	7.16E-04	1.69E-02	0.00E+00	2.6722E-01	7.4648E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9296490	0.9635420	0.9664170	0.9876070	0.9653500	1.0245E+02	3.8765E+00
α_2	6.60E-03	2.59E-02	2.29E-02	5.51E-02	2.61E-02	2.7495E+00	1.0358E+02
α_3	3.38E-04	8.51E-03	5.69E-03	2.63E-02	8.57E-03	9.0431E-01	1.0542E+02
α_4	9.00E-09	2.09E-03	2.86E-04	1.05E-02	0.00E+00	2.2267E-01	1.0610E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9428250	0.9676150	0.9694100	0.9862660	0.9718880	1.6654E+02	5.5740E+00
α_2	5.00E-03	1.78E-02	1.60E-02	3.69E-02	1.32E-02	3.0666E+00	1.6905E+02
α_3	1.65E-03	1.05E-02	8.69E-03	2.56E-02	1.15E-02	1.8107E+00	1.7030E+02
α_4	4.06E-05	3.63E-03	1.97E-03	1.28E-02	3.45E-03	6.2439E-01	1.7149E+02
α_5	3.46E-21	4.20E-04	2.37E-07	2.43E-03	0.00E+00	7.2277E-02	1.7204E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9477100	0.9695130	0.9710070	0.9862100	0.9762560	2.0137E+02	6.3321E+00
α_2	3.63E-03	1.38E-02	1.23E-02	2.92E-02	7.20E-03	2.8622E+00	2.0484E+02
α_3	1.65E-03	9.44E-03	7.92E-03	2.24E-02	9.47E-03	1.9612E+00	2.0574E+02
α_4	3.21E-04	5.19E-03	3.71E-03	1.51E-02	5.62E-03	1.0783E+00	2.0662E+02
α_5	6.21E-07	1.67E-03	5.09E-04	7.29E-03	1.45E-03	3.4720E-01	2.0735E+02
α_6	6.78E-19	4.01E-04	7.00E-07	2.34E-03	0.00E+00	8.3237E-02	2.0762E+02

Motor Driven Pumps
 Emergency Service Water Pump
 STANDBY SERVICE WATER MDP FAIL TO START
ALPHA FACTOR and MGL PARAMETERS

2010

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9832190	0.9658670	0.9653500	0.9718880	0.9762560
α_2	1.68E-02	3.41E-02	2.61E-02	1.32E-02	7.20E-03
α_3		0.00E+00	8.57E-03	1.15E-02	9.47E-03
α_4			0.00E+00	3.45E-03	5.62E-03
α_5				0.00E+00	1.45E-03
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.83E-01	9.66E-01	9.65E-01	9.72E-01	9.76E-01
Beta	1.68E-02	3.41E-02	3.46E-02	2.81E-02	2.37E-02
Gamma		0.00E+00	2.47E-01	5.32E-01	6.97E-01
Delta			0.00E+00	2.31E-01	4.27E-01
Epsilon				0.00E+00	2.05E-01
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	27.68	41.52	55.36	69.20	83.04
N ₁	1.8262	1.2286	0.9571	1.1786	1.3929
N ₂	0.5036	1.5107	1.5214	0.9524	0.6230
N ₃		0.0000	0.5000	0.8333	0.8194
N ₄			0.0000	0.2500	0.4861
N ₅				0.0000	0.1250
N ₆					0.0000

1.1.8.4 STANDBY SERVICE WATER MDP FAIL TO RUN

System : Standby service water
Component : Motor Driven Pump
Failure Mode : Fail to Run (Normally running equipment)
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8959650	0.9739500	0.9892430	0.9999480	1.0000000	1.6246E+01	4.3452E-01
α_2	4.81E-05	2.60E-02	1.08E-02	1.04E-01	0.00E+00	4.3452E-01	1.6246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9143470	0.9699670	0.9780280	0.9980130	1.0000000	3.5555E+01	1.1009E+00
α_2	7.25E-04	2.27E-02	1.48E-02	7.18E-02	0.00E+00	8.3366E-01	3.5822E+01
α_3	2.56E-07	7.29E-03	1.48E-03	3.46E-02	0.00E+00	2.6722E-01	3.6389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9178250	0.9656410	0.9712250	0.9943340	1.0000000	5.2136E+01	1.8551E+00
α_2	1.89E-03	2.27E-02	1.72E-02	6.27E-02	0.00E+00	1.2281E+00	5.2763E+01
α_3	8.45E-06	7.49E-03	2.78E-03	3.09E-02	0.00E+00	4.0431E-01	5.3587E+01
α_4	1.78E-08	4.12E-03	5.66E-04	2.07E-02	0.00E+00	2.2267E-01	5.3768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9337450	0.9665250	0.9694270	0.9893730	1.0000000	1.0216E+02	3.5382E+00
α_2	3.85E-03	2.00E-02	1.71E-02	4.62E-02	0.00E+00	2.1142E+00	1.0358E+02
α_3	4.52E-04	9.25E-03	6.39E-03	2.78E-02	0.00E+00	9.7738E-01	1.0472E+02
α_4	2.33E-06	3.54E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0532E+02
α_5	5.65E-21	6.84E-04	3.87E-07	3.96E-03	0.00E+00	7.2277E-02	1.0563E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9366750	0.9663680	0.9687880	0.9877920	1.0000000	1.2294E+02	4.2787E+00
α_2	3.62E-03	1.76E-02	1.51E-02	4.00E-02	0.00E+00	2.2392E+00	1.2498E+02
α_3	6.32E-04	8.98E-03	6.57E-03	2.55E-02	0.00E+00	1.1418E+00	1.2608E+02
α_4	4.16E-05	4.66E-03	2.44E-03	1.68E-02	0.00E+00	5.9222E-01	1.2663E+02
α_5	7.30E-09	1.75E-03	2.37E-04	8.75E-03	0.00E+00	2.2220E-01	1.2700E+02
α_6	1.11E-18	6.54E-04	1.14E-06	3.82E-03	0.00E+00	8.3237E-02	1.2714E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	6.00	6.00	6.00	6.00	6.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.1.8.5 SERVICE WATER MDP FAIL TO START SPAR:ESW-MDP-FS

System : Normally operating service water
Standby service water

Component : Motor Driven Pump

Failure Mode : Fail to start

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 142.90

Total Number of Common-Cause Failure Events: 8

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9571730	0.9835900	0.9870600	0.9981410	0.9869090	8.7318E+01	1.4568E+00
α_2	1.86E-03	1.64E-02	1.29E-02	4.28E-02	1.31E-02	1.4568E+00	8.7318E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9483280	0.9732380	0.9753680	0.9908770	0.9756610	1.4248E+02	3.9179E+00
α_2	7.59E-03	2.41E-02	2.19E-02	4.79E-02	2.33E-02	3.5257E+00	1.4287E+02
α_3	2.44E-06	2.68E-03	9.54E-04	1.12E-02	1.08E-03	3.9222E-01	1.4601E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9469800	0.9692620	0.9708060	0.9862680	0.9717470	1.9469E+02	6.1741E+00
α_2	9.07E-03	2.36E-02	2.20E-02	4.34E-02	2.29E-02	4.7333E+00	1.9613E+02
α_3	4.15E-04	5.75E-03	4.22E-03	1.63E-02	4.91E-03	1.1556E+00	1.9971E+02
α_4	9.45E-08	1.42E-03	3.19E-04	6.60E-03	4.09E-04	2.8517E-01	2.0058E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9539000	0.9715730	0.9726500	0.9855560	0.9752800	2.8139E+02	8.2331E+00
α_2	6.43E-03	1.66E-02	1.55E-02	3.05E-02	1.42E-02	4.8052E+00	2.8482E+02
α_3	2.06E-03	8.78E-03	7.68E-03	1.93E-02	8.25E-03	2.5436E+00	2.8708E+02
α_4	6.84E-05	2.70E-03	1.67E-03	8.81E-03	2.14E-03	7.8069E-01	2.8884E+02
α_5	5.79E-16	3.58E-04	2.62E-06	2.07E-03	1.65E-04	1.0358E-01	2.8952E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9576120	0.9732030	0.9741020	0.9857150	0.9777440	3.3878E+02	9.3283E+00
α_2	4.73E-03	1.28E-02	1.19E-02	2.40E-02	9.78E-03	4.4581E+00	3.4365E+02
α_3	2.20E-03	8.31E-03	7.39E-03	1.76E-02	7.72E-03	2.8926E+00	3.4522E+02
α_4	4.52E-04	4.13E-03	3.23E-03	1.09E-02	3.73E-03	1.4378E+00	3.4667E+02
α_5	2.45E-06	1.27E-03	5.12E-04	5.09E-03	9.64E-04	4.4100E-01	3.4767E+02
α_6	1.20E-16	2.84E-04	1.57E-06	1.65E-03	6.88E-05	9.8837E-02	3.4801E+02

Motor Driven Pumps
 Emergency Service Water Pump
 SERVICE WATER MDP FAIL TO START SPAR:ESW-MDP-FS

2010

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9869090	0.9756610	0.9717470	0.9752800	0.9777440
α_2	1.31E-02	2.33E-02	2.29E-02	1.42E-02	9.78E-03
α_3		1.08E-03	4.91E-03	8.25E-03	7.72E-03
α_4			4.09E-04	2.14E-03	3.73E-03
α_5				1.65E-04	9.64E-04
α_6					6.88E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.87E-01	9.76E-01	9.72E-01	9.75E-01	9.78E-01
Beta	1.31E-02	2.43E-02	2.83E-02	2.47E-02	2.23E-02
Gamma		4.44E-02	1.88E-01	4.27E-01	5.61E-01
Delta			7.68E-02	2.18E-01	3.82E-01
Epsilon				7.15E-02	2.17E-01
Mu					6.66E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	71.45	107.18	142.90	178.63	214.35
N ₁	5.6220	5.7411	5.6521	6.5954	7.4886
N ₂	1.0223	2.6920	3.5052	2.6910	2.2189
N ₃		0.1250	0.7513	1.5662	1.7508
N ₄			0.0625	0.4063	0.8456
N ₅				0.0313	0.2188
N ₆					0.0156

1.1.8.6 SERVICE WATER MDP FAIL TO RUN SPAR:ESW-MDP-FR

System :	Normally operating service water
	Standby service water
Component :	Motor Driven Pump
Failure Mode :	Fail to Run (Normally running equipment)
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 60.60

Total Number of Common-Cause Failure Events: 6

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9013690	0.9585690	0.9651890	0.9930940	0.9583360	4.3099E+01	1.8628E+00
α_2	6.91E-03	4.14E-02	3.48E-02	9.86E-02	4.17E-02	1.8628E+00	4.3099E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9167600	0.9583650	0.9620940	0.9872180	0.9548770	7.7583E+01	3.3705E+00
α_2	4.95E-03	2.59E-02	2.21E-02	5.98E-02	2.51E-02	2.0955E+00	7.8858E+01
α_3	1.40E-03	1.57E-02	1.20E-02	4.30E-02	2.00E-02	1.2750E+00	7.9678E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9224430	0.9573320	0.9599820	0.9831640	0.9544180	1.0918E+02	4.8661E+00
α_2	7.09E-03	2.60E-02	2.32E-02	5.41E-02	2.62E-02	2.9611E+00	1.1108E+02
α_3	7.85E-04	1.04E-02	7.67E-03	2.91E-02	1.18E-02	1.1813E+00	1.1286E+02
α_4	1.25E-04	6.35E-03	3.79E-03	2.13E-02	7.58E-03	7.2367E-01	1.1332E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9330220	0.9595600	0.9612380	0.9803540	0.9535110	1.7399E+02	7.3327E+00
α_2	8.52E-03	2.36E-02	2.19E-02	4.46E-02	2.65E-02	4.2769E+00	1.7705E+02
α_3	1.53E-03	9.88E-03	8.14E-03	2.42E-02	9.97E-03	1.7910E+00	1.7953E+02
α_4	2.30E-04	5.20E-03	3.53E-03	1.59E-02	6.96E-03	9.4229E-01	1.8038E+02
α_5	3.62E-07	1.78E-03	4.87E-04	7.94E-03	3.07E-03	3.2248E-01	1.8100E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9352880	0.9593570	0.9607570	0.9786600	0.9526790	2.0937E+02	8.8698E+00
α_2	8.49E-03	2.19E-02	2.05E-02	4.03E-02	2.62E-02	4.7844E+00	2.1346E+02
α_3	1.84E-03	9.66E-03	8.21E-03	2.24E-02	9.97E-03	2.1090E+00	2.1613E+02
α_4	3.80E-04	5.29E-03	3.88E-03	1.50E-02	5.79E-03	1.1543E+00	2.1709E+02
α_5	2.93E-05	2.81E-03	1.51E-03	1.00E-02	4.04E-03	6.1390E-01	2.1763E+02
α_6	1.70E-09	9.54E-04	1.10E-04	4.87E-03	1.29E-03	2.0824E-01	2.1803E+02

Motor Driven Pumps
 Emergency Service Water Pump
 SERVICE WATER MDP FAIL TO RUN SPAR:ESW-MDP-FR
ALPHA FACTOR and MGL PARAMETERS

2010

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9583360	0.9548770	0.9544180	0.9535110	0.9526790
α_2	4.17E-02	2.51E-02	2.62E-02	2.65E-02	2.62E-02
α_3		2.00E-02	1.18E-02	9.97E-03	9.97E-03
α_4			7.58E-03	6.96E-03	5.79E-03
α_5				3.07E-03	4.04E-03
α_6					1.29E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.58E-01	9.55E-01	9.54E-01	9.54E-01	9.53E-01
Beta	4.17E-02	4.51E-02	4.56E-02	4.65E-02	4.73E-02
Gamma		4.44E-01	4.24E-01	4.30E-01	4.46E-01
Delta			3.92E-01	5.01E-01	5.27E-01
Epsilon				3.06E-01	4.79E-01
Mu					2.42E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	29.06	43.60	58.13	72.66	87.19
N ₁	3.7933	4.4283	4.9157	5.1654	5.2422
N ₂	1.4283	1.2618	1.7330	2.1627	2.5452
N ₃		1.0078	0.7770	0.8136	0.9672
N ₄			0.5010	0.5679	0.5621
N ₅				0.2502	0.3917
N ₆					0.1250

1.1.9 PWR High Pressure Safety Injection Pump

1.1.9.1 HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FAIL TO START

System : Chemical and volume control
High pressure injection

Component : Motor Driven Pump

Failure Mode : Fail to start

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 143.10

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9756040	0.9907320	0.9927470	0.9989830	0.9930600	1.5335E+02	1.4345E+00
α_2	1.02E-03	9.27E-03	7.26E-03	2.44E-02	6.94E-03	1.4345E+00	1.5335E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9801560	0.9914700	0.9927560	0.9983840	0.9953630	2.4421E+02	2.1009E+00
α_2	5.19E-04	5.41E-03	4.15E-03	1.46E-02	2.32E-03	1.3337E+00	2.4498E+02
α_3	7.47E-05	3.11E-03	1.91E-03	1.02E-02	2.32E-03	7.6722E-01	2.4554E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9819300	0.9914820	0.9924410	0.9977720	0.9965180	3.3234E+02	2.8551E+00
α_2	5.06E-04	4.41E-03	3.47E-03	1.15E-02	8.70E-04	1.4781E+00	3.3372E+02
α_3	1.06E-04	2.70E-03	1.80E-03	8.36E-03	1.74E-03	9.0431E-01	3.3429E+02
α_4	4.09E-06	1.41E-03	6.10E-04	5.52E-03	8.70E-04	4.7267E-01	3.3472E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9930600	0.9953630	0.9965180
α_2	6.94E-03	2.32E-03	8.70E-04
α_3		2.32E-03	1.74E-03
α_4			8.70E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.93E-01	9.95E-01	9.97E-01
Beta	6.94E-03	4.64E-03	3.48E-03
Gamma		5.00E-01	7.50E-01
Delta			3.33E-01

HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FAIL TO START

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	143.10	214.65	286.20
N ₁	0.0000	0.0000	0.0000
N ₂	1.0000	0.5000	0.2500
N ₃		0.5000	0.5000
N ₄			0.2500

1.1.9.2 HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FTR LESS THAN 1H

System :	Chemical and volume control High pressure injection
Component :	Motor Driven Pump
Failure Mode :	Fail to Run less than 1 Hour
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8687700	0.9670330	0.9862440	0.9999400	1.0000000	1.2746E+01	4.3452E-01
α_2	6.16E-05	3.30E-02	1.38E-02	1.31E-01	0.00E+00	4.3452E-01	1.2746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9054640	0.9667970	0.9756610	0.9977910	1.0000000	3.2055E+01	1.1009E+00
α_2	8.04E-04	2.51E-02	1.64E-02	7.93E-02	0.00E+00	8.3366E-01	3.2322E+01
α_3	2.84E-07	8.06E-03	1.63E-03	3.82E-02	0.00E+00	2.6722E-01	3.2889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9122220	0.9632590	0.9692100	0.9939300	1.0000000	4.8636E+01	1.8551E+00
α_2	2.02E-03	2.43E-02	1.84E-02	6.70E-02	0.00E+00	1.2281E+00	4.9263E+01
α_3	9.04E-06	8.01E-03	2.98E-03	3.31E-02	0.00E+00	4.0431E-01	5.0087E+01
α_4	1.91E-08	4.41E-03	6.05E-04	2.21E-02	0.00E+00	2.2267E-01	5.0268E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	2.50	2.50	2.50
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.1.9.3 HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FAIL TO RUN**System :** Chemical and volume control

High pressure injection

Component : Motor Driven Pump**Failure Mode :** Fail to Run (Normally running equipment)

Fail to Run >1 Hour (Standby equipment)

Fail to Run less than 1 Hour

Start Date : 1997/01/01**Data Version :** 2010/12/31

Total Number of Independent Failure Events: 135.80

Total Number of Common-Cause Failure Events: 5

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9549480	0.9796430	0.9822570	0.9954100	0.9816360	1.1717E+02	2.4348E+00
α_2	4.59E-03	2.04E-02	1.77E-02	4.51E-02	1.84E-02	2.4348E+00	1.1717E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9556200	0.9760680	0.9777040	0.9909440	0.9783410	1.8769E+02	4.6019E+00
α_2	5.93E-03	1.86E-02	1.70E-02	3.70E-02	1.70E-02	3.5847E+00	1.8871E+02
α_3	2.84E-04	5.29E-03	3.70E-03	1.57E-02	4.64E-03	1.0172E+00	1.9127E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9606790	0.9774990	0.9787020	0.9902030	0.9811190	2.5626E+02	5.8988E+00
α_2	3.60E-03	1.23E-02	1.11E-02	2.52E-02	9.35E-03	3.2301E+00	2.5893E+02
α_3	1.47E-03	7.90E-03	6.69E-03	1.85E-02	7.78E-03	2.0710E+00	2.6009E+02
α_4	2.12E-05	2.28E-03	1.20E-03	8.21E-03	1.75E-03	5.9767E-01	2.6156E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9816360	0.9783410	0.9811190
α_2	1.84E-02	1.70E-02	9.35E-03
α_3		4.64E-03	7.78E-03
α_4			1.75E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.82E-01	9.78E-01	9.81E-01
Beta	1.84E-02	2.17E-02	1.89E-02
Gamma		2.14E-01	5.05E-01
Delta			1.84E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	104.46	156.69	208.92
N ₁	2.4660	1.4480	1.2071
N ₂	2.0003	2.7510	2.0020
N ₃		0.7500	1.6667
N ₄			0.3750

1.1.9.4 HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FAIL TO RUN >1H

System :

Chemical and volume control

Component :

High pressure injection

Failure Mode :

Motor Driven Pump

Start Date :

Fail to Run (Normally running equipment)

Data Version :

Fail to Run >1 Hour (Standby equipment)

1997/01/01

2010/12/31

Total Number of Independent Failure Events: 133.30

Total Number of Common-Cause Failure Events: 5

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9542190	0.9793110	0.9819660	0.9953340	0.9813070	1.1525E+02	2.4348E+00
α_2	4.67E-03	2.07E-02	1.80E-02	4.58E-02	1.87E-02	2.4348E+00	1.1525E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9549510	0.9757040	0.9773630	0.9908050	0.9779480	1.8481E+02	4.6019E+00
α_2	6.02E-03	1.89E-02	1.73E-02	3.75E-02	1.73E-02	3.5847E+00	1.8583E+02
α_3	2.89E-04	5.37E-03	3.76E-03	1.59E-02	4.72E-03	1.0172E+00	1.8839E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9600980	0.9771650	0.9783890	0.9900560	0.9807750	2.5242E+02	5.8988E+00
α_2	3.65E-03	1.25E-02	1.13E-02	2.56E-02	9.52E-03	3.2301E+00	2.5509E+02
α_3	1.50E-03	8.02E-03	6.79E-03	1.87E-02	7.92E-03	2.0710E+00	2.5625E+02
α_4	2.15E-05	2.31E-03	1.22E-03	8.33E-03	1.78E-03	5.9767E-01	2.5772E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9813070	0.9779480	0.9807750
α_2	1.87E-02	1.73E-02	9.52E-03
α_3		4.72E-03	7.92E-03
α_4			1.78E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.81E-01	9.78E-01	9.81E-01
Beta	1.87E-02	2.21E-02	1.92E-02
Gamma		2.14E-01	5.05E-01
Delta			1.84E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	102.54	153.81	205.08
N ₁	2.4660	1.4480	1.2071
N ₂	2.0003	2.7510	2.0020
N ₃		0.7500	1.6667
N ₄			0.3750

1.1.10 PWR Residual Heat Removal Pump

1.1.10.1 PWR RHR MDP FAIL TO START

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 33.50

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9048220	0.9619520	0.9690180	0.9948830	0.9628450	4.0566E+01	1.6045E+00
α_2	5.12E-03	3.80E-02	3.10E-02	9.52E-02	3.72E-02	1.6045E+00	4.0566E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9281530	0.9668900	0.9708430	0.9920950	0.9687360	7.4600E+01	2.5546E+00
α_2	3.47E-03	2.28E-02	1.88E-02	5.58E-02	1.99E-02	1.7592E+00	7.5395E+01
α_3	2.80E-04	1.03E-02	6.50E-03	3.33E-02	1.14E-02	7.9542E-01	7.6359E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9344890	0.9666210	0.9694270	0.9891500	0.9707450	1.0574E+02	3.6514E+00
α_2	3.94E-03	1.98E-02	1.70E-02	4.55E-02	1.53E-02	2.1700E+00	1.0722E+02
α_3	4.79E-04	9.17E-03	6.41E-03	2.73E-02	9.76E-03	1.0036E+00	1.0839E+02
α_4	1.35E-05	4.37E-03	1.92E-03	1.70E-02	4.15E-03	4.7777E-01	1.0891E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9628450	0.9687360	0.9707450
α_2	3.72E-02	1.99E-02	1.53E-02
α_3		1.14E-02	9.76E-03
α_4			4.15E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.63E-01	9.69E-01	9.71E-01
Beta	3.72E-02	3.13E-02	2.93E-02
Gamma		3.63E-01	4.76E-01
Delta			2.99E-01

Motor Driven Pumps
PWR Residual Heat Removal Pump
PWR RHR MDP FAIL TO START

2010

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	28.76	43.13	57.51
N ₁	1.5600	1.9145	2.0960
N ₂	1.1700	0.9255	0.9419
N ₃		0.5282	0.5993
N ₄			0.2551

1.1.10.2 PWR RHR MDP FTR LESS THAN 1H

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to Run less than 1 Hour
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 3.10

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.7559040	0.9029460	0.9208280	0.9885570	0.7560980	1.3346E+01	1.4345E+00
α_2	1.14E-02	9.71E-02	7.92E-02	2.44E-01	2.44E-01	1.4345E+00	1.3346E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8683020	0.9421330	0.9501000	0.9886510	0.8230090	3.4205E+01	2.1009E+00
α_2	3.62E-03	3.67E-02	2.86E-02	9.78E-02	8.85E-02	1.3337E+00	3.4972E+01
α_3	5.18E-04	2.11E-02	1.32E-02	6.88E-02	8.85E-02	7.6722E-01	3.5539E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8921340	0.9482690	0.9536140	0.9861190	0.8611110	5.2336E+01	2.8551E+00
α_2	3.13E-03	2.68E-02	2.13E-02	6.92E-02	3.47E-02	1.4781E+00	5.3713E+01
α_3	6.56E-04	1.64E-02	1.10E-02	5.04E-02	6.94E-02	9.0431E-01	5.4287E+01
α_4	2.51E-05	8.56E-03	3.74E-03	3.34E-02	3.47E-02	4.7267E-01	5.4718E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.7560980	0.8230090	0.8611110
α_2	2.44E-01	8.85E-02	3.47E-02
α_3		8.85E-02	6.94E-02
α_4			3.47E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	7.56E-01	8.23E-01	8.61E-01
Beta	2.44E-01	1.77E-01	1.39E-01
Gamma		5.00E-01	7.50E-01
Delta			3.33E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	3.10	4.65	6.20
N ₁	0.0000	0.0000	0.0000
N ₂	1.0000	0.5000	0.2500
N ₃		0.5000	0.5000
N ₄			0.2500

1.1.10.3 PWR RHR MDP FAIL TO RUN

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to Run >1 Hour (Standby equipment) Fail to Run less than 1 Hour
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 10.10

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8315110	0.9341380	0.9470550	0.9924380	0.9099100	2.0346E+01	1.4345E+00
α_2	7.56E-03	6.59E-02	5.29E-02	1.68E-01	9.01E-02	1.4345E+00	2.0346E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8972310	0.9551140	0.9614590	0.9912720	0.9380800	4.4705E+01	2.1009E+00
α_2	2.79E-03	2.85E-02	2.21E-02	7.62E-02	3.10E-02	1.3337E+00	4.5472E+01
α_3	3.99E-04	1.64E-02	1.02E-02	5.35E-02	3.10E-02	7.6722E-01	4.6039E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9135850	0.9587360	0.9630890	0.9889930	0.9528300	6.6336E+01	2.8551E+00
α_2	2.49E-03	2.14E-02	1.69E-02	5.54E-02	1.18E-02	1.4781E+00	6.7713E+01
α_3	5.22E-04	1.31E-02	8.77E-03	4.03E-02	2.36E-02	9.0431E-01	6.8287E+01
α_4	2.00E-05	6.83E-03	2.98E-03	2.67E-02	1.18E-02	4.7267E-01	6.8718E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9099100	0.9380800	0.9528300
α_2	9.01E-02	3.10E-02	1.18E-02
α_3		3.10E-02	2.36E-02
α_4			1.18E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.10E-01	9.38E-01	9.53E-01
Beta	9.01E-02	6.19E-02	4.72E-02
Gamma		5.00E-01	7.50E-01
Delta			3.33E-01

Motor Driven Pumps
PWR Residual Heat Removal Pump
PWR RHR MDP FAIL TO RUN

2010

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	10.10	15.15	20.20
N ₁	0.0000	0.0000	0.0000
N ₂	1.0000	0.5000	0.2500
N ₃		0.5000	0.5000
N ₄			0.2500

Motor Driven Pumps
 PWR Residual Heat Removal Pump
 PWR RHR MDP FAIL TO RUN >1H

2010

1.1.10.4 PWR RHR MDP FAIL TO RUN >1H

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to Run >1 Hour (Standby equipment)
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 7.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9017830	0.9754240	0.9898730	0.9999510	1.0000000	1.7246E+01	4.3452E-01
α_2	4.52E-05	2.46E-02	1.01E-02	9.82E-02	0.00E+00	4.3452E-01	1.7246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9165860	0.9707650	0.9786210	0.9980670	1.0000000	3.6555E+01	1.1009E+00
α_2	7.05E-04	2.21E-02	1.44E-02	7.00E-02	0.00E+00	8.3366E-01	3.6822E+01
α_3	2.49E-07	7.10E-03	1.44E-03	3.37E-02	0.00E+00	2.6722E-01	3.7389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9192920	0.9662660	0.9717540	0.9944390	1.0000000	5.3136E+01	1.8551E+00
α_2	1.85E-03	2.23E-02	1.68E-02	6.16E-02	0.00E+00	1.2281E+00	5.3763E+01
α_3	8.29E-06	7.35E-03	2.73E-03	3.04E-02	0.00E+00	4.0431E-01	5.4587E+01
α_4	1.75E-08	4.05E-03	5.55E-04	2.03E-02	0.00E+00	2.2267E-01	5.4768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Motor Driven Pumps
PWR Residual Heat Removal Pump
PWR RHR MDP FAIL TO RUN >1H

2010

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	7.00	7.00	7.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.1.11 BWR Standby Liquid Control Pump

1.1.11.1 STANDBY LIQUID CONTROL MDP FAIL TO START SPAR: SLC-MDP-FS

System : Standby liquid control
Component : Motor Driven Pump
Failure Mode : Fail to start
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 14.50

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9303290	0.9824790	0.9926940	0.9999600	0.9993190	2.4926E+01	4.4452E-01
α_2	3.66E-05	1.75E-02	7.31E-03	6.97E-02	6.81E-04	4.4452E-01	2.4926E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	0.9993190
α_2	6.81E-04

MGL Parameter	CCCG=2
1-Beta	9.99E-01
Beta	6.81E-04

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	14.50
N_1	0.1800
N_2	0.0100

1.1.11.2 STANDBY LIQUID CONTROL MDP FAIL TO RUN SPAR: SLC-MDP-FR

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to Run >1 Hour (Standby equipment) Fail to Run less than 1 Hour
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 10.10

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8315110	0.9341380	0.9470550	0.9924380	0.9099100	2.0346E+01	1.4345E+00
α_2	7.56E-03	6.59E-02	5.29E-02	1.68E-01	9.01E-02	1.4345E+00	2.0346E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	0.9099100
α_2	9.01E-02

MGL Parameter	CCCG=2
1-Beta	9.10E-01
Beta	9.01E-02

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	10.10
N_1	0.0000
N_2	1.0000

1.1.11.3 STANDBY LIQUID CONTROL MDP FAIL TO RUN >1H

System : Standby liquid control
Component : Motor Driven Pump
Failure Mode : Fail to Run >1 Hour (Standby equipment)
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 2.20

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8657670	0.9662650	0.9859070	0.9999390	1.0000000	1.2446E+01	4.3452E-01
α_2	6.31E-05	3.37E-02	1.41E-02	1.34E-01	0.00E+00	4.3452E-01	1.2446E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	2.20
N_1	0.0000
N_2	0.0000

Motor Driven Pumps
 Component Cooling Water Pumps
 CCW MOTOR DRIVEN PUMP FAIL TO START SPAR: CCW-MDP-FS

2010

1.1.12 Component Cooling Water Pumps

1.1.12.1 CCW MOTOR DRIVEN PUMP FAIL TO START SPAR: CCW-MDP-FS

System :	Component cooling water
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 79.70

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9806290	0.9951920	0.9980790	0.9999920	1.0000000	8.9946E+01	4.3452E-01
α_2	8.56E-06	4.81E-03	1.92E-03	1.94E-02	0.00E+00	4.3452E-01	8.9946E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9712540	0.9900240	0.9927850	0.9993480	1.0000000	1.0925E+02	1.1009E+00
α_2	2.37E-04	7.55E-03	4.86E-03	2.41E-02	0.00E+00	8.3366E-01	1.0952E+02
α_3	8.42E-08	2.42E-03	4.85E-04	1.15E-02	0.00E+00	2.6722E-01	1.1008E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3
α_1	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00
α_3		0.00E+00

MGL Parameter	CCCG=2	CCCG=3
1-Beta	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00
Gamma		0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3
Adj. Ind. Events	79.70	79.70
N_1	0.0000	0.0000
N_2	0.0000	0.0000
N_3		0.0000

1.1.12.2 CCW MOTOR DRIVEN PUMP FAIL TO RUN SPAR: CCW-MDP-FR

System : Component cooling water
Component : Motor Driven Pump
Failure Mode : Fail to Run (Normally running equipment)
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 54.50

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9114470	0.9652970	0.9721280	0.9957350	0.9672290	4.2219E+01	1.5178E+00
α_2	4.26E-03	3.47E-02	2.79E-02	8.86E-02	3.28E-02	1.5178E+00	4.2219E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9342170	0.9704720	0.9743250	0.9935480	0.9744690	7.7265E+01	2.3509E+00
α_2	8.57E-04	1.36E-02	9.81E-03	3.94E-02	5.11E-03	1.0837E+00	7.8532E+01
α_3	1.40E-03	1.59E-02	1.21E-02	4.36E-02	2.04E-02	1.2672E+00	7.8349E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3
α_1	0.9672290	0.9744690
α_2	3.28E-02	5.11E-03
α_3		2.04E-02

MGL Parameter	CCCG=2	CCCG=3
1-Beta	9.67E-01	9.74E-01
Beta	3.28E-02	2.55E-02
Gamma		8.00E-01

Avg. Impact Vector	CCCG=2	CCCG=3
Adj. Ind. Events	31.14	46.71
N_1	0.8333	1.0000
N_2	1.0833	0.2500
N_3		1.0000

1.1.13 Positive Displacement Pumps

1.1.13.1 POSITIVE DISPLACEMENT PUMP FAIL TO START

Component : Motor Driven Pump
Failure Mode : Fail to start
Component Group : Positive Displacement
Start Date : 1998/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 89.60

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9823140	0.9955760	0.9981920	0.9999920	0.9998890	1.0003E+02	4.4452E-01
α_2	9.04E-06	4.42E-03	1.81E-03	1.77E-02	1.11E-04	4.4452E-01	1.0003E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9804610	0.9931720	0.9950280	0.9995290	0.9997920	1.6420E+02	1.1289E+00
α_2	1.79E-04	5.21E-03	3.39E-03	1.64E-02	2.00E-04	8.6066E-01	1.6447E+02
α_3	5.85E-08	1.62E-03	3.26E-04	7.69E-03	7.43E-06	2.6822E-01	1.6506E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9798920	0.9916170	0.9930050	0.9985880	0.9997090	2.2563E+02	1.9074E+00
α_2	4.95E-04	5.61E-03	4.25E-03	1.54E-02	2.71E-04	1.2767E+00	2.2626E+02
α_3	2.12E-06	1.79E-03	6.67E-04	7.39E-03	2.01E-05	4.0791E-01	2.2713E+02
α_4	4.22E-09	9.79E-04	1.33E-04	4.90E-03	5.57E-07	2.2277E-01	2.2731E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9998890	0.9997920	0.9997090
α_2	1.11E-04	2.00E-04	2.71E-04
α_3		7.43E-06	2.01E-05
α_4			5.57E-07

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	1.11E-04	2.08E-04	2.91E-04
Gamma		3.57E-02	7.07E-02
Delta			2.70E-02

POSITIVE DISPLACEMENT PUMP FAIL TO START

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	89.60	134.40	179.20
N ₁	0.1800	0.2430	0.2916
N ₂	0.0100	0.0270	0.0486
N ₃		0.0010	0.0036
N ₄			0.0001

1.1.13.2 POSITIVE DISPLACEMENT PUMP FAIL TO RUN**Component :**

Motor Driven Pump

Failure Mode :

Fail to Run (Normally running equipment)

Component Group :

Positive Displacement

Start Date :

1998/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 86.20

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9577590	0.9845660	0.9882850	0.9986410	0.9883390	8.0873E+01	1.2678E+00
α_2	1.36E-03	1.54E-02	1.17E-02	4.22E-02	1.17E-02	1.2678E+00	8.0873E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9532970	0.9773390	0.9796280	0.9935700	0.9811660	1.3374E+02	3.1009E+00
α_2	4.52E-03	1.89E-02	1.66E-02	4.11E-02	1.65E-02	2.5837E+00	1.3426E+02
α_3	1.78E-05	3.78E-03	1.78E-03	1.43E-02	2.35E-03	5.1722E-01	1.3632E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9575280	0.9775940	0.9792580	0.9919720	0.9831320	1.8456E+02	4.2301E+00
α_2	3.00E-03	1.31E-02	1.14E-02	2.90E-02	8.88E-03	2.4781E+00	1.8631E+02
α_3	7.84E-04	7.44E-03	5.79E-03	1.97E-02	7.10E-03	1.4043E+00	1.8739E+02
α_4	6.92E-07	1.84E-03	5.62E-04	8.02E-03	8.88E-04	3.4767E-01	1.8844E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9883390	0.9811660	0.9831320
α_2	1.17E-02	1.65E-02	8.88E-03
α_3		2.35E-03	7.10E-03
α_4			8.88E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.88E-01	9.81E-01	9.83E-01
Beta	1.17E-02	1.88E-02	1.69E-02
Gamma		1.25E-01	4.74E-01
Delta			1.11E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	68.96	103.44	137.92
N ₁	1.6667	0.7500	0.5000
N ₂	0.8333	1.7500	1.2500
N ₃		0.2500	1.0000
N ₄			0.1250

1.2 Turbine Driven Pumps

1.2.1 Pooled Turbine Driven Pumps

1.2.1.1 TURBINE DRIVEN PUMP FAIL TO START SPAR: TDP-FS

Component : Turbine Driven Pump
Failure Mode : Fail to start
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 167.90

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9789610	0.9920120	0.9937470	0.9991230	0.9940790	1.7815E+02	1.4345E+00
α_2	8.74E-04	7.99E-03	6.25E-03	2.10E-02	5.92E-03	1.4345E+00	1.7815E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9827500	0.9925890	0.9937130	0.9985920	0.9960450	2.8140E+02	2.1009E+00
α_2	4.51E-04	4.70E-03	3.60E-03	1.27E-02	1.98E-03	1.3337E+00	2.8217E+02
α_3	6.49E-05	2.71E-03	1.66E-03	8.90E-03	1.98E-03	7.6722E-01	2.8273E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9842490	0.9925800	0.9934180	0.9980610	0.9970310	3.8194E+02	2.8551E+00
α_2	4.41E-04	3.84E-03	3.02E-03	1.00E-02	7.42E-04	1.4781E+00	3.8332E+02
α_3	9.27E-05	2.35E-03	1.56E-03	7.29E-03	1.48E-03	9.0431E-01	3.8389E+02
α_4	3.56E-06	1.23E-03	5.32E-04	4.81E-03	7.42E-04	4.7267E-01	3.8432E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9940790	0.9960450	0.9970310
α_2	5.92E-03	1.98E-03	7.42E-04
α_3		1.98E-03	1.48E-03
α_4			7.42E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.94E-01	9.96E-01	9.97E-01
Beta	5.92E-03	3.95E-03	2.97E-03
Gamma		5.00E-01	7.50E-01
Delta			3.33E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	167.90	251.85	335.80
N ₁	0.0000	0.0000	0.0000
N ₂	1.0000	0.5000	0.2500
N ₃		0.5000	0.5000
N ₄			0.2500

1.2.1.2 TURBINE DRIVEN PUMP FTR LESS THAN 1H

Component : Turbine Driven Pump
Failure Mode : Fail to Run less than 1 Hour
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 62.60

Total Number of Common-Cause Failure Events: 0

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9761140	0.9940700	0.9976270	0.9999880	1.0000000	7.2846E+01	4.3452E-01
α_2	1.06E-05	5.93E-03	2.38E-03	2.39E-02	0.00E+00	4.3452E-01	7.2846E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9660150	0.9881950	0.9914590	0.9992280	1.0000000	9.2155E+01	1.1009E+00
α_2	2.81E-04	8.94E-03	5.76E-03	2.84E-02	0.00E+00	8.3366E-01	9.2422E+01
α_3	9.97E-08	2.87E-03	5.74E-04	1.36E-02	0.00E+00	2.6722E-01	9.2989E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9595530	0.9832260	0.9860440	0.9972690	1.0000000	1.0874E+02	1.8551E+00
α_2	9.12E-04	1.11E-02	8.33E-03	3.08E-02	0.00E+00	1.2281E+00	1.0937E+02
α_3	4.10E-06	3.66E-03	1.35E-03	1.51E-02	0.00E+00	4.0431E-01	1.1019E+02
α_4	8.65E-09	2.01E-03	2.75E-04	1.01E-02	0.00E+00	2.2267E-01	1.1037E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	62.60	62.60	62.60
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.2.1.3 TDP FTR LESS THAN AND > 1 HOUR ALL SYSTEMS SPAR: TDP-FR**Component :**

Turbine Driven Pump

Failure Mode :

Fail to Run (Normally running equipment)

Fail to Run >1 Hour (Standby equipment)

Fail to Run less than 1 Hour

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 130.60

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9876020	0.9969250	0.9987700	0.9999890	1.0000000	1.4085E+02	4.3452E-01
α_2	5.46E-06	3.08E-03	1.23E-03	1.24E-02	0.00E+00	4.3452E-01	1.4085E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9802920	0.9931730	0.9950720	0.9995550	1.0000000	1.6015E+02	1.1009E+00
α_2	1.62E-04	5.17E-03	3.32E-03	1.65E-02	0.00E+00	8.3366E-01	1.6042E+02
α_3	5.75E-08	1.66E-03	3.31E-04	7.86E-03	0.00E+00	2.6722E-01	1.6098E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9748790	0.9896130	0.9913740	0.9983130	1.0000000	1.7674E+02	1.8551E+00
α_2	5.63E-04	6.88E-03	5.14E-03	1.91E-02	0.00E+00	1.2281E+00	1.7737E+02
α_3	2.53E-06	2.26E-03	8.34E-04	9.36E-03	0.00E+00	4.0431E-01	1.7819E+02
α_4	5.35E-09	1.25E-03	1.70E-04	6.24E-03	0.00E+00	2.2267E-01	1.7837E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9693910	0.9846360	0.9860200	0.9951690	1.0000000	2.2676E+02	3.5382E+00
α_2	1.76E-03	9.18E-03	7.80E-03	2.13E-02	0.00E+00	2.1142E+00	2.2818E+02
α_3	2.06E-04	4.24E-03	2.92E-03	1.28E-02	0.00E+00	9.7738E-01	2.2932E+02
α_4	1.07E-06	1.63E-03	5.46E-04	6.91E-03	0.00E+00	3.7439E-01	2.2992E+02
α_5	2.58E-21	3.14E-04	1.77E-07	1.81E-03	0.00E+00	7.2277E-02	2.3023E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9678230	0.9830090	0.9842690	0.9938810	1.0000000	2.4754E+02	4.2787E+00
α_2	1.82E-03	8.89E-03	7.63E-03	2.03E-02	0.00E+00	2.2392E+00	2.4958E+02
α_3	3.18E-04	4.53E-03	3.31E-03	1.29E-02	0.00E+00	1.1418E+00	2.5068E+02
α_4	2.10E-05	2.35E-03	1.23E-03	8.49E-03	0.00E+00	5.9222E-01	2.5123E+02
α_5	3.68E-09	8.82E-04	1.19E-04	4.42E-03	0.00E+00	2.2220E-01	2.5160E+02
α_6	5.59E-19	3.31E-04	5.77E-07	1.93E-03	0.00E+00	8.3237E-02	2.5174E+02

Turbine Driven Pumps

2010

Pooled Turbine Driven Pumps

TDP FTR LESS THAN AND > 1 HOUR ALL SYSTEMS SPAR: TDP-FR

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	130.60	130.60	130.60	130.60	130.60
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

Turbine Driven Pumps
 Pooled Turbine Driven Pumps
 TURBINE DRIVEN PUMP FAIL TO RUN >1H

2010

1.2.1.4 TURBINE DRIVEN PUMP FAIL TO RUN >1H

Component : Turbine Driven Pump
Failure Mode : Fail to Run (Normally running equipment)
Start Date : Fail to Run >1 Hour (Standby equipment)
Data Version : 1997/01/01
 2010/12/31

Total Number of Independent Failure Events: 68.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9777550	0.9944770	0.9977910	0.9999910	1.0000000	7.8246E+01	4.3452E-01
α_2	9.84E-06	5.52E-03	2.21E-03	2.22E-02	0.00E+00	4.3452E-01	7.8246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9678650	0.9888410	0.9919290	0.9992710	1.0000000	9.7555E+01	1.1009E+00
α_2	2.65E-04	8.45E-03	5.44E-03	2.69E-02	0.00E+00	8.3366E-01	9.7822E+01
α_3	9.42E-08	2.71E-03	5.42E-04	1.28E-02	0.00E+00	2.6722E-01	9.8389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9614270	0.9840070	0.9866970	0.9973970	1.0000000	1.1414E+02	1.8551E+00
α_2	8.70E-04	1.06E-02	7.94E-03	2.94E-02	0.00E+00	1.2281E+00	1.1477E+02
α_3	3.91E-06	3.49E-03	1.29E-03	1.44E-02	0.00E+00	4.0431E-01	1.1559E+02
α_4	8.25E-09	1.92E-03	2.62E-04	9.61E-03	0.00E+00	2.2267E-01	1.1577E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Turbine Driven Pumps

2010

Pooled Turbine Driven Pumps

TURBINE DRIVEN PUMP FAIL TO RUN >1H

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	68.00	68.00	68.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

Turbine Driven Pumps

2010

AFW Turbine-Driven Pumps

AFW TURBINE DRIVEN PUMP FAIL TO START SPAR: AFW-TDP-FS

1.2.2 AFW Turbine-Driven Pumps

1.2.2.1 AFW TURBINE DRIVEN PUMP FAIL TO START SPAR: AFW-TDP-FS

System :	Auxiliary feedwater
Component :	Turbine Driven Pump
Failure Mode :	Fail to start
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 66.90

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9774400	0.9943990	0.9977600	0.9999910	1.0000000	7.7146E+01	4.3452E-01
α_2	9.98E-06	5.60E-03	2.24E-03	2.26E-02	0.00E+00	4.3452E-01	7.7146E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9675050	0.9887150	0.9918380	0.9992620	1.0000000	9.6455E+01	1.1009E+00
α_2	2.68E-04	8.55E-03	5.50E-03	2.72E-02	0.00E+00	8.3366E-01	9.6722E+01
α_3	9.53E-08	2.74E-03	5.49E-04	1.30E-02	0.00E+00	2.6722E-01	9.7289E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9610610	0.9838540	0.9865690	0.9973720	1.0000000	1.1304E+02	1.8551E+00
α_2	8.78E-04	1.07E-02	8.01E-03	2.96E-02	0.00E+00	1.2281E+00	1.1367E+02
α_3	3.94E-06	3.52E-03	1.30E-03	1.45E-02	0.00E+00	4.0431E-01	1.1449E+02
α_4	8.33E-09	1.94E-03	2.64E-04	9.70E-03	0.00E+00	2.2267E-01	1.1467E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	66.90	66.90	66.90
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.2.2.2 AFW TURBINE DRIVEN PUMP FTR LESS THAN 1H SPAR: AFW-TDP-FH

System : Auxiliary feedwater
Component : Turbine Driven Pump
Failure Mode : Fail to Run less than 1 Hour
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 40.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9655000	0.9914260	0.9965530	0.9999830	1.0000000	5.0246E+01	4.3452E-01
α_2	1.54E-05	8.57E-03	3.45E-03	3.45E-02	0.00E+00	4.3452E-01	5.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9552250	0.9844190	0.9886960	0.9989790	1.0000000	6.9555E+01	1.1009E+00
α_2	3.72E-04	1.18E-02	7.62E-03	3.75E-02	0.00E+00	8.3366E-01	6.9822E+01
α_3	1.32E-07	3.78E-03	7.59E-04	1.79E-02	0.00E+00	2.6722E-01	7.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9492630	0.9789170	0.9824320	0.9965570	1.0000000	8.6136E+01	1.8551E+00
α_2	1.15E-03	1.40E-02	1.05E-02	3.86E-02	0.00E+00	1.2281E+00	8.6763E+01
α_3	5.16E-06	4.59E-03	1.70E-03	1.90E-02	0.00E+00	4.0431E-01	8.7587E+01
α_4	1.09E-08	2.53E-03	3.46E-04	1.27E-02	0.00E+00	2.2267E-01	8.7768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	40.00	40.00	40.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.2.2.3 AFW TURBINE DRIVEN PUMP FAIL TO RUN SPAR: AFW-TDP-FR

System : Auxiliary feedwater
Component : Turbine Driven Pump
Failure Mode : Fail to Run >1 Hour (Standby equipment)
Start Date : Fail to Run less than 1 Hour
Data Version : 1997/01/01
2010/12/31

Total Number of Independent Failure Events: 48.00

Total Number of Common-Cause Failure Events: 0

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9701940	0.9925950	0.9970290	0.9999850	1.0000000	5.8246E+01	4.3452E-01
α_2	1.32E-05	7.40E-03	2.97E-03	2.98E-02	0.00E+00	4.3452E-01	5.8246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9597510	0.9860040	0.9898550	0.9990840	1.0000000	7.7555E+01	1.1009E+00
α_2	3.33E-04	1.06E-02	6.84E-03	3.37E-02	0.00E+00	8.3366E-01	7.7822E+01
α_3	1.18E-07	3.40E-03	6.81E-04	1.61E-02	0.00E+00	2.6722E-01	7.8389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9534540	0.9806740	0.9839060	0.9968480	1.0000000	9.4136E+01	1.8551E+00
α_2	1.05E-03	1.28E-02	9.60E-03	3.54E-02	0.00E+00	1.2281E+00	9.4763E+01
α_3	4.73E-06	4.21E-03	1.56E-03	1.74E-02	0.00E+00	4.0431E-01	9.5587E+01
α_4	9.98E-09	2.32E-03	3.17E-04	1.16E-02	0.00E+00	2.2267E-01	9.5768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	48.00	48.00	48.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

Turbine Driven Pumps

2010

AFW Turbine-Driven Pumps

AFW TURBINE DRIVEN PUMP FAIL TO RUN >1H

1.2.2.4 AFW TURBINE DRIVEN PUMP FAIL TO RUN >1H

System :

Auxiliary feedwater

Component :

Turbine Driven Pump

Failure Mode :

Fail to Run >1 Hour (Standby equipment)

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 8.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9069840	0.9767390	0.9904340	0.9999540	1.0000000	1.8246E+01	4.3452E-01
α_2	4.27E-05	2.33E-02	9.56E-03	9.30E-02	0.00E+00	4.3452E-01	1.8246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9187120	0.9715210	0.9791840	0.9981180	1.0000000	3.7555E+01	1.1009E+00
α_2	6.87E-04	2.16E-02	1.40E-02	6.82E-02	0.00E+00	8.3366E-01	3.7822E+01
α_3	2.43E-07	6.91E-03	1.40E-03	3.28E-02	0.00E+00	2.6722E-01	3.8389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9207150	0.9668680	0.9722640	0.9945410	1.0000000	5.4136E+01	1.8551E+00
α_2	1.82E-03	2.19E-02	1.65E-02	6.05E-02	0.00E+00	1.2281E+00	5.4763E+01
α_3	8.14E-06	7.22E-03	2.68E-03	2.98E-02	0.00E+00	4.0431E-01	5.5587E+01
α_4	1.72E-08	3.98E-03	5.45E-04	1.99E-02	0.00E+00	2.2267E-01	5.5768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	8.00	8.00	8.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.2.3 BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Pumps

1.2.3.1 COMBINED HPCI AND RCIC TDP FAIL TO START

System : High pressure coolant injection

Reactor core isolation

Component : Turbine Driven Pump

Failure Mode : Fail to start

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 88.00

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9622100	0.9856090	0.9887030	0.9984190	0.9887640	9.8246E+01	1.4345E+00
α_2	1.58E-03	1.44E-02	1.13E-02	3.78E-02	1.12E-02	1.4345E+00	9.8246E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	0.9887640
α_2	1.12E-02

MGL Parameter	CCCG=2
1-Beta	9.89E-01
Beta	1.12E-02

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	88.00
N_1	0.0000
N_2	1.0000

1.2.3.2 COMBINED HPCI AND RCIC TDP FTR LESS THAN 1H

System : High pressure coolant injection

Reactor core isolation

Component : Turbine Driven Pump

Failure Mode : Fail to Run less than 1 Hour

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 22.60

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9475590	0.9869440	0.9947100	0.9999740	1.0000000	3.2846E+01	4.3452E-01
α_2	2.36E-05	1.31E-02	5.29E-03	5.24E-02	0.00E+00	4.3452E-01	3.2846E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	22.60
N_1	0.0000
N_2	0.0000

1.2.3.3 COMBINED HPCI AND RCIC TDP FAIL TO RUN

System : High pressure coolant injection

Reactor core isolation

Component : Turbine Driven Pump

Failure Mode : Fail to Run >1 Hour (Standby equipment)

Fail to Run less than 1 Hour

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 25.60

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9518730	0.9880230	0.9951600	0.9999760	1.0000000	3.5846E+01	4.3452E-01
α_2	2.16E-05	1.20E-02	4.84E-03	4.81E-02	0.00E+00	4.3452E-01	3.5846E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	25.60
N ₁	0.0000
N ₂	0.0000

1.2.3.4 COMBINED HPCI AND RCIC TDP FAIL TO RUN >1H

System : High pressure coolant injection

Reactor core isolation

Component : Turbine Driven Pump

Failure Mode : Fail to Run >1 Hour (Standby equipment)

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 3.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8734960	0.9682380	0.9867710	0.9999360	1.0000000	1.3246E+01	4.3452E-01
α_2	5.92E-05	3.18E-02	1.32E-02	1.27E-01	0.00E+00	4.3452E-01	1.3246E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	3.00
N_1	0.0000
N_2	0.0000

1.3 Motor Operated Valves

1.3.1 Pooled Motor Operated Valve Distributions

1.3.1.1 MOV FAIL TO OPEN/CLOSE ALL SYSTEMS SPAR: MOV-FO

Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand
	Fail to Open/Close Mode Unspecified (demand based)
	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 486.70

Total Number of Common-Cause Failure Events: 8

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9733330	0.9886710	0.9904450	0.9979480	0.9905450	1.7598E+02	2.0165E+00
α_2	2.05E-03	1.13E-02	9.56E-03	2.67E-02	9.46E-03	2.0165E+00	1.7598E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9738350	0.9866890	0.9878310	0.9956450	0.9894640	2.7659E+02	3.7313E+00
α_2	2.76E-03	1.04E-02	9.23E-03	2.19E-02	8.30E-03	2.9063E+00	2.7742E+02
α_3	8.89E-05	2.94E-03	1.88E-03	9.43E-03	2.23E-03	8.2502E-01	2.7950E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9728200	0.9844870	0.9853280	0.9932690	0.9878370	3.7364E+02	5.8877E+00
α_2	4.06E-03	1.13E-02	1.04E-02	2.14E-02	9.21E-03	4.2825E+00	3.7525E+02
α_3	2.05E-04	2.98E-03	2.17E-03	8.54E-03	2.19E-03	1.1315E+00	3.7840E+02
α_4	3.66E-06	1.25E-03	5.41E-04	4.88E-03	7.57E-04	4.7367E-01	3.7905E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9735460	0.9836850	0.9843070	0.9916900	0.9883110	5.0454E+02	8.3683E+00
α_2	3.96E-03	9.91E-03	9.28E-03	1.80E-02	7.18E-03	5.0829E+00	5.0783E+02
α_3	9.71E-04	4.55E-03	3.92E-03	1.03E-02	3.28E-03	2.3331E+00	5.1058E+02
α_4	3.34E-05	1.47E-03	8.95E-04	4.87E-03	9.21E-04	7.5479E-01	5.1215E+02
α_5	3.28E-10	3.85E-04	3.86E-05	1.99E-03	3.03E-04	1.9748E-01	5.1271E+02

Motor Operated Valves

2010

Pooled Motor Operated Valve Distributions

MOV FAIL TO OPEN/CLOSE ALL SYSTEMS SPAR: MOV-FO

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9750180	0.9840990	0.9846180	0.9914020	0.9888510	6.0618E+02	9.7944E+00
α_2	3.16E-03	8.05E-03	7.52E-03	1.47E-02	5.49E-03	4.9562E+00	6.1102E+02
α_3	1.43E-03	5.05E-03	4.53E-03	1.05E-02	3.98E-03	3.1118E+00	6.1286E+02
α_4	1.18E-04	1.80E-03	1.30E-03	5.19E-03	1.04E-03	1.1074E+00	6.1487E+02
α_5	2.24E-06	7.68E-04	3.33E-04	3.01E-03	5.08E-04	4.7330E-01	6.1550E+02
α_6	1.21E-12	2.37E-04	8.82E-06	1.31E-03	1.26E-04	1.4574E-01	6.1583E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9758200	0.9839290	0.9843450	0.9906090	0.9898010	7.5441E+02	1.2322E+01
α_2	3.08E-03	7.31E-03	6.89E-03	1.30E-02	4.37E-03	5.6080E+00	7.6112E+02
α_3	1.37E-03	4.49E-03	4.06E-03	9.04E-03	3.14E-03	3.4398E+00	7.6329E+02
α_4	4.61E-04	2.60E-03	2.18E-03	6.17E-03	1.74E-03	1.9939E+00	7.6474E+02
α_5	4.14E-05	1.14E-03	7.50E-04	3.59E-03	6.17E-04	8.7707E-01	7.6585E+02
α_6	1.50E-07	4.47E-04	1.33E-04	1.96E-03	2.72E-04	3.4278E-01	7.6639E+02
α_7	2.16E-25	7.87E-05	7.94E-09	4.42E-04	5.43E-05	6.0371E-02	7.6667E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9771010	0.9845000	0.9848610	0.9906520	0.9905140	8.7015E+02	1.3700E+01
α_2	2.78E-03	6.51E-03	6.14E-03	1.15E-02	3.66E-03	5.7527E+00	8.7810E+02
α_3	1.20E-03	3.90E-03	3.53E-03	7.86E-03	2.60E-03	3.4466E+00	8.8040E+02
α_4	5.58E-04	2.63E-03	2.26E-03	5.95E-03	1.79E-03	2.3238E+00	8.8153E+02
α_5	1.33E-04	1.47E-03	1.11E-03	4.01E-03	8.94E-04	1.2962E+00	8.8255E+02
α_6	7.27E-06	6.96E-04	3.73E-04	2.48E-03	3.77E-04	6.1486E-01	8.8323E+02
α_7	7.44E-10	2.45E-04	3.12E-05	1.24E-03	1.43E-04	2.1677E-01	8.8363E+02
α_8	1.31E-30	5.51E-05	4.38E-10	2.91E-04	2.37E-05	4.8724E-02	8.8380E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9905450	0.9894640	0.9878370	0.9883110	0.9888510	0.9898010	0.9905140
α_2	9.46E-03	8.30E-03	9.21E-03	7.18E-03	5.49E-03	4.37E-03	3.66E-03
α_3		2.23E-03	2.19E-03	3.28E-03	3.98E-03	3.14E-03	2.60E-03
α_4			7.57E-04	9.21E-04	1.04E-03	1.74E-03	1.79E-03
α_5				3.03E-04	5.08E-04	6.17E-04	8.94E-04
α_6					1.26E-04	2.72E-04	3.77E-04
α_7						5.43E-05	1.43E-04
α_8							2.37E-05

Motor Operated Valves

2010

Pooled Motor Operated Valve Distributions

MOV FAIL TO OPEN/CLOSE ALL SYSTEMS SPAR: MOV-FO

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.91E-01	9.89E-01	9.88E-01	9.88E-01	9.89E-01	9.90E-01	9.91E-01
Beta	9.46E-03	1.05E-02	1.22E-02	1.17E-02	1.11E-02	1.02E-02	9.49E-03
Gamma		2.12E-01	2.43E-01	3.85E-01	5.07E-01	5.71E-01	6.14E-01
Delta			2.57E-01	2.72E-01	2.96E-01	4.61E-01	5.54E-01
Epsilon				2.48E-01	3.78E-01	3.51E-01	4.45E-01
Mu					1.99E-01	3.46E-01	3.78E-01
Upsilon						1.67E-01	3.06E-01
Sigma							1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	162.23	243.35	324.47	405.58	486.70	567.82	648.93
N ₁	3.5027	3.6814	3.0389	2.8019	2.5394	2.5414	2.4909
N ₂	1.5820	2.0726	3.0544	2.9687	2.7170	2.5202	2.4080
N ₃		0.5578	0.7272	1.3557	1.9700	1.8086	1.7082
N ₄			0.2510	0.3804	0.5152	1.0050	1.1773
N ₅				0.1252	0.2511	0.3553	0.5879
N ₆					0.0625	0.1565	0.2479
N ₇						0.0313	0.0938
N ₈							0.0156

1.3.1.2 MOV FAIL TO OPEN ALL SYSTEMS SPAR: MOV-CC

Component : Motor Operated Valve
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 272.80

Total Number of Common-Cause Failure Events: 4

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9518680	0.9807780	0.9843850	0.9973570	0.9838390	8.3925E+01	1.6448E+00
α_2	2.65E-03	1.92E-02	1.56E-02	4.81E-02	1.62E-02	1.6448E+00	8.3925E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9599550	0.9814940	0.9837050	0.9954900	0.9862770	1.3959E+02	2.6319E+00
α_2	2.01E-03	1.28E-02	1.06E-02	3.10E-02	8.79E-03	1.8146E+00	1.4041E+02
α_3	1.69E-04	5.75E-03	3.66E-03	1.84E-02	4.93E-03	8.1732E-01	1.4140E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9627900	0.9810490	0.9826580	0.9938060	0.9874330	1.9240E+02	3.7167E+00
α_2	2.12E-03	1.09E-02	9.30E-03	2.52E-02	6.15E-03	2.1395E+00	1.9398E+02
α_3	3.67E-04	5.63E-03	4.07E-03	1.62E-02	4.73E-03	1.1045E+00	1.9501E+02
α_4	7.01E-06	2.41E-03	1.04E-03	9.44E-03	1.69E-03	4.7267E-01	1.9564E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9649400	0.9801630	0.9812760	0.9915710	0.9886140	2.7870E+02	5.6406E+00
α_2	2.61E-03	9.99E-03	8.87E-03	2.12E-02	3.94E-03	2.8410E+00	2.8150E+02
α_3	1.05E-03	6.52E-03	5.40E-03	1.58E-02	4.74E-03	1.8529E+00	2.8249E+02
α_4	5.84E-05	2.64E-03	1.60E-03	8.74E-03	2.03E-03	7.4939E-01	2.8359E+02
α_5	5.83E-10	6.94E-04	6.95E-05	3.59E-03	6.77E-04	1.9728E-01	2.8414E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9677770	0.9812130	0.9821410	0.9914700	0.9902640	3.3592E+02	6.4317E+00
α_2	1.62E-03	7.17E-03	6.23E-03	1.59E-02	9.70E-04	2.4537E+00	3.3990E+02
α_3	1.54E-03	6.99E-03	6.06E-03	1.56E-02	5.66E-03	2.3928E+00	3.3996E+02
α_4	1.34E-04	2.83E-03	1.94E-03	8.55E-03	1.70E-03	9.6722E-01	3.4138E+02
α_5	3.98E-06	1.38E-03	5.97E-04	5.40E-03	1.13E-03	4.7220E-01	3.4188E+02
α_6	2.17E-12	4.26E-04	1.59E-05	2.36E-03	2.83E-04	1.4574E-01	3.4221E+02

Motor Operated Valves

2010

Pooled Motor Operated Valve Distributions

MOV FAIL TO OPEN ALL SYSTEMS SPAR: MOV-CC

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9689200	0.9806800	0.9813880	0.9900170	0.9914110	4.3946E+02	8.6578E+00
α_2	2.22E-03	7.43E-03	6.71E-03	1.51E-02	9.39E-04	3.3297E+00	4.4479E+02
α_3	1.17E-03	5.33E-03	4.62E-03	1.19E-02	2.94E-03	2.3895E+00	4.4573E+02
α_4	5.43E-04	3.80E-03	3.09E-03	9.47E-03	2.77E-03	1.7014E+00	4.4642E+02
α_5	5.81E-05	1.86E-03	1.19E-03	5.94E-03	1.21E-03	8.3427E-01	4.4728E+02
α_6	2.55E-07	7.64E-04	2.28E-04	3.35E-03	6.07E-04	3.4258E-01	4.4778E+02
α_7	3.71E-25	1.35E-04	1.36E-08	7.57E-04	1.21E-04	6.0371E-02	4.4806E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9705700	0.9812740	0.9818850	0.9898850	0.9922410	5.1055E+02	9.7430E+00
α_2	2.24E-03	6.99E-03	6.37E-03	1.39E-02	1.00E-03	3.6388E+00	5.1665E+02
α_3	8.41E-04	4.22E-03	3.60E-03	9.70E-03	1.55E-03	2.1955E+00	5.1810E+02
α_4	5.80E-04	3.58E-03	2.96E-03	8.67E-03	2.43E-03	1.8610E+00	5.1843E+02
α_5	1.71E-04	2.27E-03	1.67E-03	6.41E-03	1.61E-03	1.1808E+00	5.1911E+02
α_6	1.10E-05	1.16E-03	6.10E-04	4.15E-03	7.97E-04	6.0136E-01	5.1969E+02
α_7	1.26E-09	4.17E-04	5.31E-05	2.10E-03	3.19E-04	2.1677E-01	5.2008E+02
α_8	2.23E-30	9.36E-05	7.45E-10	4.94E-04	5.30E-05	4.8724E-02	5.2024E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9838390	0.9862770	0.9874330	0.9886140	0.9902640	0.9914110	0.9922410
α_2	1.62E-02	8.79E-03	6.15E-03	3.94E-03	9.70E-04	9.39E-04	1.00E-03
α_3		4.93E-03	4.73E-03	4.74E-03	5.66E-03	2.94E-03	1.55E-03
α_4			1.69E-03	2.03E-03	1.70E-03	2.77E-03	2.43E-03
α_5				6.77E-04	1.13E-03	1.21E-03	1.61E-03
α_6					2.83E-04	6.07E-04	7.97E-04
α_7						1.21E-04	3.19E-04
α_8							5.30E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.84E-01	9.86E-01	9.87E-01	9.89E-01	9.90E-01	9.91E-01	9.92E-01
Beta	1.62E-02	1.37E-02	1.26E-02	1.14E-02	9.74E-03	8.59E-03	7.76E-03
Gamma		3.59E-01	5.10E-01	6.54E-01	9.00E-01	8.91E-01	8.71E-01
Delta			2.63E-01	3.64E-01	3.55E-01	6.15E-01	7.70E-01
Epsilon				2.50E-01	4.55E-01	4.12E-01	5.33E-01
Mu					2.00E-01	3.75E-01	4.21E-01
Upsilon						1.67E-01	3.18E-01
Sigma							1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	72.75	109.12	145.49	181.87	218.24	254.61	290.99
N ₁	0.9293	0.9132	0.7766	0.6698	0.7430	0.7972	0.8319
N ₂	1.2103	0.9809	0.9114	0.7268	0.2145	0.2419	0.2941
N ₃		0.5501	0.7002	0.8755	1.2510	0.7583	0.4571
N ₄			0.2500	0.3750	0.3750	0.7125	0.7145
N ₅				0.1250	0.2500	0.3125	0.4725
N ₆					0.0625	0.1563	0.2344
N ₇						0.0313	0.0938
N ₈							0.0156

1.3.1.3 MOV FAIL TO CLOSE ALL SYSTEMS SPAR: MOV-OO

Component : Motor Operated Valve
Failure Mode : Fail to close (reseat) on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 195.90

Total Number of Common-Cause Failure Events: 4

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9742010	0.9919930	0.9949270	0.9997760	0.9958710	9.9889E+01	8.0622E-01
α_2	2.27E-04	8.01E-03	5.07E-03	2.58E-02	4.13E-03	8.0622E-01	9.9889E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9694990	0.9866730	0.9885800	0.9973230	0.9918230	1.6292E+02	2.2005E+00
α_2	1.99E-03	1.17E-02	9.76E-03	2.79E-02	8.12E-03	1.9255E+00	1.6320E+02
α_3	7.76E-08	1.67E-03	3.51E-04	7.83E-03	5.80E-05	2.7502E-01	1.6485E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9658200	0.9822290	0.9836270	0.9938550	0.9878420	2.2253E+02	4.0261E+00
α_2	4.51E-03	1.49E-02	1.35E-02	3.00E-02	1.20E-02	3.3711E+00	2.2318E+02
α_3	3.22E-06	1.90E-03	7.53E-04	7.70E-03	1.51E-04	4.3131E-01	2.2612E+02
α_4	4.48E-09	9.87E-04	1.36E-04	4.94E-03	5.60E-06	2.2367E-01	2.2633E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9664550	0.9805540	0.9815380	0.9912860	0.9877420	3.1596E+02	6.2660E+00
α_2	4.92E-03	1.35E-02	1.25E-02	2.55E-02	1.01E-02	4.3561E+00	3.1787E+02
α_3	5.07E-04	4.52E-03	3.55E-03	1.19E-02	2.16E-03	1.4576E+00	3.2077E+02
α_4	8.55E-07	1.18E-03	4.03E-04	4.98E-03	2.43E-05	3.7979E-01	3.2185E+02
α_5	2.07E-21	2.25E-04	1.30E-07	1.30E-03	8.99E-07	7.2477E-02	3.2215E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9674510	0.9802840	0.9811030	0.9903190	0.9873750	3.7994E+02	7.6415E+00
α_2	4.69E-03	1.22E-02	1.14E-02	2.26E-02	9.40E-03	4.7417E+00	3.8284E+02
α_3	7.79E-04	4.80E-03	3.98E-03	1.16E-02	2.70E-03	1.8608E+00	3.8572E+02
α_4	3.87E-05	1.89E-03	1.13E-03	6.32E-03	5.26E-04	7.3242E-01	3.8685E+02
α_5	2.56E-09	5.76E-04	7.88E-05	2.88E-03	4.13E-06	2.2330E-01	3.8736E+02
α_6	3.63E-19	2.15E-04	3.75E-07	1.25E-03	0.00E+00	8.3237E-02	3.8750E+02

Motor Operated Valves
 Pooled Motor Operated Valve Distributions
 MOV FAIL TO CLOSE ALL SYSTEMS SPAR: MOV-OO
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9685020	0.9798070	0.9804410	0.9889430	0.9881860	4.9052E+02	1.0109E+01
α_2	4.42E-03	1.07E-02	1.01E-02	1.92E-02	7.35E-03	5.3661E+00	4.9526E+02
α_3	1.32E-03	5.36E-03	4.71E-03	1.16E-02	3.39E-03	2.6815E+00	4.9795E+02
α_4	2.27E-04	2.56E-03	1.94E-03	7.02E-03	9.43E-04	1.2814E+00	4.9935E+02
α_5	8.09E-06	1.13E-03	5.68E-04	4.15E-03	1.38E-04	5.6457E-01	5.0006E+02
α_6	1.36E-10	3.72E-04	3.18E-05	1.95E-03	6.45E-07	1.8648E-01	5.0044E+02
α_7	0.00E+00	5.81E-05	5.08E-14	2.18E-04	0.00E+00	2.9071E-02	5.0060E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9699900	0.9803170	0.9808650	0.9887690	0.9888200	5.6866E+02	1.1418E+01
α_2	3.91E-03	9.41E-03	8.85E-03	1.68E-02	5.97E-03	5.4586E+00	5.7462E+02
α_3	1.40E-03	5.15E-03	4.60E-03	1.08E-02	3.54E-03	2.9894E+00	5.7709E+02
α_4	3.65E-04	2.77E-03	2.23E-03	7.05E-03	1.31E-03	1.6093E+00	5.7847E+02
α_5	4.26E-05	1.42E-03	9.04E-04	4.56E-03	3.26E-04	8.2373E-01	5.7925E+02
α_6	4.81E-07	6.56E-04	2.24E-04	2.77E-03	3.81E-05	3.8046E-01	5.7970E+02
α_7	2.80E-14	2.12E-04	3.81E-06	1.21E-03	0.00E+00	1.2297E-01	5.7995E+02
α_8	5.25E-43	5.71E-05	8.13E-13	2.41E-04	0.00E+00	3.3124E-02	5.8004E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9958710	0.9918230	0.9878420	0.9877420	0.9873750	0.9881860	0.9888200
α_2	4.13E-03	8.12E-03	1.20E-02	1.01E-02	9.40E-03	7.35E-03	5.97E-03
α_3		5.80E-05	1.51E-04	2.16E-03	2.70E-03	3.39E-03	3.54E-03
α_4			5.60E-06	2.43E-05	5.26E-04	9.43E-04	1.31E-03
α_5				8.99E-07	4.13E-06	1.38E-04	3.26E-04
α_6					0.00E+00	6.45E-07	3.81E-05
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.96E-01	9.92E-01	9.88E-01	9.88E-01	9.87E-01	9.88E-01	9.89E-01
Beta	4.13E-03	8.18E-03	1.22E-02	1.23E-02	1.26E-02	1.18E-02	1.12E-02
Gamma		7.09E-03	1.29E-02	1.78E-01	2.56E-01	3.78E-01	4.66E-01
Delta			3.57E-02	1.15E-02	1.64E-01	2.42E-01	3.21E-01
Epsilon				3.57E-02	7.78E-03	1.28E-01	2.18E-01
Mu					0.00E+00	4.65E-03	1.05E-01
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Motor Operated Valves

2010

Pooled Motor Operated Valve Distributions

MOV FAIL TO CLOSE ALL SYSTEMS SPAR: MOV-OO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	87.07	130.60	174.13	217.67	261.20	304.73	348.27
N ₁	2.5733	2.7683	2.2623	2.1320	1.7964	1.7442	1.6590
N ₂	0.3717	1.0918	2.1430	2.2419	2.5025	2.2783	2.1139
N ₃		0.0078	0.0270	0.4802	0.7190	1.0503	1.2510
N ₄			0.0010	0.0054	0.1402	0.2925	0.4628
N ₅				0.0002	0.0011	0.0428	0.1154
N ₆					0.0000	0.0002	0.0135
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.1.4 MOV SPURIOUS OPERATION ALL SYSTEMS SPAR: MOV-CO

Component :	Motor Operated Valve
Failure Mode :	Spurious operation open or close
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 24.00

Total Number of Common-Cause Failure Events: 1

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8725230	0.9628520	0.9785950	0.9994900	0.9684190	1.6817E+01	6.4882E-01
α_2	5.07E-04	3.71E-02	2.14E-02	1.27E-01	3.16E-02	6.4882E-01	1.6817E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9013250	0.9605540	0.9678750	0.9947070	0.9496400	3.8984E+01	1.6009E+00
α_2	2.75E-03	3.11E-02	2.38E-02	8.46E-02	4.32E-02	1.2623E+00	3.9323E+01
α_3	2.57E-06	8.34E-03	2.48E-03	3.66E-02	7.19E-03	3.3862E-01	4.0246E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9080180	0.9571600	0.9620750	0.9894800	0.9416900	5.8365E+01	2.6123E+00
α_2	4.31E-03	2.86E-02	2.36E-02	6.99E-02	3.96E-02	1.7424E+00	5.9235E+01
α_3	1.24E-04	1.04E-02	5.73E-03	3.65E-02	1.76E-02	6.3291E-01	6.0344E+01
α_4	3.59E-08	3.89E-03	6.13E-04	1.91E-02	1.10E-03	2.3697E-01	6.0740E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9282170	0.9613920	0.9640230	0.9855610	0.9419630	1.1123E+02	4.4669E+00
α_2	5.19E-03	2.20E-02	1.93E-02	4.80E-02	2.68E-02	2.5428E+00	1.1315E+02
α_3	1.29E-03	1.22E-02	9.48E-03	3.22E-02	2.68E-02	1.4060E+00	1.1429E+02
α_4	8.00E-06	3.85E-03	1.58E-03	1.54E-02	4.46E-03	4.4579E-01	1.1525E+02
α_5	5.16E-21	6.25E-04	3.53E-07	3.62E-03	0.00E+00	7.2277E-02	1.1562E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9327880	0.9623540	0.9645330	0.9844680	0.9473680	1.3494E+02	5.2787E+00
α_2	3.97E-03	1.75E-02	1.53E-02	3.87E-02	1.13E-02	2.4535E+00	1.3777E+02
α_3	1.78E-03	1.22E-02	9.99E-03	3.03E-02	3.01E-02	1.7132E+00	1.3851E+02
α_4	1.63E-04	5.75E-03	3.64E-03	1.86E-02	1.13E-02	8.0652E-01	1.3941E+02
α_5	6.62E-09	1.58E-03	2.15E-04	7.94E-03	0.00E+00	2.2220E-01	1.4000E+02
α_6	1.01E-18	5.94E-04	1.04E-06	3.46E-03	0.00E+00	8.3237E-02	1.4014E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9684190	0.9496400	0.9416900	0.9419630	0.9473680
α_2	3.16E-02	4.32E-02	3.96E-02	2.68E-02	1.13E-02
α_3		7.19E-03	1.76E-02	2.68E-02	3.01E-02
α_4			1.10E-03	4.46E-03	1.13E-02
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.68E-01	9.50E-01	9.42E-01	9.42E-01	9.47E-01
Beta	3.16E-02	5.04E-02	5.83E-02	5.80E-02	5.26E-02
Gamma		1.43E-01	3.21E-01	5.38E-01	7.86E-01
Delta			5.89E-02	1.43E-01	2.73E-01
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	6.00	9.00	12.00	15.00	18.00
N ₁	0.5714	0.4286	0.2286	0.0714	0.0000
N ₂	0.2143	0.4286	0.5143	0.4286	0.2143
N ₃		0.0714	0.2286	0.4286	0.5714
N ₄			0.0143	0.0714	0.2143
N ₅				0.0000	0.0000
N ₆					0.0000

PWR Containment Spray Motor Operated Valves
 CONTAINMENT SPRAY MOV FAIL TO OPEN/CLOSE

1.3.2 PWR Containment Spray Motor Operated Valves

1.3.2.1 CONTAINMENT SPRAY MOV FAIL TO OPEN/CLOSE

System :	Containment spray recirculation
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand Fail to Open/Close Mode Unspecified (demand based) Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 23.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9489320	0.9872880	0.9948520	0.9999750	1.0000000	3.3746E+01	4.3452E-01
α_2	2.29E-05	1.27E-02	5.15E-03	5.11E-02	0.00E+00	4.3452E-01	3.3746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9417320	0.9796720	0.9852150	0.9986630	1.0000000	5.3055E+01	1.1009E+00
α_2	4.87E-04	1.54E-02	9.97E-03	4.88E-02	0.00E+00	8.3366E-01	5.3322E+01
α_3	1.73E-07	4.93E-03	9.93E-04	2.34E-02	0.00E+00	2.6722E-01	5.3889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9376940	0.9740520	0.9783390	0.9957420	1.0000000	6.9636E+01	1.8551E+00
α_2	1.42E-03	1.72E-02	1.29E-02	4.75E-02	0.00E+00	1.2281E+00	7.0263E+01
α_3	6.36E-06	5.66E-03	2.09E-03	2.34E-02	0.00E+00	4.0431E-01	7.1087E+01
α_4	1.34E-08	3.11E-03	4.26E-04	1.56E-02	0.00E+00	2.2267E-01	7.1268E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9430560	0.9712800	0.9737970	0.9909040	1.0000000	1.1966E+02	3.5382E+00
α_2	3.30E-03	1.72E-02	1.46E-02	3.97E-02	0.00E+00	2.1142E+00	1.2108E+02
α_3	3.87E-04	7.93E-03	5.48E-03	2.39E-02	0.00E+00	9.7738E-01	1.2222E+02
α_4	2.00E-06	3.04E-03	1.02E-03	1.29E-02	0.00E+00	3.7439E-01	1.2282E+02
α_5	4.84E-21	5.87E-04	3.32E-07	3.40E-03	0.00E+00	7.2277E-02	1.2313E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9442590	0.9704350	0.9725790	0.9892870	1.0000000	1.4044E+02	4.2787E+00
α_2	3.18E-03	1.55E-02	1.33E-02	3.52E-02	0.00E+00	2.2392E+00	1.4248E+02
α_3	5.55E-04	7.89E-03	5.77E-03	2.25E-02	0.00E+00	1.1418E+00	1.4358E+02
α_4	3.66E-05	4.09E-03	2.14E-03	1.48E-02	0.00E+00	5.9222E-01	1.4413E+02
α_5	6.42E-09	1.54E-03	2.08E-04	7.69E-03	0.00E+00	2.2220E-01	1.4450E+02
α_6	9.74E-19	5.75E-04	1.01E-06	3.36E-03	0.00E+00	8.3237E-02	1.4464E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	23.50	23.50	23.50	23.50	23.50
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

Motor Operated Valves
 PWR Containment Spray Motor Operated Valves
 CONTAINMENT SPRAY MOV-CC

2010

1.3.2.2 CONTAINMENT SPRAY MOV-CC

System :	Containment spray recirculation
Component :	Motor Operated Valve
Failure Mode :	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 16.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9358690	0.9840140	0.9935000	0.9999680	1.0000000	2.6746E+01	4.3452E-01
α_2	2.90E-05	1.60E-02	6.50E-03	6.41E-02	0.00E+00	4.3452E-01	2.6746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9331860	0.9766540	0.9829890	0.9984660	1.0000000	4.6055E+01	1.1009E+00
α_2	5.60E-04	1.77E-02	1.15E-02	5.60E-02	0.00E+00	8.3366E-01	4.6322E+01
α_3	1.99E-07	5.67E-03	1.14E-03	2.69E-02	0.00E+00	2.6722E-01	4.6889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9310250	0.9712350	0.9759630	0.9952700	1.0000000	6.2636E+01	1.8551E+00
α_2	1.58E-03	1.90E-02	1.43E-02	5.26E-02	0.00E+00	1.2281E+00	6.3263E+01
α_3	7.06E-06	6.27E-03	2.32E-03	2.59E-02	0.00E+00	4.0431E-01	6.4087E+01
α_4	1.49E-08	3.45E-03	4.73E-04	1.73E-02	0.00E+00	2.2267E-01	6.4268E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9396640	0.9695500	0.9722090	0.9903480	1.0000000	1.1266E+02	3.5382E+00
α_2	3.50E-03	1.82E-02	1.55E-02	4.21E-02	0.00E+00	2.1142E+00	1.1408E+02
α_3	4.11E-04	8.41E-03	5.81E-03	2.53E-02	0.00E+00	9.7738E-01	1.1522E+02
α_4	2.12E-06	3.22E-03	1.08E-03	1.37E-02	0.00E+00	3.7439E-01	1.1582E+02
α_5	5.13E-21	6.22E-04	3.52E-07	3.60E-03	0.00E+00	7.2277E-02	1.1613E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9414510	0.9689320	0.9711740	0.9887350	1.0000000	1.3344E+02	4.2787E+00
α_2	3.34E-03	1.63E-02	1.40E-02	3.70E-02	0.00E+00	2.2392E+00	1.3548E+02
α_3	5.84E-04	8.29E-03	6.06E-03	2.36E-02	0.00E+00	1.1418E+00	1.3658E+02
α_4	3.84E-05	4.30E-03	2.25E-03	1.55E-02	0.00E+00	5.9222E-01	1.3713E+02
α_5	6.74E-09	1.61E-03	2.19E-04	8.08E-03	0.00E+00	2.2220E-01	1.3750E+02
α_6	1.02E-18	6.04E-04	1.06E-06	3.53E-03	0.00E+00	8.3237E-02	1.3764E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	16.50	16.50	16.50	16.50	16.50
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

Motor Operated Valves
 PWR Containment Spray Motor Operated Valves
 CONTAINMENT SPRAY MOV-OO

2010

1.3.2.3 CONTAINMENT SPRAY MOV-OO

System :	Containment spray recirculation
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 7.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9017830	0.9754240	0.9898730	0.9999510	1.0000000	1.7246E+01	4.3452E-01
α_2	4.52E-05	2.46E-02	1.01E-02	9.82E-02	0.00E+00	4.3452E-01	1.7246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9165860	0.9707650	0.9786210	0.9980670	1.0000000	3.6555E+01	1.1009E+00
α_2	7.05E-04	2.21E-02	1.44E-02	7.00E-02	0.00E+00	8.3366E-01	3.6822E+01
α_3	2.49E-07	7.10E-03	1.44E-03	3.37E-02	0.00E+00	2.6722E-01	3.7389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9192920	0.9662660	0.9717540	0.9944390	1.0000000	5.3136E+01	1.8551E+00
α_2	1.85E-03	2.23E-02	1.68E-02	6.16E-02	0.00E+00	1.2281E+00	5.3763E+01
α_3	8.29E-06	7.35E-03	2.73E-03	3.04E-02	0.00E+00	4.0431E-01	5.4587E+01
α_4	1.75E-08	4.05E-03	5.55E-04	2.03E-02	0.00E+00	2.2267E-01	5.4768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9343580	0.9668390	0.9697150	0.9894740	1.0000000	1.0316E+02	3.5382E+00
α_2	3.82E-03	1.98E-02	1.69E-02	4.58E-02	0.00E+00	2.1142E+00	1.0458E+02
α_3	4.48E-04	9.16E-03	6.33E-03	2.75E-02	0.00E+00	9.7738E-01	1.0572E+02
α_4	2.31E-06	3.51E-03	1.18E-03	1.49E-02	0.00E+00	3.7439E-01	1.0632E+02
α_5	5.59E-21	6.77E-04	3.83E-07	3.92E-03	0.00E+00	7.2277E-02	1.0663E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9371630	0.9666300	0.9690330	0.9878880	1.0000000	1.2394E+02	4.2787E+00
α_2	3.59E-03	1.75E-02	1.50E-02	3.97E-02	0.00E+00	2.2392E+00	1.2598E+02
α_3	6.27E-04	8.91E-03	6.51E-03	2.54E-02	0.00E+00	1.1418E+00	1.2708E+02
α_4	4.13E-05	4.62E-03	2.42E-03	1.67E-02	0.00E+00	5.9222E-01	1.2763E+02
α_5	7.25E-09	1.73E-03	2.35E-04	8.68E-03	0.00E+00	2.2220E-01	1.2800E+02
α_6	1.10E-18	6.49E-04	1.14E-06	3.79E-03	0.00E+00	8.3237E-02	1.2814E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	7.00	7.00	7.00	7.00	7.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.3.3 BWR Residual Heat Removal Motor-Operated Valves

1.3.3.1 BWR RHR MOV FAIL TO OPEN/CLOSE

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand
	Fail to Open/Close Mode Unspecified (demand based)
	Fail to open on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 123.50

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9588300	0.9840110	0.9872660	0.9980620	0.9871410	9.3409E+01	1.5178E+00
α_2	1.94E-03	1.60E-02	1.27E-02	4.12E-02	1.29E-02	1.5178E+00	9.3409E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9663090	0.9849690	0.9869850	0.9967460	0.9900600	1.5405E+02	2.3509E+00
α_2	1.31E-03	1.01E-02	8.13E-03	2.58E-02	5.96E-03	1.5837E+00	1.5482E+02
α_3	1.18E-04	4.91E-03	3.02E-03	1.61E-02	3.98E-03	7.6722E-01	1.5563E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9684800	0.9844070	0.9858850	0.9952960	0.9910270	2.1181E+02	3.3551E+00
α_2	1.62E-03	9.19E-03	7.72E-03	2.18E-02	4.49E-03	1.9781E+00	2.1319E+02
α_3	1.66E-04	4.20E-03	2.80E-03	1.30E-02	2.99E-03	9.0431E-01	2.1426E+02
α_4	6.38E-06	2.20E-03	9.52E-04	8.60E-03	1.50E-03	4.7267E-01	2.1469E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9695490	0.9831140	0.9841460	0.9931420	0.9920080	3.0303E+02	5.2049E+00
α_2	2.37E-03	9.16E-03	8.12E-03	1.95E-02	3.40E-03	2.8225E+00	3.0541E+02
α_3	5.09E-04	4.66E-03	3.64E-03	1.23E-02	2.20E-03	1.4357E+00	3.0680E+02
α_4	5.39E-05	2.43E-03	1.47E-03	8.06E-03	1.80E-03	7.4939E-01	3.0749E+02
α_5	5.38E-10	6.40E-04	6.41E-05	3.31E-03	5.99E-04	1.9728E-01	3.0804E+02

Motor Operated Valves

2010

BWR Residual Heat Removal Motor-Operated Valves

BWR RHR MOV FAIL TO OPEN/CLOSE

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9713760	0.9835110	0.9843700	0.9927070	0.9926350	3.6498E+02	6.1190E+00
α_2	2.16E-03	7.98E-03	7.11E-03	1.68E-02	2.89E-03	2.9614E+00	3.6814E+02
α_3	5.26E-04	4.20E-03	3.35E-03	1.08E-02	1.67E-03	1.5585E+00	3.6954E+02
α_4	1.30E-04	2.64E-03	1.82E-03	7.96E-03	1.56E-03	9.8112E-01	3.7012E+02
α_5	3.67E-06	1.27E-03	5.50E-04	4.99E-03	1.00E-03	4.7220E-01	3.7063E+02
α_6	2.01E-12	3.93E-04	1.46E-05	2.17E-03	2.50E-04	1.4574E-01	3.7095E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9716030	0.9824390	0.9831000	0.9910140	0.9930840	4.7323E+02	8.4590E+00
α_2	2.66E-03	7.98E-03	7.31E-03	1.56E-02	2.59E-03	3.8424E+00	4.7785E+02
α_3	7.70E-04	4.23E-03	3.56E-03	9.95E-03	1.39E-03	2.0363E+00	4.7965E+02
α_4	2.69E-04	2.78E-03	2.13E-03	7.52E-03	1.21E-03	1.3408E+00	4.8035E+02
α_5	5.47E-05	1.74E-03	1.11E-03	5.54E-03	1.08E-03	8.3657E-01	4.8085E+02
α_6	2.37E-07	7.11E-04	2.12E-04	3.11E-03	5.37E-04	3.4258E-01	4.8135E+02
α_7	3.45E-25	1.25E-04	1.26E-08	7.04E-04	1.07E-04	6.0371E-02	4.8163E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9728060	0.9827380	0.9833080	0.9907150	0.9934350	5.4902E+02	9.6437E+00
α_2	2.59E-03	7.40E-03	6.82E-03	1.42E-02	2.37E-03	4.1319E+00	5.5453E+02
α_3	7.56E-04	3.87E-03	3.29E-03	8.94E-03	1.27E-03	2.1601E+00	5.5650E+02
α_4	2.91E-04	2.60E-03	2.04E-03	6.85E-03	9.28E-04	1.4551E+00	5.5721E+02
α_5	1.02E-04	1.84E-03	1.29E-03	5.46E-03	9.65E-04	1.0293E+00	5.5763E+02
α_6	1.03E-05	1.08E-03	5.69E-04	3.87E-03	7.06E-04	6.0176E-01	5.5806E+02
α_7	1.18E-09	3.88E-04	4.94E-05	1.96E-03	2.82E-04	2.1677E-01	5.5845E+02
α_8	2.08E-30	8.72E-05	6.94E-10	4.60E-04	4.69E-05	4.8724E-02	5.5861E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9871410	0.9900600	0.9910270	0.9920080	0.9926350	0.9930840	0.9934350
α_2	1.29E-02	5.96E-03	4.49E-03	3.40E-03	2.89E-03	2.59E-03	2.37E-03
α_3		3.98E-03	2.99E-03	2.20E-03	1.67E-03	1.39E-03	1.27E-03
α_4			1.50E-03	1.80E-03	1.56E-03	1.21E-03	9.28E-04
α_5				5.99E-04	1.00E-03	1.08E-03	9.65E-04
α_6					2.50E-04	5.37E-04	7.06E-04
α_7						1.07E-04	2.82E-04
α_8							4.69E-05

Motor Operated Valves

2010

BWR Residual Heat Removal Motor-Operated Valves

BWR RHR MOV FAIL TO OPEN/CLOSE

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.87E-01	9.90E-01	9.91E-01	9.92E-01	9.93E-01	9.93E-01	9.93E-01
Beta	1.29E-02	9.94E-03	8.97E-03	7.99E-03	7.36E-03	6.92E-03	6.56E-03
Gamma		4.00E-01	5.00E-01	5.75E-01	6.08E-01	6.25E-01	6.39E-01
Delta			3.33E-01	5.22E-01	6.27E-01	6.78E-01	6.98E-01
Epsilon				2.50E-01	4.46E-01	5.88E-01	6.83E-01
Mu					2.00E-01	3.73E-01	5.17E-01
Upsilon						1.67E-01	3.18E-01
Sigma							1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	82.33	123.50	164.67	205.83	247.00	288.17	329.33
N ₁	0.8333	1.0000	1.0000	1.0417	1.0417	1.0127	0.9645
N ₂	1.0833	0.7500	0.7500	0.7083	0.7222	0.7546	0.7872
N ₃		0.5000	0.5000	0.4583	0.4167	0.4051	0.4217
N ₄			0.2500	0.3750	0.3889	0.3519	0.3086
N ₅				0.1250	0.2500	0.3148	0.3210
N ₆					0.0625	0.1563	0.2348
N ₇						0.0313	0.0938
N ₈							0.0156

Motor Operated Valves
 BWR Residual Heat Removal Motor-Operated Valves
 BWR RHR MOV FAIL TO OPEN

2010

1.3.3.2 BWR RHR MOV FAIL TO OPEN

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Operated Valve
Failure Mode :	Fail to open on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 74.20

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9561880	0.9832970	0.9868790	0.9981570	0.9867020	8.4446E+01	1.4345E+00
α_2	1.84E-03	1.67E-02	1.31E-02	4.38E-02	1.33E-02	1.4345E+00	8.4446E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9658970	0.9853030	0.9875020	0.9972020	0.9910950	1.4085E+02	2.1009E+00
α_2	8.98E-04	9.33E-03	7.16E-03	2.52E-02	4.45E-03	1.3337E+00	1.4162E+02
α_3	1.29E-04	5.37E-03	3.31E-03	1.76E-02	4.45E-03	7.6722E-01	1.4218E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9693850	0.9855360	0.9871450	0.9962020	0.9933070	1.9454E+02	2.8551E+00
α_2	8.62E-04	7.49E-03	5.90E-03	1.95E-02	1.67E-03	1.4781E+00	1.9592E+02
α_3	1.81E-04	4.58E-03	3.05E-03	1.42E-02	3.35E-03	9.0431E-01	1.9649E+02
α_4	6.96E-06	2.39E-03	1.04E-03	9.37E-03	1.67E-03	4.7267E-01	1.9692E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9704120	0.9841430	0.9852550	0.9940720	0.9946380	2.8166E+02	4.5383E+00
α_2	1.60E-03	7.82E-03	6.71E-03	1.79E-02	6.70E-04	2.2392E+00	2.8396E+02
α_3	4.65E-04	4.73E-03	3.63E-03	1.27E-02	2.01E-03	1.3524E+00	2.8485E+02
α_4	5.80E-05	2.62E-03	1.59E-03	8.68E-03	2.01E-03	7.4939E-01	2.8545E+02
α_5	5.80E-10	6.89E-04	6.91E-05	3.57E-03	6.70E-04	1.9728E-01	2.8600E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9724730	0.9846920	0.9856170	0.9937420	0.9955280	3.3954E+02	5.2787E+00
α_2	1.41E-03	6.68E-03	5.75E-03	1.51E-02	2.80E-04	2.3017E+00	3.4252E+02
α_3	4.18E-04	4.04E-03	3.13E-03	1.08E-02	1.12E-03	1.3918E+00	3.4343E+02
α_4	1.33E-04	2.81E-03	1.92E-03	8.49E-03	1.68E-03	9.6722E-01	3.4385E+02
α_5	3.95E-06	1.37E-03	5.92E-04	5.37E-03	1.12E-03	4.7220E-01	3.4435E+02
α_6	2.16E-12	4.23E-04	1.58E-05	2.34E-03	2.80E-04	1.4574E-01	3.4467E+02

Motor Operated Valves

2010

BWR Residual Heat Removal Motor-Operated Valves

BWR RHR MOV FAIL TO OPEN

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9725780	0.9834990	0.9842060	0.9919930	0.9961630	4.4375E+02	7.4452E+00
α_2	1.96E-03	6.91E-03	6.20E-03	1.43E-02	1.20E-04	3.1191E+00	4.4808E+02
α_3	6.08E-04	3.96E-03	3.26E-03	9.72E-03	6.00E-04	1.7875E+00	4.4941E+02
α_4	2.64E-04	2.88E-03	2.19E-03	7.87E-03	1.20E-03	1.3014E+00	4.4989E+02
α_5	5.77E-05	1.85E-03	1.19E-03	5.90E-03	1.20E-03	8.3427E-01	4.5036E+02
α_6	2.53E-07	7.59E-04	2.26E-04	3.32E-03	6.00E-04	3.4258E-01	4.5085E+02
α_7	3.68E-25	1.34E-04	1.35E-08	7.52E-04	1.20E-04	6.0371E-02	4.5113E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9738770	0.9838530	0.9844620	0.9917400	0.9966420	5.1553E+02	8.4611E+00
α_2	1.93E-03	6.41E-03	5.80E-03	1.30E-02	5.24E-05	3.3603E+00	5.2063E+02
α_3	5.55E-04	3.50E-03	2.89E-03	8.52E-03	3.15E-04	1.8322E+00	5.2216E+02
α_4	2.69E-04	2.64E-03	2.04E-03	7.05E-03	7.87E-04	1.3809E+00	5.2261E+02
α_5	1.05E-04	1.95E-03	1.36E-03	5.79E-03	1.05E-03	1.0208E+00	5.2297E+02
α_6	1.09E-05	1.15E-03	6.06E-04	4.12E-03	7.87E-04	6.0136E-01	5.2339E+02
α_7	1.26E-09	4.14E-04	5.27E-05	2.09E-03	3.15E-04	2.1677E-01	5.2377E+02
α_8	2.22E-30	9.30E-05	7.40E-10	4.90E-04	5.24E-05	4.8724E-02	5.2394E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9867020	0.9910950	0.9933070	0.9946380	0.9955280	0.9961630	0.9966420
α_2	1.33E-02	4.45E-03	1.67E-03	6.70E-04	2.80E-04	1.20E-04	5.24E-05
α_3		4.45E-03	3.35E-03	2.01E-03	1.12E-03	6.00E-04	3.15E-04
α_4			1.67E-03	2.01E-03	1.68E-03	1.20E-03	7.87E-04
α_5				6.70E-04	1.12E-03	1.20E-03	1.05E-03
α_6					2.80E-04	6.00E-04	7.87E-04
α_7						1.20E-04	3.15E-04
α_8							5.24E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.87E-01	9.91E-01	9.93E-01	9.95E-01	9.96E-01	9.96E-01	9.97E-01
Beta	1.33E-02	8.90E-03	6.69E-03	5.36E-03	4.47E-03	3.84E-03	3.36E-03
Gamma		5.00E-01	7.50E-01	8.75E-01	9.38E-01	9.69E-01	9.84E-01
Delta			3.33E-01	5.71E-01	7.33E-01	8.39E-01	9.05E-01
Epsilon				2.50E-01	4.55E-01	6.15E-01	7.37E-01
Mu					2.00E-01	3.75E-01	5.24E-01
Upsilon						1.67E-01	3.18E-01
Sigma							1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	74.20	111.30	148.40	185.50	222.60	259.70	296.80
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	1.0000	0.5000	0.2500	0.1250	0.0625	0.0313	0.0156
N ₃		0.5000	0.5000	0.3750	0.2500	0.1563	0.0938
N ₄			0.2500	0.3750	0.3750	0.3125	0.2344
N ₅				0.1250	0.2500	0.3125	0.3125
N ₆					0.0625	0.1563	0.2344
N ₇						0.0313	0.0938
N ₈							0.0156

Motor Operated Valves
 BWR Residual Heat Removal Motor-Operated Valves
 BWR RHR MOV FAIL TO CLOSE

2010

1.3.3.3 BWR RHR MOV FAIL TO CLOSE

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 47.30

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9446310	0.9853090	0.9929860	0.9999270	0.9966090	3.4729E+01	5.1782E-01
α_2	7.08E-05	1.47E-02	7.02E-03	5.54E-02	3.39E-03	5.1782E-01	3.4729E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9464220	0.9799500	0.9844730	0.9980050	0.9931920	6.6025E+01	1.3509E+00
α_2	1.02E-03	1.61E-02	1.16E-02	4.65E-02	6.81E-03	1.0837E+00	6.6292E+01
α_3	1.38E-07	3.97E-03	7.96E-04	1.88E-02	0.00E+00	2.6722E-01	6.7109E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9457010	0.9756680	0.9788700	0.9946910	0.9897540	9.4436E+01	2.3551E+00
α_2	2.64E-03	1.79E-02	1.47E-02	4.40E-02	1.02E-02	1.7281E+00	9.5063E+01
α_3	4.69E-06	4.18E-03	1.54E-03	1.73E-02	0.00E+00	4.0431E-01	9.6387E+01
α_4	9.89E-09	2.30E-03	3.14E-04	1.15E-02	0.00E+00	2.2267E-01	9.6568E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9503380	0.9738070	0.9757540	0.9906320	0.9890430	1.5633E+02	4.2049E+00
α_2	4.19E-03	1.68E-02	1.48E-02	3.61E-02	9.59E-03	2.6975E+00	1.5784E+02
α_3	3.93E-04	6.61E-03	4.70E-03	1.93E-02	1.37E-03	1.0607E+00	1.5947E+02
α_4	1.53E-06	2.33E-03	7.84E-04	9.91E-03	0.00E+00	3.7439E-01	1.6016E+02
α_5	3.71E-21	4.50E-04	2.54E-07	2.60E-03	0.00E+00	7.2277E-02	1.6046E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9523810	0.9736200	0.9752340	0.9893540	0.9884620	1.8893E+02	5.1190E+00
α_2	3.98E-03	1.49E-02	1.33E-02	3.15E-02	9.06E-03	2.8989E+00	1.9115E+02
α_3	6.25E-04	6.74E-03	5.14E-03	1.83E-02	2.29E-03	1.3085E+00	1.9274E+02
α_4	3.08E-05	3.12E-03	1.66E-03	1.12E-02	1.91E-04	6.0612E-01	1.9344E+02
α_5	4.78E-09	1.15E-03	1.55E-04	5.74E-03	0.00E+00	2.2220E-01	1.9383E+02
α_6	7.26E-19	4.29E-04	7.49E-07	2.50E-03	0.00E+00	8.3237E-02	1.9397E+02

Motor Operated Valves

2010

BWR Residual Heat Removal Motor-Operated Valves

BWR RHR MOV FAIL TO CLOSE

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9551240	0.9729060	0.9740460	0.9868020	0.9880450	2.6784E+02	7.4589E+00
α_2	4.60E-03	1.38E-02	1.27E-02	2.71E-02	8.53E-03	3.8112E+00	2.7149E+02
α_3	1.13E-03	6.83E-03	5.68E-03	1.65E-02	2.93E-03	1.8800E+00	2.7342E+02
α_4	2.06E-04	3.74E-03	2.62E-03	1.11E-02	4.65E-04	1.0283E+00	2.7427E+02
α_5	9.56E-06	1.90E-03	9.04E-04	7.19E-03	2.71E-05	5.2407E-01	2.7477E+02
α_6	2.44E-10	6.77E-04	5.77E-05	3.55E-03	0.00E+00	1.8628E-01	2.7511E+02
α_7	0.00E+00	1.06E-04	9.24E-14	3.97E-04	0.00E+00	2.9071E-02	2.7527E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9570090	0.9732340	0.9742030	0.9861400	0.9877750	3.1429E+02	8.6437E+00
α_2	4.47E-03	1.27E-02	1.18E-02	2.44E-02	7.98E-03	4.1163E+00	3.1882E+02
α_3	1.19E-03	6.40E-03	5.41E-03	1.50E-02	3.39E-03	2.0663E+00	3.2087E+02
α_4	3.05E-04	3.78E-03	2.82E-03	1.05E-02	7.68E-04	1.2208E+00	3.2171E+02
α_5	4.21E-05	2.22E-03	1.31E-03	7.48E-03	8.79E-05	7.1683E-01	3.2222E+02
α_6	6.49E-07	1.14E-03	3.73E-04	4.86E-03	4.13E-06	3.6736E-01	3.2257E+02
α_7	5.04E-14	3.81E-04	6.84E-06	2.17E-03	0.00E+00	1.2297E-01	3.2281E+02
α_8	9.44E-43	1.03E-04	1.46E-12	4.33E-04	0.00E+00	3.3124E-02	3.2290E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9966090	0.9931920	0.9897540	0.9890430	0.9884620	0.9880450	0.9877750
α_2	3.39E-03	6.81E-03	1.02E-02	9.59E-03	9.06E-03	8.53E-03	7.98E-03
α_3		0.00E+00	0.00E+00	1.37E-03	2.29E-03	2.93E-03	3.39E-03
α_4			0.00E+00	0.00E+00	1.91E-04	4.65E-04	7.68E-04
α_5				0.00E+00	0.00E+00	2.71E-05	8.79E-05
α_6					0.00E+00	0.00E+00	4.13E-06
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.97E-01	9.93E-01	9.90E-01	9.89E-01	9.88E-01	9.88E-01	9.88E-01
Beta	3.39E-03	6.81E-03	1.02E-02	1.10E-02	1.15E-02	1.20E-02	1.22E-02
Gamma		0.00E+00	0.00E+00	1.25E-01	2.15E-01	2.87E-01	3.48E-01
Delta			0.00E+00	0.00E+00	7.70E-02	1.44E-01	2.02E-01
Epsilon				0.00E+00	0.00E+00	5.52E-02	1.07E-01
Mu					0.00E+00	0.00E+00	4.49E-02
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

BWR Residual Heat Removal Motor-Operated Valves

BWR RHR MOV FAIL TO CLOSE

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	23.65	35.47	47.30	59.13	70.95	82.78	94.60
N ₁	0.8333	1.0000	1.0000	1.0417	1.0417	1.0127	0.9645
N ₂	0.0833	0.2500	0.5000	0.5833	0.6597	0.7234	0.7716
N ₃		0.0000	0.0000	0.0833	0.1667	0.2488	0.3279
N ₄			0.0000	0.0000	0.0139	0.0394	0.0743
N ₅				0.0000	0.0000	0.0023	0.0085
N ₆					0.0000	0.0000	0.0004
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.4 BWR Isolation Condenser Motor-Operated Valves

1.3.4.1 ISO CONDENSER MOV FAIL TO OPEN/CLOSE

System :	Isolation condenser
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand Fail to Open/Close Mode Unspecified (demand based) Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 8.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9069840	0.9767390	0.9904340	0.9999540	1.0000000	1.8246E+01	4.3452E-01
α_2	4.27E-05	2.33E-02	9.56E-03	9.30E-02	0.00E+00	4.3452E-01	1.8246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9187120	0.9715210	0.9791840	0.9981180	1.0000000	3.7555E+01	1.1009E+00
α_2	6.87E-04	2.16E-02	1.40E-02	6.82E-02	0.00E+00	8.3366E-01	3.7822E+01
α_3	2.43E-07	6.91E-03	1.40E-03	3.28E-02	0.00E+00	2.6722E-01	3.8389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9207150	0.9668680	0.9722640	0.9945410	1.0000000	5.4136E+01	1.8551E+00
α_2	1.82E-03	2.19E-02	1.65E-02	6.05E-02	0.00E+00	1.2281E+00	5.4763E+01
α_3	8.14E-06	7.22E-03	2.68E-03	2.98E-02	0.00E+00	4.0431E-01	5.5587E+01
α_4	1.72E-08	3.98E-03	5.45E-04	1.99E-02	0.00E+00	2.2267E-01	5.5768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9349600	0.9671470	0.9699980	0.9895730	1.0000000	1.0416E+02	3.5382E+00
α_2	3.78E-03	1.96E-02	1.67E-02	4.54E-02	0.00E+00	2.1142E+00	1.0558E+02
α_3	4.43E-04	9.08E-03	6.27E-03	2.73E-02	0.00E+00	9.7738E-01	1.0672E+02
α_4	2.29E-06	3.48E-03	1.17E-03	1.48E-02	0.00E+00	3.7439E-01	1.0732E+02
α_5	5.54E-21	6.71E-04	3.80E-07	3.89E-03	0.00E+00	7.2277E-02	1.0763E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9376440	0.9668880	0.9692700	0.9879830	1.0000000	1.2494E+02	4.2787E+00
α_2	3.56E-03	1.73E-02	1.49E-02	3.94E-02	0.00E+00	2.2392E+00	1.2698E+02
α_3	6.22E-04	8.84E-03	6.46E-03	2.52E-02	0.00E+00	1.1418E+00	1.2808E+02
α_4	4.10E-05	4.58E-03	2.40E-03	1.65E-02	0.00E+00	5.9222E-01	1.2863E+02
α_5	7.19E-09	1.72E-03	2.33E-04	8.62E-03	0.00E+00	2.2220E-01	1.2900E+02
α_6	1.09E-18	6.44E-04	1.13E-06	3.76E-03	0.00E+00	8.3237E-02	1.2914E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	8.00	8.00	8.00	8.00	8.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.3.4.2 ISO CONDENSER MOV FAIL TO OPEN

System : Isolation condenser
Component : Motor Operated Valve
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8959650	0.9739500	0.9892430	0.9999480	1.0000000	1.6246E+01	4.3452E-01
α_2	4.81E-05	2.60E-02	1.08E-02	1.04E-01	0.00E+00	4.3452E-01	1.6246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9143470	0.9699670	0.9780280	0.9980130	1.0000000	3.5555E+01	1.1009E+00
α_2	7.25E-04	2.27E-02	1.48E-02	7.18E-02	0.00E+00	8.3366E-01	3.5822E+01
α_3	2.56E-07	7.29E-03	1.48E-03	3.46E-02	0.00E+00	2.6722E-01	3.6389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9178250	0.9656410	0.9712250	0.9943340	1.0000000	5.2136E+01	1.8551E+00
α_2	1.89E-03	2.27E-02	1.72E-02	6.27E-02	0.00E+00	1.2281E+00	5.2763E+01
α_3	8.45E-06	7.49E-03	2.78E-03	3.09E-02	0.00E+00	4.0431E-01	5.3587E+01
α_4	1.78E-08	4.12E-03	5.66E-04	2.07E-02	0.00E+00	2.2267E-01	5.3768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9337450	0.9665250	0.9694270	0.9893730	1.0000000	1.0216E+02	3.5382E+00
α_2	3.85E-03	2.00E-02	1.71E-02	4.62E-02	0.00E+00	2.1142E+00	1.0358E+02
α_3	4.52E-04	9.25E-03	6.39E-03	2.78E-02	0.00E+00	9.7738E-01	1.0472E+02
α_4	2.33E-06	3.54E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0532E+02
α_5	5.65E-21	6.84E-04	3.87E-07	3.96E-03	0.00E+00	7.2277E-02	1.0563E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9366750	0.9663680	0.9687880	0.9877920	1.0000000	1.2294E+02	4.2787E+00
α_2	3.62E-03	1.76E-02	1.51E-02	4.00E-02	0.00E+00	2.2392E+00	1.2498E+02
α_3	6.32E-04	8.98E-03	6.57E-03	2.55E-02	0.00E+00	1.1418E+00	1.2608E+02
α_4	4.16E-05	4.66E-03	2.44E-03	1.68E-02	0.00E+00	5.9222E-01	1.2663E+02
α_5	7.30E-09	1.75E-03	2.37E-04	8.75E-03	0.00E+00	2.2220E-01	1.2700E+02
α_6	1.11E-18	6.54E-04	1.14E-06	3.82E-03	0.00E+00	8.3237E-02	1.2714E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	6.00	6.00	6.00	6.00	6.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.3.4.3 ISO CONDENSER MOV FAIL TO CLOSE

System :	Isolation condenser
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
α_2	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
α_2	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
α_3	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
α_2	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
α_3	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
α_4	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9311740	0.9652090	0.9682200	0.9889480	1.0000000	9.8161E+01	3.5382E+00
α_2	4.01E-03	2.08E-02	1.77E-02	4.80E-02	0.00E+00	2.1142E+00	9.9585E+01
α_3	4.70E-04	9.61E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0072E+02
α_4	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0132E+02
α_5	5.87E-21	7.11E-04	4.02E-07	4.12E-03	0.00E+00	7.2277E-02	1.0163E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9346440	0.9652760	0.9677640	0.9873890	1.0000000	1.1894E+02	4.2787E+00
α_2	3.74E-03	1.82E-02	1.56E-02	4.13E-02	0.00E+00	2.2392E+00	1.2098E+02
α_3	6.53E-04	9.27E-03	6.78E-03	2.64E-02	0.00E+00	1.1418E+00	1.2208E+02
α_4	4.30E-05	4.81E-03	2.52E-03	1.73E-02	0.00E+00	5.9222E-01	1.2263E+02
α_5	7.54E-09	1.80E-03	2.45E-04	9.04E-03	0.00E+00	2.2220E-01	1.2300E+02
α_6	1.14E-18	6.76E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2314E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	2.00	2.00	2.00	2.00	2.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.3.5 PWR Auxiliary Feedwater Motor-Operated Valves

1.3.5.1 AFW MOV FAIL TO OPEN/CLOSE SPAR: AFW-MOV-FO

System :

Auxiliary feedwater

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Fail to Open/Close Mode Unspecified (demand based)

Fail to open on demand

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 56.80

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9211530	0.9746430	0.9831460	0.9990840	0.9815960	3.3356E+01	8.6782E-01
α_2	9.13E-04	2.54E-02	1.69E-02	7.88E-02	1.84E-02	8.6782E-01	3.3356E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9212760	0.9648050	0.9694410	0.9924600	0.9654380	6.3075E+01	2.3009E+00
α_2	5.45E-03	3.03E-02	2.57E-02	7.12E-02	3.31E-02	1.9837E+00	6.3392E+01
α_3	8.63E-07	4.85E-03	1.30E-03	2.18E-02	1.44E-03	3.1722E-01	6.5059E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9175380	0.9566550	0.9598800	0.9847510	0.9517160	8.9499E+01	4.0551E+00
α_2	1.02E-02	3.45E-02	3.12E-02	7.00E-02	4.39E-02	3.2281E+00	9.0326E+01
α_3	6.32E-05	6.46E-03	3.44E-03	2.31E-02	4.39E-03	6.0431E-01	9.2950E+01
α_4	1.02E-08	2.38E-03	3.25E-04	1.19E-02	0.00E+00	2.2267E-01	9.3331E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9316380	0.9602190	0.9621700	0.9821240	0.9526190	1.4977E+02	6.2049E+00
α_2	8.67E-03	2.53E-02	2.33E-02	4.88E-02	3.26E-02	3.9475E+00	1.5203E+02
α_3	1.82E-03	1.16E-02	9.60E-03	2.83E-02	1.48E-02	1.8107E+00	1.5416E+02
α_4	1.58E-06	2.40E-03	8.07E-04	1.02E-02	0.00E+00	3.7439E-01	1.5560E+02
α_5	3.82E-21	4.63E-04	2.62E-07	2.68E-03	0.00E+00	7.2277E-02	1.5590E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9358030	0.9613170	0.9629440	0.9812800	0.9551850	1.8088E+02	7.2786E+00
α_2	6.36E-03	1.96E-02	1.79E-02	3.85E-02	2.16E-02	3.6836E+00	1.8447E+02
α_3	3.29E-03	1.37E-02	1.21E-02	3.00E-02	2.16E-02	2.5862E+00	1.8557E+02
α_4	6.64E-05	3.74E-03	2.19E-03	1.27E-02	1.66E-03	7.0332E-01	1.8746E+02
α_5	4.93E-09	1.18E-03	1.60E-04	5.92E-03	0.00E+00	2.2220E-01	1.8794E+02
α_6	7.49E-19	4.42E-04	7.73E-07	2.58E-03	0.00E+00	8.3237E-02	1.8808E+02

Motor Operated Valves

2010

PWR Auxiliary Feedwater Motor-Operated Valves

AFW MOV FAIL TO OPEN/CLOSE SPAR: AFW-MOV-FO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9445200	0.9647700	0.9659230	0.9810880	0.9613410	2.5865E+02	9.4449E+00
α_2	5.54E-03	1.56E-02	1.44E-02	2.97E-02	1.41E-02	4.1841E+00	2.6391E+02
α_3	2.83E-03	1.07E-02	9.54E-03	2.27E-02	1.60E-02	2.8756E+00	2.6522E+02
α_4	7.93E-04	6.01E-03	4.83E-03	1.52E-02	8.02E-03	1.6111E+00	2.6648E+02
α_5	1.43E-05	2.08E-03	1.04E-03	7.69E-03	4.77E-04	5.5877E-01	2.6754E+02
α_6	2.51E-10	6.95E-04	5.93E-05	3.65E-03	0.00E+00	1.8628E-01	2.6791E+02
α_7	0.00E+00	1.08E-04	9.49E-14	4.08E-04	0.00E+00	2.9071E-02	2.6807E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9486030	0.9667310	0.9677140	0.9814950	0.9660060	3.0398E+02	1.0461E+01
α_2	4.71E-03	1.33E-02	1.23E-02	2.54E-02	9.49E-03	4.1822E+00	3.1026E+02
α_3	2.31E-03	8.95E-03	7.93E-03	1.91E-02	1.22E-02	2.8135E+00	3.1163E+02
α_4	1.09E-03	6.24E-03	5.23E-03	1.49E-02	9.25E-03	1.9628E+00	3.1248E+02
α_5	1.45E-04	3.08E-03	2.11E-03	9.31E-03	2.93E-03	9.6713E-01	3.1347E+02
α_6	8.67E-07	1.21E-03	4.11E-04	5.10E-03	1.39E-04	3.7926E-01	3.1406E+02
α_7	5.18E-14	3.91E-04	7.03E-06	2.23E-03	0.00E+00	1.2297E-01	3.1432E+02
α_8	9.70E-43	1.05E-04	1.50E-12	4.45E-04	0.00E+00	3.3124E-02	3.1441E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9815960	0.9654380	0.9517160	0.9526190	0.9551850	0.9613410	0.9660060
α_2	1.84E-02	3.31E-02	4.39E-02	3.26E-02	2.16E-02	1.41E-02	9.49E-03
α_3		1.44E-03	4.39E-03	1.48E-02	2.16E-02	1.60E-02	1.22E-02
α_4			0.00E+00	0.00E+00	1.66E-03	8.02E-03	9.25E-03
α_5				0.00E+00	0.00E+00	4.77E-04	2.93E-03
α_6					0.00E+00	0.00E+00	1.39E-04
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.82E-01	9.65E-01	9.52E-01	9.53E-01	9.55E-01	9.61E-01	9.66E-01
Beta	1.84E-02	3.46E-02	4.83E-02	4.74E-02	4.48E-02	3.87E-02	3.40E-02
Gamma		4.17E-02	9.09E-02	3.12E-01	5.19E-01	6.35E-01	7.21E-01
Delta			0.00E+00	0.00E+00	7.14E-02	3.46E-01	5.03E-01
Epsilon				0.00E+00	0.00E+00	5.61E-02	2.49E-01
Mu					0.00E+00	0.00E+00	4.54E-02
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Motor Operated Valves

2010

PWR Auxiliary Feedwater Motor-Operated Valves

AFW MOV FAIL TO OPEN/CLOSE SPAR: AFW-MOV-FO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	21.31	31.97	42.63	53.28	63.94	74.60	85.25
N ₁	1.8000	1.5500	0.7333	0.3333	0.0000	0.0000	0.0000
N ₂	0.4333	1.1500	2.0000	1.8333	1.4444	1.0963	0.8375
N ₃		0.0500	0.2000	0.8333	1.4444	1.2444	1.0751
N ₄			0.0000	0.0000	0.1111	0.6222	0.8163
N ₅				0.0000	0.0000	0.0370	0.2588
N ₆					0.0000	0.0000	0.0123
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.5.2 AFW MOV FAIL TO OPEN SPAR: AFW-MOV-CC

System : Auxiliary feedwater
Component : Motor Operated Valve
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 28.20

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8944810	0.9696120	0.9828540	0.9996220	0.9803920	2.0246E+01	6.3452E-01
α_2	3.76E-04	3.04E-02	1.71E-02	1.06E-01	1.96E-02	6.3452E-01	2.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9121850	0.9649730	0.9715230	0.9953160	0.9667770	4.4105E+01	1.6009E+00
α_2	2.55E-03	2.81E-02	2.15E-02	7.61E-02	2.99E-02	1.2837E+00	4.4422E+01
α_3	1.24E-06	6.94E-03	1.87E-03	3.11E-02	3.32E-03	3.1722E-01	4.5389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9161740	0.9608340	0.9652860	0.9902550	0.9595960	6.5136E+01	2.6551E+00
α_2	4.34E-03	2.70E-02	2.25E-02	6.50E-02	3.03E-02	1.8281E+00	6.5963E+01
α_3	8.75E-05	8.91E-03	4.76E-03	3.19E-02	1.01E-02	6.0431E-01	6.7187E+01
α_4	1.42E-08	3.28E-03	4.50E-04	1.65E-02	0.00E+00	2.2267E-01	6.7568E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9322830	0.9634590	0.9659250	0.9862100	0.9591840	1.1966E+02	4.5383E+00
α_2	5.11E-03	2.10E-02	1.85E-02	4.56E-02	2.04E-02	2.6142E+00	1.2158E+02
α_3	1.37E-03	1.19E-02	9.40E-03	3.10E-02	2.04E-02	1.4774E+00	1.2272E+02
α_4	1.98E-06	3.01E-03	1.01E-03	1.28E-02	0.00E+00	3.7439E-01	1.2382E+02
α_5	4.80E-21	5.82E-04	3.29E-07	3.37E-03	0.00E+00	7.2277E-02	1.2413E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9372950	0.9649070	0.9669470	0.9855370	0.9657530	1.4514E+02	5.2787E+00
α_2	3.06E-03	1.49E-02	1.28E-02	3.39E-02	0.00E+00	2.2392E+00	1.4818E+02
α_3	2.78E-03	1.42E-02	1.21E-02	3.29E-02	3.42E-02	2.1418E+00	1.4828E+02
α_4	3.52E-05	3.94E-03	2.06E-03	1.42E-02	0.00E+00	5.9222E-01	1.4983E+02
α_5	6.17E-09	1.48E-03	2.00E-04	7.40E-03	0.00E+00	2.2220E-01	1.5020E+02
α_6	9.37E-19	5.53E-04	9.68E-07	3.23E-03	0.00E+00	8.3237E-02	1.5034E+02

Motor Operated Valves

2010

PWR Auxiliary Feedwater Motor-Operated Valves

AFW MOV FAIL TO OPEN SPAR: AFW-MOV-CC

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9451210	0.9668220	0.9682030	0.9838180	0.9705010	2.1695E+02	7.4450E+00
α_2	3.87E-03	1.38E-02	1.23E-02	2.85E-02	0.00E+00	3.0878E+00	2.2131E+02
α_3	2.03E-03	9.94E-03	8.53E-03	2.27E-02	1.77E-02	2.2312E+00	2.2216E+02
α_4	6.39E-04	6.19E-03	4.80E-03	1.65E-02	1.18E-02	1.3889E+00	2.2301E+02
α_5	1.14E-05	2.33E-03	1.10E-03	8.79E-03	0.00E+00	5.2177E-01	2.2387E+02
α_6	2.99E-10	8.30E-04	7.09E-05	4.36E-03	0.00E+00	1.8628E-01	2.2421E+02
α_7	0.00E+00	1.30E-04	1.13E-13	4.88E-04	0.00E+00	2.9071E-02	2.2437E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9485180	0.9680470	0.9692220	0.9835720	0.9740930	2.5633E+02	8.4610E+00
α_2	3.80E-03	1.26E-02	1.14E-02	2.56E-02	0.00E+00	3.3447E+00	2.6145E+02
α_3	1.50E-03	7.92E-03	6.72E-03	1.85E-02	9.33E-03	2.0984E+00	2.6269E+02
α_4	8.23E-04	6.14E-03	4.95E-03	1.55E-02	1.24E-02	1.6265E+00	2.6316E+02
α_5	1.15E-04	3.28E-03	2.14E-03	1.03E-02	4.15E-03	8.6833E-01	2.6392E+02
α_6	7.84E-07	1.39E-03	4.54E-04	5.93E-03	0.00E+00	3.6696E-01	2.6442E+02
α_7	6.15E-14	4.64E-04	8.35E-06	2.64E-03	0.00E+00	1.2297E-01	2.6467E+02
α_8	1.15E-42	1.25E-04	1.78E-12	5.29E-04	0.00E+00	3.3124E-02	2.6476E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9803920	0.9667770	0.9595960	0.9591840	0.9657530	0.9705010	0.9740930
α_2	1.96E-02	2.99E-02	3.03E-02	2.04E-02	0.00E+00	0.00E+00	0.00E+00
α_3		3.32E-03	1.01E-02	2.04E-02	3.42E-02	1.77E-02	9.33E-03
α_4			0.00E+00	0.00E+00	0.00E+00	1.18E-02	1.24E-02
α_5				0.00E+00	0.00E+00	0.00E+00	4.15E-03
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.80E-01	9.67E-01	9.60E-01	9.59E-01	9.66E-01	9.71E-01	9.74E-01
Beta	1.96E-02	3.32E-02	4.04E-02	4.08E-02	3.42E-02	2.95E-02	2.59E-02
Gamma		1.00E-01	2.50E-01	5.00E-01	1.00E+00	1.00E+00	1.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	4.00E-01	6.40E-01
Epsilon				0.00E+00	0.00E+00	0.00E+00	2.50E-01
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	9.40	14.10	18.80	23.50	28.20	32.90	37.60
N₁	0.6000	0.4500	0.2000	0.0000	0.0000	0.0000	0.0000
N₂	0.2000	0.4500	0.6000	0.5000	0.0000	0.0000	0.0000
N₃		0.0500	0.2000	0.5000	1.0000	0.6000	0.3600
N₄			0.0000	0.0000	0.0000	0.4000	0.4800
N₅				0.0000	0.0000	0.0000	0.1600
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.3.5.3 AFW MOV FAIL TO CLOSE SPAR: AFW-MOV-OO

System : Auxiliary feedwater
Component : Motor Operated Valve
Failure Mode : Fail to close (reseat) on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 27.60

Total Number of Common-Cause Failure Events: 2

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9016080	0.9711570	0.9832270	0.9995620	0.9812960	2.2486E+01	6.6782E-01
α_2	4.36E-04	2.88E-02	1.68E-02	9.84E-02	1.87E-02	6.6782E-01	2.2486E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113900	0.9632580	0.9693770	0.9941640	0.9618740	4.7215E+01	1.8009E+00
α_2	3.90E-03	3.13E-02	2.52E-02	7.97E-02	3.81E-02	1.5337E+00	4.7482E+01
α_3	1.91E-07	5.45E-03	1.10E-03	2.59E-02	0.00E+00	2.6722E-01	4.8749E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9088840	0.9547930	0.9589530	0.9864770	0.9416990	6.8749E+01	3.2551E+00
α_2	8.98E-03	3.65E-02	3.23E-02	7.84E-02	5.83E-02	2.6281E+00	6.9376E+01
α_3	6.31E-06	5.62E-03	2.08E-03	2.32E-02	0.00E+00	4.0431E-01	7.1600E+01
α_4	1.33E-08	3.09E-03	4.23E-04	1.55E-02	0.00E+00	2.2267E-01	7.1781E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9279470	0.9597440	0.9620950	0.9834990	0.9436960	1.2409E+02	5.2049E+00
α_2	8.27E-03	2.67E-02	2.43E-02	5.33E-02	4.50E-02	3.4475E+00	1.2585E+02
α_3	9.45E-04	1.01E-02	7.75E-03	2.75E-02	1.13E-02	1.3107E+00	1.2798E+02
α_4	1.90E-06	2.90E-03	9.75E-04	1.23E-02	0.00E+00	3.7439E-01	1.2892E+02
α_5	4.61E-21	5.59E-04	3.16E-07	3.23E-03	0.00E+00	7.2277E-02	1.2922E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9311780	0.9598400	0.9617910	0.9818460	0.9430550	1.5006E+02	6.2786E+00
α_2	7.67E-03	2.36E-02	2.16E-02	4.63E-02	4.11E-02	3.6836E+00	1.5265E+02
α_3	1.31E-03	1.01E-02	8.15E-03	2.58E-02	1.27E-02	1.5862E+00	1.5475E+02
α_4	8.00E-05	4.50E-03	2.64E-03	1.53E-02	3.16E-03	7.0332E-01	1.5564E+02
α_5	5.94E-09	1.42E-03	1.93E-04	7.12E-03	0.00E+00	2.2220E-01	1.5612E+02
α_6	9.01E-19	5.32E-04	9.31E-07	3.11E-03	0.00E+00	8.3237E-02	1.5626E+02

Motor Operated Valves

2010

PWR Auxiliary Feedwater Motor-Operated Valves

AFW MOV FAIL TO CLOSE SPAR: AFW-MOV-OO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9411850	0.9634630	0.9647910	0.9812030	0.9507900	2.2269E+02	8.4449E+00
α_2	6.43E-03	1.81E-02	1.67E-02	3.45E-02	2.70E-02	4.1841E+00	2.2695E+02
α_3	2.05E-03	9.85E-03	8.47E-03	2.23E-02	1.59E-02	2.2756E+00	2.2886E+02
α_4	4.16E-04	5.24E-03	3.90E-03	1.46E-02	5.47E-03	1.2111E+00	2.2992E+02
α_5	1.66E-05	2.42E-03	1.21E-03	8.91E-03	9.10E-04	5.5877E-01	2.3058E+02
α_6	2.91E-10	8.06E-04	6.88E-05	4.23E-03	0.00E+00	1.8628E-01	2.3095E+02
α_7	0.00E+00	1.26E-04	1.10E-13	4.73E-04	0.00E+00	2.9071E-02	2.3111E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9453060	0.9652620	0.9663990	0.9813480	0.9566720	2.6289E+02	9.4610E+00
α_2	5.44E-03	1.54E-02	1.42E-02	2.93E-02	1.81E-02	4.1822E+00	2.6817E+02
α_3	2.03E-03	9.01E-03	7.84E-03	2.00E-02	1.55E-02	2.4535E+00	2.6990E+02
α_4	6.29E-04	5.44E-03	4.29E-03	1.42E-02	7.29E-03	1.4828E+00	2.7087E+02
α_5	8.37E-05	2.96E-03	1.87E-03	9.57E-03	2.14E-03	8.0713E-01	2.7154E+02
α_6	1.00E-06	1.39E-03	4.75E-04	5.89E-03	2.66E-04	3.7926E-01	2.7197E+02
α_7	5.98E-14	4.52E-04	8.12E-06	2.57E-03	0.00E+00	1.2297E-01	2.7223E+02
α_8	1.12E-42	1.22E-04	1.73E-12	5.14E-04	0.00E+00	3.3124E-02	2.7232E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9812960	0.9618740	0.9416990	0.9436960	0.9430550	0.9507900	0.9566720
α_2	1.87E-02	3.81E-02	5.83E-02	4.50E-02	4.11E-02	2.70E-02	1.81E-02
α_3		0.00E+00	0.00E+00	1.13E-02	1.27E-02	1.59E-02	1.55E-02
α_4			0.00E+00	0.00E+00	3.16E-03	5.47E-03	7.29E-03
α_5				0.00E+00	0.00E+00	9.10E-04	2.14E-03
α_6					0.00E+00	0.00E+00	2.66E-04
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.81E-01	9.62E-01	9.42E-01	9.44E-01	9.43E-01	9.51E-01	9.57E-01
Beta	1.87E-02	3.81E-02	5.83E-02	5.63E-02	5.69E-02	4.92E-02	4.33E-02
Gamma		0.00E+00	0.00E+00	2.00E-01	2.78E-01	4.52E-01	5.81E-01
Delta			0.00E+00	0.00E+00	2.00E-01	2.87E-01	3.85E-01
Epsilon				0.00E+00	0.00E+00	1.43E-01	2.48E-01
Mu					0.00E+00	0.00E+00	1.11E-01
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	11.04	16.56	22.08	27.60	33.12	38.64	44.16
N ₁	1.2000	1.1000	0.5333	0.3333	0.0000	0.0000	0.0000
N ₂	0.2333	0.7000	1.4000	1.3333	1.4444	1.0963	0.8375
N ₃		0.0000	0.0000	0.3333	0.4444	0.6444	0.7151
N ₄			0.0000	0.0000	0.1111	0.2222	0.3363
N ₅				0.0000	0.0000	0.0370	0.0988
N ₆					0.0000	0.0000	0.0123
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.6 PWR High Pressure Safety Injection Motor-Operated Valves

1.3.6.1 HIGH PRESSURE INJECTION MOV FAIL TO OPEN/CLOSE

System :	Chemical and volume control
Component :	High pressure injection
Failure Mode :	Motor Operated Valve
	Fail to close (reseat) on demand
	Fail to Open/Close Mode Unspecified (demand based)
	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 60.60

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9754510	0.9939040	0.9975550	0.9999880	1.0000000	7.0846E+01	4.3452E-01
α_2	1.09E-05	6.10E-03	2.44E-03	2.46E-02	0.00E+00	4.3452E-01	7.0846E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9652740	0.9879360	0.9912710	0.9992110	1.0000000	9.0155E+01	1.1009E+00
α_2	2.87E-04	9.14E-03	5.89E-03	2.91E-02	0.00E+00	8.3366E-01	9.0422E+01
α_3	1.02E-07	2.93E-03	5.87E-04	1.39E-02	0.00E+00	2.6722E-01	9.0989E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9588140	0.9829170	0.9857860	0.9972180	1.0000000	1.0674E+02	1.8551E+00
α_2	9.29E-04	1.13E-02	8.48E-03	3.14E-02	0.00E+00	1.2281E+00	1.0737E+02
α_3	4.17E-06	3.72E-03	1.38E-03	1.54E-02	0.00E+00	4.0431E-01	1.0819E+02
α_4	8.81E-09	2.05E-03	2.80E-04	1.03E-02	0.00E+00	2.2267E-01	1.0837E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9561320	0.9779270	0.9798830	0.9930350	1.0000000	1.5676E+02	3.5382E+00
α_2	2.53E-03	1.32E-02	1.12E-02	3.06E-02	0.00E+00	2.1142E+00	1.5818E+02
α_3	2.97E-04	6.10E-03	4.20E-03	1.84E-02	0.00E+00	9.7738E-01	1.5932E+02
α_4	1.53E-06	2.34E-03	7.85E-04	9.92E-03	0.00E+00	3.7439E-01	1.5992E+02
α_5	3.72E-21	4.51E-04	2.55E-07	2.61E-03	0.00E+00	7.2277E-02	1.6023E+02

PWR High Pressure Safety Injection Motor-Operated Valves

HIGH PRESSURE INJECTION MOV FAIL TO OPEN/CLOSE

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9555360	0.9764670	0.9781970	0.9915010	1.0000000	1.7754E+02	4.2787E+00
α_2	2.52E-03	1.23E-02	1.06E-02	2.81E-02	0.00E+00	2.2392E+00	1.7958E+02
α_3	4.41E-04	6.28E-03	4.59E-03	1.79E-02	0.00E+00	1.1418E+00	1.8068E+02
α_4	2.91E-05	3.26E-03	1.70E-03	1.18E-02	0.00E+00	5.9222E-01	1.8123E+02
α_5	5.10E-09	1.22E-03	1.66E-04	6.12E-03	0.00E+00	2.2220E-01	1.8160E+02
α_6	7.75E-19	4.58E-04	8.00E-07	2.67E-03	0.00E+00	8.3237E-02	1.8174E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9560850	0.9743320	0.9755850	0.9883120	1.0000000	2.4465E+02	6.4450E+00
α_2	3.46E-03	1.23E-02	1.10E-02	2.55E-02	0.00E+00	3.0878E+00	2.4801E+02
α_3	8.75E-04	6.50E-03	5.24E-03	1.64E-02	0.00E+00	1.6312E+00	2.4946E+02
α_4	1.97E-04	3.94E-03	2.72E-03	1.18E-02	0.00E+00	9.8887E-01	2.5011E+02
α_5	1.02E-05	2.08E-03	9.83E-04	7.85E-03	0.00E+00	5.2177E-01	2.5057E+02
α_6	2.68E-10	7.42E-04	6.33E-05	3.89E-03	0.00E+00	1.8628E-01	2.5091E+02
α_7	0.00E+00	1.16E-04	1.01E-13	4.36E-04	0.00E+00	2.9071E-02	2.5107E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9569050	0.9739850	0.9750810	0.9873310	1.0000000	2.7933E+02	7.4610E+00
α_2	3.50E-03	1.17E-02	1.05E-02	2.36E-02	0.00E+00	3.3447E+00	2.8345E+02
α_3	8.96E-04	6.06E-03	4.96E-03	1.50E-02	0.00E+00	1.7384E+00	2.8505E+02
α_4	2.83E-04	4.00E-03	2.92E-03	1.14E-02	0.00E+00	1.1465E+00	2.8564E+02
α_5	4.49E-05	2.47E-03	1.45E-03	8.36E-03	0.00E+00	7.0833E-01	2.8608E+02
α_6	7.24E-07	1.28E-03	4.19E-04	5.47E-03	0.00E+00	3.6696E-01	2.8642E+02
α_7	5.68E-14	4.29E-04	7.71E-06	2.44E-03	0.00E+00	1.2297E-01	2.8667E+02
α_8	1.06E-42	1.15E-04	1.65E-12	4.88E-04	0.00E+00	3.3124E-02	2.8676E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

PWR High Pressure Safety Injection Motor-Operated Valves

HIGH PRESSURE INJECTION MOV FAIL TO OPEN/CLOSE

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	60.60	60.60	60.60	60.60	60.60	60.60	60.60
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.6.2 HIGH PRESSURE INJECTION MOTOR OPERATED VALVE FAIL TO OPEN

System : Chemical and volume control
High pressure injection

Component : Motor Operated Valve
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 29.60

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9566310	0.9892130	0.9956470	0.9999790	1.0000000	3.9846E+01	4.3452E-01
α_2	1.94E-05	1.08E-02	4.35E-03	4.34E-02	0.00E+00	4.3452E-01	3.9846E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9475700	0.9817300	0.9867280	0.9988050	1.0000000	5.9155E+01	1.1009E+00
α_2	4.37E-04	1.38E-02	8.95E-03	4.39E-02	0.00E+00	8.3366E-01	5.9422E+01
α_3	1.55E-07	4.43E-03	8.92E-04	2.10E-02	0.00E+00	2.6722E-01	5.9989E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9425380	0.9760920	0.9800560	0.9960870	1.0000000	7.5736E+01	1.8551E+00
α_2	1.31E-03	1.58E-02	1.19E-02	4.38E-02	0.00E+00	1.2281E+00	7.6363E+01
α_3	5.86E-06	5.21E-03	1.93E-03	2.15E-02	0.00E+00	4.0431E-01	7.7187E+01
α_4	1.24E-08	2.87E-03	3.92E-04	1.44E-02	0.00E+00	2.2267E-01	7.7368E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9457150	0.9726350	0.9750400	0.9913390	1.0000000	1.2576E+02	3.5382E+00
α_2	3.14E-03	1.64E-02	1.39E-02	3.78E-02	0.00E+00	2.1142E+00	1.2718E+02
α_3	3.69E-04	7.56E-03	5.22E-03	2.27E-02	0.00E+00	9.7738E-01	1.2832E+02
α_4	1.90E-06	2.90E-03	9.75E-04	1.23E-02	0.00E+00	3.7439E-01	1.2892E+02
α_5	4.61E-21	5.59E-04	3.16E-07	3.23E-03	0.00E+00	7.2277E-02	1.2923E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9464910	0.9716300	0.9736940	0.9897260	1.0000000	1.4654E+02	4.2787E+00
α_2	3.05E-03	1.48E-02	1.28E-02	3.38E-02	0.00E+00	2.2392E+00	1.4858E+02
α_3	5.33E-04	7.57E-03	5.53E-03	2.16E-02	0.00E+00	1.1418E+00	1.4968E+02
α_4	3.51E-05	3.93E-03	2.06E-03	1.42E-02	0.00E+00	5.9222E-01	1.5023E+02
α_5	6.16E-09	1.47E-03	2.00E-04	7.38E-03	0.00E+00	2.2220E-01	1.5060E+02
α_6	9.35E-19	5.52E-04	9.65E-07	3.22E-03	0.00E+00	8.3237E-02	1.5074E+02

PWR High Pressure Safety Injection Motor-Operated Valves

HIGH PRESSURE INJECTION MOTOR OPERATED VALVE FAIL TO OPEN

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9499560	0.9707170	0.9721300	0.9866470	1.0000000	2.1365E+02	6.4450E+00
α_2	3.95E-03	1.40E-02	1.26E-02	2.90E-02	0.00E+00	3.0878E+00	2.1701E+02
α_3	9.98E-04	7.41E-03	5.98E-03	1.87E-02	0.00E+00	1.6312E+00	2.1846E+02
α_4	2.25E-04	4.49E-03	3.11E-03	1.35E-02	0.00E+00	9.8887E-01	2.1911E+02
α_5	1.17E-05	2.37E-03	1.12E-03	8.96E-03	0.00E+00	5.2177E-01	2.1957E+02
α_6	3.05E-10	8.46E-04	7.22E-05	4.44E-03	0.00E+00	1.8628E-01	2.1991E+02
α_7	0.00E+00	1.32E-04	1.16E-13	4.97E-04	0.00E+00	2.9071E-02	2.2007E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9517180	0.9708320	0.9720490	0.9857800	1.0000000	2.4833E+02	7.4610E+00
α_2	3.93E-03	1.31E-02	1.18E-02	2.65E-02	0.00E+00	3.3447E+00	2.5245E+02
α_3	1.01E-03	6.80E-03	5.56E-03	1.68E-02	0.00E+00	1.7384E+00	2.5405E+02
α_4	3.17E-04	4.48E-03	3.28E-03	1.28E-02	0.00E+00	1.1465E+00	2.5464E+02
α_5	5.04E-05	2.77E-03	1.63E-03	9.37E-03	0.00E+00	7.0833E-01	2.5508E+02
α_6	8.12E-07	1.43E-03	4.70E-04	6.14E-03	0.00E+00	3.6696E-01	2.5542E+02
α_7	6.37E-14	4.81E-04	8.64E-06	2.74E-03	0.00E+00	1.2297E-01	2.5567E+02
α_8	1.19E-42	1.29E-04	1.84E-12	5.47E-04	0.00E+00	3.3124E-02	2.5576E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

HIGH PRESSURE INJECTION MOTOR OPERATED VALVE FAIL TO OPEN

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	29.60	29.60	29.60	29.60	29.60	29.60	29.60
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.3.6.3 HIGH PRESSURE INJECTION MOTOR OPERATED VALVE FAIL TO CLOSE

System : Chemical and volume control
High pressure injection

Component : Motor Operated Valve
Failure Mode : Fail to close (reseat) on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 27.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9536530	0.9884680	0.9953420	0.9999770	1.0000000	3.7246E+01	4.3452E-01
α_2	2.08E-05	1.15E-02	4.66E-03	4.63E-02	0.00E+00	4.3452E-01	3.7246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9452290	0.9809060	0.9861230	0.9987500	1.0000000	5.6555E+01	1.1009E+00
α_2	4.57E-04	1.45E-02	9.36E-03	4.59E-02	0.00E+00	8.3366E-01	5.6822E+01
α_3	1.62E-07	4.63E-03	9.32E-04	2.20E-02	0.00E+00	2.6722E-01	5.7389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9405680	0.9752630	0.9793590	0.9959440	1.0000000	7.3136E+01	1.8551E+00
α_2	1.35E-03	1.64E-02	1.23E-02	4.53E-02	0.00E+00	1.2281E+00	7.3763E+01
α_3	6.06E-06	5.39E-03	2.00E-03	2.23E-02	0.00E+00	4.0431E-01	7.4587E+01
α_4	1.28E-08	2.97E-03	4.06E-04	1.49E-02	0.00E+00	2.2267E-01	7.4768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9446120	0.9720730	0.9745250	0.9911590	1.0000000	1.2316E+02	3.5382E+00
α_2	3.21E-03	1.67E-02	1.42E-02	3.86E-02	0.00E+00	2.1142E+00	1.2458E+02
α_3	3.76E-04	7.71E-03	5.33E-03	2.32E-02	0.00E+00	9.7738E-01	1.2572E+02
α_4	1.94E-06	2.95E-03	9.95E-04	1.25E-02	0.00E+00	3.7439E-01	1.2632E+02
α_5	4.71E-21	5.70E-04	3.22E-07	3.30E-03	0.00E+00	7.2277E-02	1.2663E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9455620	0.9711330	0.9732300	0.9895430	1.0000000	1.4394E+02	4.2787E+00
α_2	3.10E-03	1.51E-02	1.30E-02	3.44E-02	0.00E+00	2.2392E+00	1.4598E+02
α_3	5.42E-04	7.70E-03	5.63E-03	2.19E-02	0.00E+00	1.1418E+00	1.4708E+02
α_4	3.57E-05	4.00E-03	2.09E-03	1.44E-02	0.00E+00	5.9222E-01	1.4763E+02
α_5	6.26E-09	1.50E-03	2.03E-04	7.51E-03	0.00E+00	2.2220E-01	1.4800E+02
α_6	9.51E-19	5.62E-04	9.82E-07	3.28E-03	0.00E+00	8.3237E-02	1.4814E+02

PWR High Pressure Safety Injection Motor-Operated Valves

HIGH PRESSURE INJECTION MOTOR OPERATED VALVE FAIL TO CLOSE

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9493630	0.9703670	0.9717960	0.9864860	1.0000000	2.1105E+02	6.4450E+00
α_2	4.00E-03	1.42E-02	1.27E-02	2.94E-02	0.00E+00	3.0878E+00	2.1441E+02
α_3	1.01E-03	7.50E-03	6.05E-03	1.89E-02	0.00E+00	1.6312E+00	2.1586E+02
α_4	2.28E-04	4.55E-03	3.15E-03	1.36E-02	0.00E+00	9.8887E-01	2.1651E+02
α_5	1.18E-05	2.40E-03	1.14E-03	9.07E-03	0.00E+00	5.2177E-01	2.1697E+02
α_6	3.09E-10	8.56E-04	7.31E-05	4.50E-03	0.00E+00	1.8628E-01	2.1731E+02
α_7	0.00E+00	1.34E-04	1.17E-13	5.03E-04	0.00E+00	2.9071E-02	2.1747E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9512310	0.9705320	0.9717610	0.9856330	1.0000000	2.4573E+02	7.4610E+00
α_2	3.97E-03	1.32E-02	1.20E-02	2.68E-02	0.00E+00	3.3447E+00	2.4985E+02
α_3	1.02E-03	6.87E-03	5.62E-03	1.70E-02	0.00E+00	1.7384E+00	2.5145E+02
α_4	3.20E-04	4.53E-03	3.31E-03	1.29E-02	0.00E+00	1.1465E+00	2.5204E+02
α_5	5.09E-05	2.80E-03	1.64E-03	9.47E-03	0.00E+00	7.0833E-01	2.5248E+02
α_6	8.20E-07	1.45E-03	4.74E-04	6.20E-03	0.00E+00	3.6696E-01	2.5282E+02
α_7	6.43E-14	4.86E-04	8.73E-06	2.76E-03	0.00E+00	1.2297E-01	2.5307E+02
α_8	1.21E-42	1.31E-04	1.86E-12	5.53E-04	0.00E+00	3.3124E-02	2.5316E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	27.00	27.00	27.00	27.00	27.00	27.00	27.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.7 PWR Residual Heat Removal Motor-Operated Valves

1.3.7.1 PWR RHR MOV FAIL TO OPEN/CLOSE

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand Fail to Open/Close Mode Unspecified (demand based) Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 81.80

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9167640	0.9790650	0.9912550	0.9999540	0.9992070	2.0709E+01	4.4282E-01
α_2	4.29E-05	2.09E-02	8.74E-03	8.32E-02	7.93E-04	4.4282E-01	2.0709E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9310450	0.9757070	0.9821540	0.9983190	0.9984070	4.5220E+01	1.1259E+00
α_2	6.42E-04	1.85E-02	1.22E-02	5.80E-02	1.59E-03	8.5866E-01	4.5487E+01
α_3	2.02E-07	5.77E-03	1.16E-03	2.73E-02	0.00E+00	2.6722E-01	4.6079E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9342130	0.9723460	0.9767860	0.9952940	0.9976080	6.6986E+01	1.9051E+00
α_2	1.66E-03	1.86E-02	1.41E-02	5.06E-02	2.39E-03	1.2781E+00	6.7613E+01
α_3	6.60E-06	5.87E-03	2.17E-03	2.42E-02	0.00E+00	4.0431E-01	6.8487E+01
α_4	1.39E-08	3.23E-03	4.42E-04	1.62E-02	0.00E+00	2.2267E-01	6.8668E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9432790	0.9712120	0.9736770	0.9907210	0.9968090	1.2218E+02	3.6215E+00
α_2	3.52E-03	1.75E-02	1.50E-02	3.99E-02	3.19E-03	2.1975E+00	1.2360E+02
α_3	3.79E-04	7.77E-03	5.36E-03	2.34E-02	0.00E+00	9.7738E-01	1.2482E+02
α_4	1.96E-06	2.98E-03	1.00E-03	1.26E-02	0.00E+00	3.7439E-01	1.2543E+02
α_5	4.74E-21	5.75E-04	3.25E-07	3.32E-03	0.00E+00	7.2277E-02	1.2573E+02

Motor Operated Valves

2010

PWR Residual Heat Removal Motor-Operated Valves

PWR RHR MOV FAIL TO OPEN/CLOSE

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9459470	0.9711260	0.9731650	0.9893440	0.9960060	1.4811E+02	4.4037E+00
α_2	3.38E-03	1.55E-02	1.34E-02	3.47E-02	3.99E-03	2.3642E+00	1.5015E+02
α_3	5.27E-04	7.49E-03	5.47E-03	2.13E-02	0.00E+00	1.1418E+00	1.5137E+02
α_4	3.47E-05	3.88E-03	2.03E-03	1.40E-02	0.00E+00	5.9222E-01	1.5192E+02
α_5	6.09E-09	1.46E-03	1.97E-04	7.30E-03	0.00E+00	2.2220E-01	1.5229E+02
α_6	9.24E-19	5.46E-04	9.54E-07	3.18E-03	0.00E+00	8.3237E-02	1.5243E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9504540	0.9708360	0.9722060	0.9865310	0.9952040	2.2037E+02	6.6200E+00
α_2	4.24E-03	1.44E-02	1.30E-02	2.93E-02	4.80E-03	3.2628E+00	2.2373E+02
α_3	9.68E-04	7.19E-03	5.80E-03	1.81E-02	0.00E+00	1.6312E+00	2.2536E+02
α_4	2.18E-04	4.36E-03	3.01E-03	1.31E-02	0.00E+00	9.8887E-01	2.2600E+02
α_5	1.13E-05	2.30E-03	1.09E-03	8.69E-03	0.00E+00	5.2177E-01	2.2647E+02
α_6	2.96E-10	8.21E-04	7.00E-05	4.31E-03	0.00E+00	1.8628E-01	2.2680E+02
α_7	0.00E+00	1.28E-04	1.12E-13	4.82E-04	0.00E+00	2.9071E-02	2.2696E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9527560	0.9712740	0.9724380	0.9858120	0.9944010	2.6016E+02	7.6943E+00
α_2	4.23E-03	1.34E-02	1.22E-02	2.66E-02	5.60E-03	3.5780E+00	2.6428E+02
α_3	9.60E-04	6.49E-03	5.31E-03	1.61E-02	0.00E+00	1.7384E+00	2.6612E+02
α_4	3.03E-04	4.28E-03	3.13E-03	1.22E-02	0.00E+00	1.1465E+00	2.6671E+02
α_5	4.81E-05	2.64E-03	1.55E-03	8.95E-03	0.00E+00	7.0833E-01	2.6715E+02
α_6	7.75E-07	1.37E-03	4.48E-04	5.86E-03	0.00E+00	3.6696E-01	2.6749E+02
α_7	6.08E-14	4.59E-04	8.25E-06	2.61E-03	0.00E+00	1.2297E-01	2.6773E+02
α_8	1.14E-42	1.24E-04	1.76E-12	5.23E-04	0.00E+00	3.3124E-02	2.6782E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9992070	0.9984070	0.9976080	0.9968090	0.9960060	0.9952040	0.9944010
α_2	7.93E-04	1.59E-03	2.39E-03	3.19E-03	3.99E-03	4.80E-03	5.60E-03
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

Motor Operated Valves

2010

PWR Residual Heat Removal Motor-Operated Valves

PWR RHR MOV FAIL TO OPEN/CLOSE

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.99E-01	9.98E-01	9.98E-01	9.97E-01	9.96E-01	9.95E-01	9.94E-01
Beta	7.93E-04	1.59E-03	2.39E-03	3.19E-03	3.99E-03	4.80E-03	5.60E-03
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	10.23	15.34	20.45	25.56	30.67	35.79	40.90
N ₁	0.2333	0.3250	0.4000	0.4583	0.5000	0.5250	0.5333
N ₂	0.0083	0.0250	0.0500	0.0833	0.1250	0.1750	0.2333
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.7.2 PWR RHR MOV FAIL TO OPEN

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Operated Valve
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 54.10

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9006160	0.9749560	0.9894760	0.9999440	0.9988150	1.7239E+01	4.4282E-01
α_2	5.17E-05	2.50E-02	1.05E-02	9.94E-02	1.19E-03	4.4282E-01	1.7239E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9224590	0.9726370	0.9798620	0.9981020	0.9976170	4.0020E+01	1.1259E+00
α_2	7.25E-04	2.09E-02	1.38E-02	6.53E-02	2.38E-03	8.5866E-01	4.0287E+01
α_3	2.28E-07	6.49E-03	1.31E-03	3.08E-02	0.00E+00	2.6722E-01	4.0879E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9269650	0.9692590	0.9741650	0.9947630	0.9964230	6.0066E+01	1.9051E+00
α_2	1.85E-03	2.06E-02	1.57E-02	5.61E-02	3.58E-03	1.2781E+00	6.0693E+01
α_3	7.35E-06	6.52E-03	2.42E-03	2.69E-02	0.00E+00	4.0431E-01	6.1567E+01
α_4	1.55E-08	3.59E-03	4.92E-04	1.80E-02	0.00E+00	2.2267E-01	6.1748E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9391390	0.9690870	0.9717170	0.9900250	0.9952270	1.1353E+02	3.6215E+00
α_2	3.78E-03	1.88E-02	1.61E-02	4.29E-02	4.77E-03	2.1975E+00	1.1495E+02
α_3	4.07E-04	8.34E-03	5.76E-03	2.51E-02	0.00E+00	9.7738E-01	1.1617E+02
α_4	2.10E-06	3.20E-03	1.08E-03	1.36E-02	0.00E+00	3.7439E-01	1.1678E+02
α_5	5.09E-21	6.17E-04	3.49E-07	3.57E-03	0.00E+00	7.2277E-02	1.1708E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9420420	0.9690180	0.9711910	0.9885560	0.9940230	1.3773E+02	4.4037E+00
α_2	3.63E-03	1.66E-02	1.44E-02	3.72E-02	5.98E-03	2.3642E+00	1.3977E+02
α_3	5.65E-04	8.03E-03	5.87E-03	2.29E-02	0.00E+00	1.1418E+00	1.4099E+02
α_4	3.72E-05	4.17E-03	2.18E-03	1.50E-02	0.00E+00	5.9222E-01	1.4154E+02
α_5	6.53E-09	1.56E-03	2.12E-04	7.83E-03	0.00E+00	2.2220E-01	1.4191E+02
α_6	9.92E-19	5.86E-04	1.02E-06	3.42E-03	0.00E+00	8.3237E-02	1.4205E+02

PWR Residual Heat Removal Motor-Operated Valves

PWR RHR MOV FAIL TO OPEN

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9476820	0.9691890	0.9706330	0.9857620	0.9928190	2.0824E+02	6.6200E+00
α_2	4.48E-03	1.52E-02	1.37E-02	3.09E-02	7.18E-03	3.2628E+00	2.1160E+02
α_3	1.02E-03	7.59E-03	6.13E-03	1.92E-02	0.00E+00	1.6312E+00	2.1323E+02
α_4	2.31E-04	4.60E-03	3.19E-03	1.38E-02	0.00E+00	9.8887E-01	2.1387E+02
α_5	1.19E-05	2.43E-03	1.15E-03	9.18E-03	0.00E+00	5.2177E-01	2.1434E+02
α_6	3.13E-10	8.67E-04	7.40E-05	4.55E-03	0.00E+00	1.8628E-01	2.1467E+02
α_7	0.00E+00	1.35E-04	1.18E-13	5.09E-04	0.00E+00	2.9071E-02	2.1483E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9502050	0.9697080	0.9709320	0.9850290	0.9916130	2.4631E+02	7.6943E+00
α_2	4.47E-03	1.41E-02	1.28E-02	2.80E-02	8.39E-03	3.5780E+00	2.5043E+02
α_3	1.01E-03	6.84E-03	5.60E-03	1.69E-02	0.00E+00	1.7384E+00	2.5227E+02
α_4	3.19E-04	4.51E-03	3.30E-03	1.29E-02	0.00E+00	1.1465E+00	2.5286E+02
α_5	5.08E-05	2.79E-03	1.64E-03	9.44E-03	0.00E+00	7.0833E-01	2.5330E+02
α_6	8.17E-07	1.44E-03	4.73E-04	6.18E-03	0.00E+00	3.6696E-01	2.5364E+02
α_7	6.41E-14	4.84E-04	8.71E-06	2.76E-03	0.00E+00	1.2297E-01	2.5388E+02
α_8	1.20E-42	1.30E-04	1.86E-12	5.51E-04	0.00E+00	3.3124E-02	2.5397E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9988150	0.9976170	0.9964230	0.9952270	0.9940230	0.9928190	0.9916130
α_2	1.19E-03	2.38E-03	3.58E-03	4.77E-03	5.98E-03	7.18E-03	8.39E-03
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.99E-01	9.98E-01	9.96E-01	9.95E-01	9.94E-01	9.93E-01	9.92E-01
Beta	1.19E-03	2.38E-03	3.58E-03	4.77E-03	5.98E-03	7.18E-03	8.39E-03
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	6.76	10.14	13.53	16.91	20.29	23.67	27.05
N ₁	0.2333	0.3250	0.4000	0.4583	0.5000	0.5250	0.5333
N ₂	0.0083	0.0250	0.0500	0.0833	0.1250	0.1750	0.2333
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.7.3 PWR RHR MOV FAIL TO CLOSE

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 25.70

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9520050	0.9880560	0.9951740	0.9999760	1.0000000	3.5946E+01	4.3452E-01
α_2	2.15E-05	1.19E-02	4.83E-03	4.80E-02	0.00E+00	4.3452E-01	3.5946E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9439790	0.9804660	0.9857990	0.9987200	1.0000000	5.5255E+01	1.1009E+00
α_2	4.67E-04	1.48E-02	9.57E-03	4.69E-02	0.00E+00	8.3366E-01	5.5522E+01
α_3	1.66E-07	4.74E-03	9.54E-04	2.25E-02	0.00E+00	2.6722E-01	5.6089E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9395320	0.9748260	0.9789910	0.9958710	1.0000000	7.1836E+01	1.8551E+00
α_2	1.38E-03	1.67E-02	1.25E-02	4.61E-02	0.00E+00	1.2281E+00	7.2463E+01
α_3	6.17E-06	5.49E-03	2.03E-03	2.27E-02	0.00E+00	4.0431E-01	7.3287E+01
α_4	1.30E-08	3.02E-03	4.13E-04	1.51E-02	0.00E+00	2.2267E-01	7.3468E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9440440	0.9717840	0.9742590	0.9910660	1.0000000	1.2186E+02	3.5382E+00
α_2	3.24E-03	1.69E-02	1.44E-02	3.90E-02	0.00E+00	2.1142E+00	1.2328E+02
α_3	3.80E-04	7.79E-03	5.38E-03	2.34E-02	0.00E+00	9.7738E-01	1.2442E+02
α_4	1.96E-06	2.99E-03	1.00E-03	1.27E-02	0.00E+00	3.7439E-01	1.2502E+02
α_5	4.76E-21	5.76E-04	3.26E-07	3.34E-03	0.00E+00	7.2277E-02	1.2533E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9450850	0.9708770	0.9729920	0.9894500	1.0000000	1.4264E+02	4.2787E+00
α_2	3.13E-03	1.52E-02	1.31E-02	3.47E-02	0.00E+00	2.2392E+00	1.4468E+02
α_3	5.47E-04	7.77E-03	5.68E-03	2.21E-02	0.00E+00	1.1418E+00	1.4578E+02
α_4	3.60E-05	4.03E-03	2.11E-03	1.45E-02	0.00E+00	5.9222E-01	1.4633E+02
α_5	6.32E-09	1.51E-03	2.05E-04	7.58E-03	0.00E+00	2.2220E-01	1.4670E+02
α_6	9.59E-19	5.67E-04	9.91E-07	3.31E-03	0.00E+00	8.3237E-02	1.4684E+02

Motor Operated Valves
 PWR Residual Heat Removal Motor-Operated Valves
 PWR RHR MOV FAIL TO CLOSE
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9490610	0.9701890	0.9716260	0.9864030	1.0000000	2.0975E+02	6.4450E+00
α_2	4.02E-03	1.43E-02	1.28E-02	2.96E-02	0.00E+00	3.0878E+00	2.1311E+02
α_3	1.02E-03	7.55E-03	6.09E-03	1.90E-02	0.00E+00	1.6312E+00	2.1456E+02
α_4	2.29E-04	4.57E-03	3.17E-03	1.37E-02	0.00E+00	9.8887E-01	2.1521E+02
α_5	1.19E-05	2.41E-03	1.14E-03	9.12E-03	0.00E+00	5.2177E-01	2.1567E+02
α_6	3.11E-10	8.62E-04	7.36E-05	4.52E-03	0.00E+00	1.8628E-01	2.1601E+02
α_7	0.00E+00	1.34E-04	1.18E-13	5.06E-04	0.00E+00	2.9071E-02	2.1617E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9509820	0.9703800	0.9716150	0.9855530	1.0000000	2.4443E+02	7.4610E+00
α_2	3.99E-03	1.33E-02	1.20E-02	2.69E-02	0.00E+00	3.3447E+00	2.4855E+02
α_3	1.02E-03	6.90E-03	5.65E-03	1.71E-02	0.00E+00	1.7384E+00	2.5015E+02
α_4	3.22E-04	4.55E-03	3.33E-03	1.30E-02	0.00E+00	1.1465E+00	2.5074E+02
α_5	5.12E-05	2.81E-03	1.65E-03	9.52E-03	0.00E+00	7.0833E-01	2.5118E+02
α_6	8.24E-07	1.46E-03	4.77E-04	6.23E-03	0.00E+00	3.6696E-01	2.5152E+02
α_7	6.46E-14	4.88E-04	8.78E-06	2.78E-03	0.00E+00	1.2297E-01	2.5177E+02
α_8	1.21E-42	1.32E-04	1.87E-12	5.56E-04	0.00E+00	3.3124E-02	2.5186E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	25.70	25.70	25.70	25.70	25.70	25.70	25.70
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.3.8 BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Motor-Operated Valves

1.3.8.1 COMBINED HPCI/RCIC MOTOR OPERATED VALVE FAIL TO OPEN/CLOSE

System :	High pressure coolant injection Reactor core isolation
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand Fail to Open/Close Mode Unspecified (demand based)
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 71.90

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9529140	0.9877530	0.9944270	0.9999520	0.9980650	3.9642E+01	4.9152E-01
α_2	4.48E-05	1.22E-02	5.58E-03	4.71E-02	1.94E-03	4.9152E-01	3.9642E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9538960	0.9831950	0.9872700	0.9985460	0.9964760	7.3501E+01	1.2563E+00
α_2	6.50E-04	1.31E-02	9.11E-03	3.93E-02	3.35E-03	9.8126E-01	7.3776E+01
α_3	1.72E-07	3.68E-03	7.78E-04	1.73E-02	1.77E-04	2.7502E-01	7.4482E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9538620	0.9799650	0.9828840	0.9960920	0.9951860	1.0456E+02	2.1377E+00
α_2	1.62E-03	1.39E-02	1.10E-02	3.61E-02	4.33E-03	1.4825E+00	1.0522E+02
α_3	6.89E-06	4.04E-03	1.60E-03	1.63E-02	4.63E-04	4.3151E-01	1.0627E+02
α_4	9.53E-09	2.10E-03	2.89E-04	1.05E-02	1.70E-05	2.2367E-01	1.0647E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9559310	0.9771560	0.9789690	0.9921840	0.9943590	1.6903E+02	3.9517E+00
α_2	3.23E-03	1.42E-02	1.24E-02	3.14E-02	4.69E-03	2.4579E+00	1.7052E+02
α_3	3.43E-04	6.02E-03	4.26E-03	1.77E-02	8.75E-04	1.0415E+00	1.7194E+02
α_4	1.60E-06	2.20E-03	7.51E-04	9.28E-03	7.37E-05	3.7979E-01	1.7260E+02
α_5	3.86E-21	4.19E-04	2.42E-07	2.42E-03	2.73E-06	7.2477E-02	1.7291E+02

BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Motor-Operated Valves

COMBINED HPCI/RCIC MOTOR OPERATED VALVE FAIL TO OPEN/CLOSE

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9576620	0.9769000	0.9784080	0.9910010	0.9937330	2.0422E+02	4.8291E+00
α_2	3.14E-03	1.27E-02	1.12E-02	2.75E-02	4.84E-03	2.6645E+00	2.0638E+02
α_3	5.07E-04	5.98E-03	4.50E-03	1.65E-02	1.24E-03	1.2506E+00	2.0780E+02
α_4	2.89E-05	2.91E-03	1.55E-03	1.04E-02	1.73E-04	6.0742E-01	2.0844E+02
α_5	4.74E-09	1.07E-03	1.46E-04	5.34E-03	1.25E-05	2.2330E-01	2.0883E+02
α_6	6.74E-19	3.98E-04	6.96E-07	2.32E-03	0.00E+00	8.3237E-02	2.0897E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9980650	0.9964760	0.9951860	0.9943590	0.9937330
α_2	1.94E-03	3.35E-03	4.33E-03	4.69E-03	4.84E-03
α_3		1.77E-04	4.63E-04	8.75E-04	1.24E-03
α_4			1.70E-05	7.37E-05	1.73E-04
α_5				2.73E-06	1.25E-05
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.98E-01	9.96E-01	9.95E-01	9.94E-01	9.94E-01
Beta	1.94E-03	3.52E-03	4.81E-03	5.64E-03	6.27E-03
Gamma		5.02E-02	9.98E-02	1.69E-01	2.27E-01
Delta			3.55E-02	8.03E-02	1.30E-01
Epsilon				3.57E-02	6.75E-02
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	28.76	43.14	57.52	71.90	86.28
N ₁	0.6360	0.8064	0.9056	0.9685	0.9977
N ₂	0.0570	0.1476	0.2544	0.3437	0.4253
N ₃		0.0078	0.0272	0.0641	0.1088
N ₄			0.0010	0.0054	0.0152
N ₅				0.0002	0.0011
N ₆					0.0000

1.3.8.2 COMBINED HPCI AND RCIC MOTOR OPERATED VALVE FAIL TO OPEN

System :	High pressure coolant injection
Component :	Reactor core isolation
Failure Mode :	Motor Operated Valve
Start Date :	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 34.10

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9211970	0.9802910	0.9919000	0.9999600	0.9998260	2.1712E+01	4.3652E-01
α_2	3.70E-05	1.97E-02	8.10E-03	7.88E-02	1.74E-04	4.3652E-01	2.1712E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9339130	0.9768680	0.9831150	0.9984570	0.9996510	4.6743E+01	1.1069E+00
α_2	5.68E-04	1.75E-02	1.14E-02	5.54E-02	3.43E-04	8.3956E-01	4.7010E+01
α_3	1.96E-07	5.59E-03	1.13E-03	2.65E-02	5.82E-06	2.6732E-01	4.7583E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9369260	0.9736750	0.9779950	0.9956430	0.9994940	6.9043E+01	1.8667E+00
α_2	1.47E-03	1.75E-02	1.32E-02	4.82E-02	4.97E-04	1.2395E+00	6.9670E+01
α_3	6.44E-06	5.70E-03	2.11E-03	2.36E-02	8.73E-06	4.0451E-01	7.0505E+01
α_4	1.35E-08	3.14E-03	4.30E-04	1.57E-02	0.00E+00	2.2267E-01	7.0687E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9451060	0.9722840	0.9747050	0.9911900	0.9993370	1.2479E+02	3.5572E+00
α_2	3.23E-03	1.66E-02	1.42E-02	3.83E-02	6.46E-04	2.1327E+00	1.2621E+02
α_3	3.72E-04	7.62E-03	5.26E-03	2.29E-02	1.75E-05	9.7788E-01	1.2737E+02
α_4	1.92E-06	2.92E-03	9.82E-04	1.24E-02	0.00E+00	3.7439E-01	1.2797E+02
α_5	4.65E-21	5.63E-04	3.18E-07	3.26E-03	0.00E+00	7.2277E-02	1.2827E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9478660	0.9723200	0.9743230	0.9899360	0.9991850	1.5128E+02	4.3067E+00
α_2	3.03E-03	1.46E-02	1.25E-02	3.30E-02	7.86E-04	2.2662E+00	1.5332E+02
α_3	5.18E-04	7.35E-03	5.37E-03	2.09E-02	2.91E-05	1.1428E+00	1.5444E+02
α_4	3.40E-05	3.81E-03	1.99E-03	1.37E-02	0.00E+00	5.9222E-01	1.5499E+02
α_5	5.97E-09	1.43E-03	1.94E-04	7.15E-03	0.00E+00	2.2220E-01	1.5536E+02
α_6	9.06E-19	5.35E-04	9.35E-07	3.12E-03	0.00E+00	8.3237E-02	1.5550E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9998260	0.9996510	0.9994940	0.9993370	0.9991850
α_2	1.74E-04	3.43E-04	4.97E-04	6.46E-04	7.86E-04
α_3		5.82E-06	8.73E-06	1.75E-05	2.91E-05
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	9.99E-01	9.99E-01	9.99E-01
Beta	1.74E-04	3.49E-04	5.06E-04	6.63E-04	8.15E-04
Gamma		1.67E-02	1.72E-02	2.63E-02	3.57E-02
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	11.37	17.05	22.73	28.42	34.10
N ₁	0.0960	0.1382	0.1766	0.2115	0.2430
N ₂	0.0020	0.0059	0.0114	0.0185	0.0270
N ₃		0.0001	0.0002	0.0005	0.0010
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.3.8.3 COMBINED HPCI AND RCIC MOTOR OPERATED VALVE FAIL TO CLOSE

System : High pressure coolant injection

Reactor core isolation

Motor Operated Valve

Failure Mode : Fail to close (reseat) on demand

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 33.80

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9332640	0.9826260	0.9920650	0.9999340	0.9968560	2.7686E+01	4.8952E-01
α_2	6.27E-05	1.74E-02	7.93E-03	6.67E-02	3.14E-03	4.8952E-01	2.7686E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9396830	0.9779940	0.9833130	0.9981060	0.9942830	5.5573E+01	1.2505E+00
α_2	8.41E-04	1.72E-02	1.19E-02	5.14E-02	5.42E-03	9.7546E-01	5.5848E+01
α_3	2.27E-07	4.84E-03	1.03E-03	2.28E-02	2.98E-04	2.7502E-01	5.6548E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9409100	0.9743200	0.9780420	0.9950040	0.9922130	8.0665E+01	2.1261E+00
α_2	2.05E-03	1.78E-02	1.41E-02	4.62E-02	6.98E-03	1.4711E+00	8.1320E+01
α_3	8.86E-06	5.21E-03	2.07E-03	2.10E-02	7.76E-04	4.3131E-01	8.2360E+01
α_4	1.23E-08	2.70E-03	3.73E-04	1.35E-02	2.87E-05	2.2367E-01	8.2567E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9470050	0.9725190	0.9746940	0.9906040	0.9909130	1.3917E+02	3.9327E+00
α_2	3.85E-03	1.70E-02	1.49E-02	3.78E-02	7.49E-03	2.4394E+00	1.4066E+02
α_3	4.14E-04	7.27E-03	5.14E-03	2.14E-02	1.47E-03	1.0410E+00	1.4206E+02
α_4	1.93E-06	2.65E-03	9.09E-04	1.12E-02	1.24E-04	3.7979E-01	1.4272E+02
α_5	4.67E-21	5.06E-04	2.93E-07	2.93E-03	4.61E-06	7.2477E-02	1.4303E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9491920	0.9722790	0.9740810	0.9892130	0.9899490	1.6839E+02	4.8011E+00
α_2	3.71E-03	1.52E-02	1.34E-02	3.30E-02	7.66E-03	2.6375E+00	1.7055E+02
α_3	6.12E-04	7.22E-03	5.43E-03	1.99E-02	2.07E-03	1.2496E+00	1.7194E+02
α_4	3.49E-05	3.51E-03	1.87E-03	1.25E-02	2.92E-04	6.0742E-01	1.7258E+02
α_5	5.73E-09	1.29E-03	1.77E-04	6.45E-03	2.12E-05	2.2330E-01	1.7297E+02
α_6	8.13E-19	4.81E-04	8.40E-07	2.80E-03	0.00E+00	8.3237E-02	1.7311E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9968560	0.9942830	0.9922130	0.9909130	0.9899490
α_2	3.14E-03	5.42E-03	6.98E-03	7.49E-03	7.66E-03
α_3		2.98E-04	7.76E-04	1.47E-03	2.07E-03
α_4			2.87E-05	1.24E-04	2.92E-04
α_5				4.61E-06	2.12E-05
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.97E-01	9.94E-01	9.92E-01	9.91E-01	9.90E-01
Beta	3.14E-03	5.72E-03	7.79E-03	9.09E-03	1.01E-02
Gamma		5.21E-02	1.03E-01	1.75E-01	2.38E-01
Delta			3.57E-02	8.09E-02	1.31E-01
Epsilon				3.57E-02	6.75E-02
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	16.90	25.35	33.80	42.25	50.70
N ₁	0.5400	0.6683	0.7290	0.7570	0.7547
N ₂	0.0550	0.1418	0.2430	0.3252	0.3983
N ₃		0.0078	0.0270	0.0636	0.1078
N ₄			0.0010	0.0054	0.0152
N ₅				0.0002	0.0011
N ₆					0.0000

1.3.9 Pressurizer PORV Motor-Operated Block Valves

1.3.9.1 PRESSURIZER PORV BLOCK MOVS FAIL TO OPEN

System :	Reactor coolant
Component :	Motor Operated Valve
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 4.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8819910	0.9704020	0.9877120	0.9999410	1.0000000	1.4246E+01	4.3452E-01
α_2	5.49E-05	2.96E-02	1.23E-02	1.18E-01	0.00E+00	4.3452E-01	1.4246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9094830	0.9682340	0.9767350	0.9978890	1.0000000	3.3555E+01	1.1009E+00
α_2	7.68E-04	2.41E-02	1.57E-02	7.59E-02	0.00E+00	8.3366E-01	3.3822E+01
α_3	2.71E-07	7.71E-03	1.56E-03	3.66E-02	0.00E+00	2.6722E-01	3.4389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9147120	0.9643190	0.9701040	0.9941100	1.0000000	5.0136E+01	1.8551E+00
α_2	1.96E-03	2.36E-02	1.78E-02	6.51E-02	0.00E+00	1.2281E+00	5.0763E+01
α_3	8.78E-06	7.78E-03	2.89E-03	3.21E-02	0.00E+00	4.0431E-01	5.1587E+01
α_4	1.85E-08	4.28E-03	5.88E-04	2.15E-02	0.00E+00	2.2267E-01	5.1768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	4.00	4.00	4.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.3.9.2 PRESSURIZER PORV BLOCK MOVS FAIL TO CLOSE

System :	Reactor coolant
Component :	Motor Operated Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 4.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8819910	0.9704020	0.9877120	0.9999410	1.0000000	1.4246E+01	4.3452E-01
α_2	5.49E-05	2.96E-02	1.23E-02	1.18E-01	0.00E+00	4.3452E-01	1.4246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9094830	0.9682340	0.9767350	0.9978890	1.0000000	3.3555E+01	1.1009E+00
α_2	7.68E-04	2.41E-02	1.57E-02	7.59E-02	0.00E+00	8.3366E-01	3.3822E+01
α_3	2.71E-07	7.71E-03	1.56E-03	3.66E-02	0.00E+00	2.6722E-01	3.4389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9147120	0.9643190	0.9701040	0.9941100	1.0000000	5.0136E+01	1.8551E+00
α_2	1.96E-03	2.36E-02	1.78E-02	6.51E-02	0.00E+00	1.2281E+00	5.0763E+01
α_3	8.78E-06	7.78E-03	2.89E-03	3.21E-02	0.00E+00	4.0431E-01	5.1587E+01
α_4	1.85E-08	4.28E-03	5.88E-04	2.15E-02	0.00E+00	2.2267E-01	5.1768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	4.00	4.00	4.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.4 Air Operated Valves

1.4.1 Pooled Air Operated Valves

1.4.1.1 AOV FAIL TO OPEN/CLOSE ALL SYSTEMS SPAR: AOV-FO

Component :

Air Operated Valve

Failure Mode :

Fail to close (reset) on demand

Fail to Open/Close Mode Unspecified (demand based)

Fail to open on demand

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 213.10

Total Number of Common-Cause Failure Events: 11

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9331610	0.9644210	0.9669510	0.9870220	0.9649150	1.1670E+02	4.3052E+00
α_2	1.30E-02	3.56E-02	3.30E-02	6.68E-02	3.51E-02	4.3052E+00	1.1670E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9395680	0.9639620	0.9655560	0.9829220	0.9639370	1.8625E+02	6.9630E+00
α_2	8.13E-03	2.24E-02	2.07E-02	4.22E-02	2.15E-02	4.3208E+00	1.8889E+02
α_3	3.34E-03	1.37E-02	1.20E-02	2.96E-02	1.46E-02	2.6422E+00	1.9057E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9441460	0.9646650	0.9658430	0.9811630	0.9654090	2.5299E+02	9.2669E+00
α_2	6.80E-03	1.78E-02	1.66E-02	3.30E-02	1.61E-02	4.6774E+00	2.5758E+02
α_3	2.48E-03	1.01E-02	8.90E-03	2.19E-02	1.05E-02	2.6543E+00	2.5960E+02
α_4	1.26E-03	7.38E-03	6.17E-03	1.76E-02	7.99E-03	1.9352E+00	2.6032E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9503400	0.9670030	0.9678490	0.9807730	0.9679380	3.5335E+02	1.2057E+01
α_2	6.94E-03	1.60E-02	1.52E-02	2.81E-02	1.41E-02	5.8612E+00	3.5955E+02
α_3	1.70E-03	7.10E-03	6.23E-03	1.55E-02	6.09E-03	2.5952E+00	3.6281E+02
α_4	1.64E-03	6.98E-03	6.11E-03	1.53E-02	8.20E-03	2.5523E+00	3.6286E+02
α_5	1.66E-04	2.87E-03	2.03E-03	8.44E-03	3.67E-03	1.0486E+00	3.6436E+02

Pooled Air Operated Valves

AOV FAIL TO OPEN/CLOSE ALL SYSTEMS SPAR: AOV-FO

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9543330	0.9690370	0.9697520	0.9813110	0.9706940	4.2465E+02	1.3568E+01
α_2	5.92E-03	1.36E-02	1.28E-02	2.37E-02	1.17E-02	5.9523E+00	4.3227E+02
α_3	1.56E-03	6.23E-03	5.49E-03	1.34E-02	5.01E-03	2.7294E+00	4.3549E+02
α_4	1.06E-03	5.16E-03	4.43E-03	1.18E-02	5.26E-03	2.2610E+00	4.3596E+02
α_5	7.75E-04	4.47E-03	3.74E-03	1.07E-02	5.48E-03	1.9584E+00	4.3626E+02
α_6	2.22E-05	1.52E-03	8.62E-04	5.27E-03	1.84E-03	6.6734E-01	4.3755E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9585020	0.9710430	0.9716070	0.9816660	0.9735660	5.4252E+02	1.6178E+01
α_2	5.23E-03	1.15E-02	1.10E-02	1.98E-02	9.12E-03	6.4461E+00	5.5225E+02
α_3	1.83E-03	6.05E-03	5.47E-03	1.23E-02	4.75E-03	3.3814E+00	5.5532E+02
α_4	8.93E-04	4.18E-03	3.61E-03	9.43E-03	3.66E-03	2.3358E+00	5.5636E+02
α_5	7.40E-04	3.83E-03	3.25E-03	8.88E-03	4.39E-03	2.1388E+00	5.5656E+02
α_6	3.03E-04	2.65E-03	2.08E-03	6.92E-03	3.51E-03	1.4781E+00	5.5722E+02
α_7	7.14E-07	7.12E-04	2.57E-04	2.96E-03	1.00E-03	3.9797E-01	5.5830E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9613450	0.9726590	0.9731440	0.9823110	0.9757040	6.2789E+02	1.7650E+01
α_2	4.62E-03	1.01E-02	9.63E-03	1.74E-02	7.62E-03	6.5394E+00	6.3900E+02
α_3	1.71E-03	5.47E-03	4.97E-03	1.10E-02	4.28E-03	3.5340E+00	6.4201E+02
α_4	8.15E-04	3.71E-03	3.21E-03	8.31E-03	2.98E-03	2.3957E+00	6.4314E+02
α_5	5.75E-04	3.16E-03	2.66E-03	7.43E-03	3.17E-03	2.0367E+00	6.4350E+02
α_6	4.32E-04	2.79E-03	2.30E-03	6.83E-03	3.42E-03	1.8007E+00	6.4374E+02
α_7	9.84E-05	1.65E-03	1.17E-03	4.83E-03	2.24E-03	1.0642E+00	6.4448E+02
α_8	2.32E-08	4.32E-04	9.32E-05	2.02E-03	5.86E-04	2.7902E-01	6.4526E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9649150	0.9639370	0.9654090	0.9679380	0.9706940	0.9735660	0.9757040
α_2	3.51E-02	2.15E-02	1.61E-02	1.41E-02	1.17E-02	9.12E-03	7.62E-03
α_3		1.46E-02	1.05E-02	6.09E-03	5.01E-03	4.75E-03	4.28E-03
α_4			7.99E-03	8.20E-03	5.26E-03	3.66E-03	2.98E-03
α_5				3.67E-03	5.48E-03	4.39E-03	3.17E-03
α_6					1.84E-03	3.51E-03	3.42E-03
α_7						1.00E-03	2.24E-03
α_8							5.86E-04

Air Operated Valves

2010

Pooled Air Operated Valves

AOV FAIL TO OPEN/CLOSE ALL SYSTEMS SPAR: AOV-FO

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.65E-01	9.64E-01	9.65E-01	9.68E-01	9.71E-01	9.74E-01	9.76E-01
Beta	3.51E-02	3.61E-02	3.46E-02	3.21E-02	2.93E-02	2.64E-02	2.43E-02
Gamma		4.05E-01	5.35E-01	5.60E-01	6.00E-01	6.55E-01	6.86E-01
Delta			4.32E-01	6.61E-01	7.15E-01	7.25E-01	7.43E-01
Epsilon				3.10E-01	5.82E-01	7.09E-01	7.60E-01
Mu					2.52E-01	5.07E-01	6.64E-01
Upsilon						2.22E-01	4.53E-01
Sigma							2.07E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	101.96	152.94	203.92	254.90	305.89	356.87	407.85
N ₁	4.4919	3.7507	2.9348	2.2845	1.8163	1.6020	1.3101
N ₂	3.8707	3.4871	3.4493	3.7470	3.7131	3.3583	3.1947
N ₃		2.3750	2.2500	1.6178	1.5876	1.7502	1.7956
N ₄			1.7125	2.1779	1.6688	1.3469	1.2492
N ₅				0.9763	1.7362	1.6170	1.3284
N ₆					0.5841	1.2918	1.4337
N ₇						0.3689	0.9412
N ₈							0.2459

1.4.1.2 AOV FAIL TO OPEN ALL SYSTEMS SPAR: AOV-CC

Component :	Air Operated Valve
Failure Mode :	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 126.20

Total Number of Common-Cause Failure Events: 5

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9375960	0.9739420	0.9782130	0.9956770	0.9764990	6.9901E+01	1.8702E+00
α_2	4.32E-03	2.61E-02	2.18E-02	6.24E-02	2.35E-02	1.8702E+00	6.9901E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9466770	0.9739610	0.9765260	0.9924820	0.9772990	1.1812E+02	3.1580E+00
α_2	3.90E-03	1.87E-02	1.61E-02	4.23E-02	1.58E-02	2.2658E+00	1.1901E+02
α_3	2.81E-04	7.36E-03	4.89E-03	2.29E-02	6.90E-03	8.9222E-01	1.2039E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9487750	0.9722600	0.9741180	0.9894030	0.9766300	1.6322E+02	4.6569E+00
α_2	4.82E-03	1.77E-02	1.58E-02	3.70E-02	1.45E-02	2.9674E+00	1.6491E+02
α_3	4.95E-04	6.88E-03	5.04E-03	1.95E-02	6.26E-03	1.1543E+00	1.6672E+02
α_4	1.78E-05	3.19E-03	1.54E-03	1.19E-02	2.61E-03	5.3517E-01	1.6734E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9525320	0.9716860	0.9729390	0.9865490	0.9764870	2.4164E+02	7.0413E+00
α_2	5.91E-03	1.67E-02	1.54E-02	3.19E-02	1.37E-02	4.1588E+00	2.4452E+02
α_3	1.05E-03	7.03E-03	5.76E-03	1.74E-02	5.17E-03	1.7482E+00	2.4693E+02
α_4	1.45E-04	3.64E-03	2.43E-03	1.13E-02	3.57E-03	9.0569E-01	2.4778E+02
α_5	5.45E-09	9.19E-04	1.33E-04	4.57E-03	1.05E-03	2.2858E-01	2.4845E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9540270	0.9714330	0.9724760	0.9852710	0.9760190	2.9059E+02	8.5453E+00
α_2	6.07E-03	1.58E-02	1.48E-02	2.92E-02	1.40E-02	4.7315E+00	2.9440E+02
α_3	1.02E-03	6.25E-03	5.19E-03	1.51E-02	4.10E-03	1.8710E+00	2.9726E+02
α_4	3.25E-04	4.06E-03	3.03E-03	1.13E-02	3.50E-03	1.2155E+00	2.9792E+02
α_5	1.38E-05	1.89E-03	9.56E-04	6.95E-03	1.93E-03	5.6600E-01	2.9857E+02
α_6	1.84E-11	5.39E-04	2.92E-05	2.93E-03	4.39E-04	1.6134E-01	2.9897E+02

Pooled Air Operated Valves

AOV FAIL TO OPEN ALL SYSTEMS SPAR: AOV-CC

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9571200	0.9719440	0.9727350	0.9840790	0.9772650	3.8614E+02	1.1146E+01
α_2	5.88E-03	1.40E-02	1.32E-02	2.48E-02	1.19E-02	5.5565E+00	3.9173E+02
α_3	1.46E-03	6.32E-03	5.51E-03	1.39E-02	4.25E-03	2.5097E+00	3.9478E+02
α_4	5.37E-04	4.06E-03	3.27E-03	1.03E-02	3.02E-03	1.6142E+00	3.9567E+02
α_5	1.30E-04	2.52E-03	1.75E-03	7.53E-03	2.32E-03	1.0007E+00	3.9629E+02
α_6	9.90E-07	1.00E-03	3.60E-04	4.16E-03	1.02E-03	3.9718E-01	3.9689E+02
α_7	1.23E-22	1.72E-04	5.74E-08	9.84E-04	1.89E-04	6.8171E-02	3.9722E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9591840	0.9726970	0.9733780	0.9838890	0.9781510	4.4918E+02	1.2608E+01
α_2	5.52E-03	1.27E-02	1.20E-02	2.23E-02	1.08E-02	5.8813E+00	4.5591E+02
α_3	1.45E-03	5.84E-03	5.15E-03	1.26E-02	4.08E-03	2.6988E+00	4.5909E+02
α_4	5.79E-04	3.83E-03	3.14E-03	9.43E-03	2.64E-03	1.7686E+00	4.6002E+02
α_5	2.28E-04	2.70E-03	2.03E-03	7.48E-03	2.29E-03	1.2480E+00	4.6054E+02
α_6	2.84E-05	1.54E-03	9.06E-04	5.21E-03	1.46E-03	7.1106E-01	4.6108E+02
α_7	8.28E-09	5.37E-04	9.24E-05	2.61E-03	5.31E-04	2.4797E-01	4.6154E+02
α_8	2.40E-28	1.14E-04	2.42E-09	6.17E-04	8.28E-05	5.2624E-02	4.6174E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9764990	0.9772990	0.9766300	0.9764870	0.9760190	0.9772650	0.9781510
α_2	2.35E-02	1.58E-02	1.45E-02	1.37E-02	1.40E-02	1.19E-02	1.08E-02
α_3		6.90E-03	6.26E-03	5.17E-03	4.10E-03	4.25E-03	4.08E-03
α_4			2.61E-03	3.57E-03	3.50E-03	3.02E-03	2.64E-03
α_5				1.05E-03	1.93E-03	2.32E-03	2.29E-03
α_6					4.39E-04	1.02E-03	1.46E-03
α_7						1.89E-04	5.31E-04
α_8							8.28E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.76E-01	9.77E-01	9.77E-01	9.76E-01	9.76E-01	9.77E-01	9.78E-01
Beta	2.35E-02	2.27E-02	2.34E-02	2.35E-02	2.40E-02	2.27E-02	2.18E-02
Gamma		3.04E-01	3.79E-01	4.16E-01	4.16E-01	4.75E-01	5.07E-01
Delta			2.94E-01	4.71E-01	5.89E-01	6.07E-01	6.32E-01
Epsilon				2.27E-01	4.04E-01	5.38E-01	6.23E-01
Mu					1.85E-01	3.43E-01	4.75E-01
Upsilon						1.56E-01	2.96E-01
Sigma							1.35E-01

Air Operated Valves

2010

Pooled Air Operated Valves

AOV FAIL TO OPEN ALL SYSTEMS SPAR: AOV-CC

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	57.36	86.05	114.73	143.41	172.09	200.77	229.45
N ₁	2.2952	2.5107	2.3548	2.0670	1.5640	1.3174	0.9958
N ₂	1.4357	1.4321	1.7393	2.0446	2.4923	2.4687	2.5366
N ₃		0.6250	0.7500	0.7708	0.7292	0.8785	0.9604
N ₄			0.3125	0.5313	0.6233	0.6253	0.6221
N ₅				0.1563	0.3438	0.4789	0.5397
N ₆					0.0781	0.2109	0.3441
N ₇						0.0391	0.1250
N ₈							0.0195

1.4.1.3 AOV FAIL TO CLOSE ALL SYSTEMS SPAR: AOV-OO

Component :	Air Operated Valve
Failure Mode :	Fail to close (reseat) on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 81.40

Total Number of Common-Cause Failure Events: 6

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8933080	0.9487700	0.9540420	0.9861950	0.9462850	5.3143E+01	2.8695E+00
α_2	1.38E-02	5.12E-02	4.60E-02	1.07E-01	5.37E-02	2.8695E+00	5.3143E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9082580	0.9492930	0.9523650	0.9798230	0.9424310	9.1845E+01	4.9059E+00
α_2	8.00E-03	2.99E-02	2.67E-02	6.26E-02	3.11E-02	2.8887E+00	9.3862E+01
α_3	3.80E-03	2.08E-02	1.76E-02	4.89E-02	2.65E-02	2.0172E+00	9.4734E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9184100	0.9519630	0.9541920	0.9779140	0.9467610	1.2812E+02	6.4651E+00
α_2	5.91E-03	2.18E-02	1.95E-02	4.57E-02	1.97E-02	2.9381E+00	1.3165E+02
α_3	2.38E-03	1.41E-02	1.18E-02	3.39E-02	1.73E-02	1.9043E+00	1.3268E+02
α_4	1.62E-03	1.21E-02	9.74E-03	3.04E-02	1.62E-02	1.6227E+00	1.3296E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9336340	0.9586120	0.9600870	0.9785620	0.9531140	1.9813E+02	8.5543E+00
α_2	6.15E-03	1.85E-02	1.69E-02	3.60E-02	1.59E-02	3.8165E+00	2.0287E+02
α_3	1.40E-03	8.83E-03	7.30E-03	2.15E-02	7.92E-03	1.8244E+00	2.0486E+02
α_4	1.77E-03	9.78E-03	8.25E-03	2.30E-02	1.54E-02	2.0211E+00	2.0466E+02
α_5	1.64E-04	4.32E-03	2.86E-03	1.34E-02	7.66E-03	8.9228E-01	2.0579E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9409330	0.9625820	0.9638190	0.9800120	0.9605640	2.3929E+02	9.3018E+00
α_2	4.30E-03	1.39E-02	1.26E-02	2.79E-02	9.58E-03	3.4600E+00	2.4513E+02
α_3	1.44E-03	8.05E-03	6.77E-03	1.90E-02	6.74E-03	2.0002E+00	2.4659E+02
α_4	8.92E-04	6.59E-03	5.32E-03	1.66E-02	8.21E-03	1.6378E+00	2.4695E+02
α_5	8.61E-04	6.49E-03	5.23E-03	1.65E-02	1.09E-02	1.6146E+00	2.4698E+02
α_6	2.07E-05	2.37E-03	1.23E-03	8.58E-03	3.97E-03	5.8924E-01	2.4800E+02

Pooled Air Operated Valves

AOV FAIL TO CLOSE ALL SYSTEMS SPAR: AOV-OO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9484890	0.9660710	0.9669880	0.9805320	0.9659480	3.2678E+02	1.1477E+01
α_2	4.02E-03	1.18E-02	1.08E-02	2.27E-02	6.02E-03	3.9775E+00	3.3428E+02
α_3	1.70E-03	7.40E-03	6.45E-03	1.63E-02	5.90E-03	2.5028E+00	3.3575E+02
α_4	7.30E-04	5.06E-03	4.12E-03	1.26E-02	4.88E-03	1.7105E+00	3.3655E+02
α_5	6.77E-04	4.91E-03	3.97E-03	1.23E-02	7.70E-03	1.6599E+00	3.3660E+02
α_6	3.25E-04	3.75E-03	2.83E-03	1.03E-02	7.31E-03	1.2672E+00	3.3699E+02
α_7	5.08E-07	1.06E-03	3.37E-04	4.57E-03	2.23E-03	3.5887E-01	3.3790E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9525800	0.9682960	0.9690820	0.9813250	0.9700210	3.8184E+02	1.2502E+01
α_2	3.49E-03	1.02E-02	9.33E-03	1.96E-02	3.91E-03	4.0028E+00	3.9034E+02
α_3	1.55E-03	6.53E-03	5.71E-03	1.43E-02	4.97E-03	2.5736E+00	3.9177E+02
α_4	6.83E-04	4.50E-03	3.69E-03	1.11E-02	3.73E-03	1.7736E+00	3.9257E+02
α_5	4.45E-04	3.80E-03	3.00E-03	9.88E-03	4.69E-03	1.4970E+00	3.9285E+02
α_6	4.14E-04	3.69E-03	2.90E-03	9.70E-03	6.48E-03	1.4566E+00	3.9289E+02
α_7	1.04E-04	2.38E-03	1.61E-03	7.29E-03	4.85E-03	9.3917E-01	3.9340E+02
α_8	1.67E-08	6.58E-04	1.24E-04	3.15E-03	1.35E-03	2.5942E-01	3.9408E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9462850	0.9424310	0.9467610	0.9531140	0.9605640	0.9659480	0.9700210
α_2	5.37E-02	3.11E-02	1.97E-02	1.59E-02	9.58E-03	6.02E-03	3.91E-03
α_3		2.65E-02	1.73E-02	7.92E-03	6.74E-03	5.90E-03	4.97E-03
α_4			1.62E-02	1.54E-02	8.21E-03	4.88E-03	3.73E-03
α_5				7.66E-03	1.09E-02	7.70E-03	4.69E-03
α_6					3.97E-03	7.31E-03	6.48E-03
α_7						2.23E-03	4.85E-03
α_8							1.35E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.46E-01	9.42E-01	9.47E-01	9.53E-01	9.61E-01	9.66E-01	9.70E-01
Beta	5.37E-02	5.76E-02	5.32E-02	4.69E-02	3.94E-02	3.41E-02	3.00E-02
Gamma		4.60E-01	6.29E-01	6.61E-01	7.57E-01	8.23E-01	8.69E-01
Delta			4.83E-01	7.44E-01	7.74E-01	7.90E-01	8.09E-01
Epsilon				3.32E-01	6.45E-01	7.79E-01	8.23E-01
Mu					2.67E-01	5.53E-01	7.30E-01
Upsilon						2.34E-01	4.89E-01
Sigma							2.17E-01

Air Operated Valves

2010

Pooled Air Operated Valves

AOV FAIL TO CLOSE ALL SYSTEMS SPAR: AOV-OO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	40.70	61.05	81.40	101.75	122.10	142.45	162.80
N ₁	2.1967	1.2400	0.5800	0.2175	0.2523	0.2845	0.3143
N ₂	2.4350	2.0550	1.7100	1.7023	1.2208	0.8897	0.6581
N ₃		1.7500	1.5000	0.8470	0.8584	0.8716	0.8352
N ₄			1.4000	1.6467	1.0456	0.7216	0.6271
N ₅				0.8200	1.3924	1.1381	0.7887
N ₆					0.5060	1.0809	1.0896
N ₇						0.3298	0.8162
N ₈							0.2263

BWR Isolation Condenser Air-Operated Valves
 ISO CONDENSER AOV FAIL TO OPEN/CLOSE

1.4.2 BWR Isolation Condenser Air-Operated Valves

1.4.2.1 ISO CONDENSER AOV FAIL TO OPEN/CLOSE

System :	Isolation condenser
Component :	Air Operated Valve
Failure Mode :	Fail to close (reseat) on demand Fail to Open/Close Mode Unspecified (demand based) Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.7072910	0.8822300	0.9029730	0.9858660	0.3333330	1.0746E+01	1.4345E+00
α_2	1.41E-02	1.18E-01	9.70E-02	2.93E-01	6.67E-01	1.4345E+00	1.0746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8529320	0.9351700	0.9439770	0.9872260	0.4285710	3.0305E+01	2.1009E+00
α_2	8.23E-04	2.57E-02	1.68E-02	8.11E-02	0.00E+00	8.3366E-01	3.1572E+01
α_3	3.50E-03	3.91E-02	3.00E-02	1.06E-01	5.71E-01	1.2672E+00	3.1139E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8811760	0.9428880	0.9487180	0.9846280	0.5000000	4.7136E+01	2.8551E+00
α_2	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
α_3	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
α_4	2.02E-03	2.45E-02	1.84E-02	6.75E-02	5.00E-01	1.2227E+00	4.8768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9177320	0.9554850	0.9584350	0.9831430	0.5555560	9.7411E+01	4.5382E+00
α_2	4.00E-03	2.07E-02	1.77E-02	4.79E-02	0.00E+00	2.1142E+00	9.9835E+01
α_3	4.69E-04	9.59E-03	6.63E-03	2.88E-02	0.00E+00	9.7738E-01	1.0097E+02
α_4	3.10E-04	8.58E-03	5.65E-03	2.68E-02	2.22E-01	8.7439E-01	1.0107E+02
α_5	4.31E-05	5.61E-03	2.87E-03	2.05E-02	2.22E-01	5.7228E-01	1.0138E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9239510	0.9573330	0.9597820	0.9823620	0.6000000	1.1844E+02	5.2787E+00
α_2	3.72E-03	1.81E-02	1.56E-02	4.11E-02	0.00E+00	2.2392E+00	1.2148E+02
α_3	6.50E-04	9.23E-03	6.75E-03	2.63E-02	0.00E+00	1.1418E+00	1.2258E+02
α_4	2.20E-04	6.81E-03	4.40E-03	2.16E-02	1.00E-01	8.4222E-01	1.2288E+02
α_5	1.14E-04	5.84E-03	3.48E-03	1.96E-02	2.00E-01	7.2220E-01	1.2300E+02
α_6	7.22E-07	2.69E-03	7.75E-04	1.19E-02	1.00E-01	3.3324E-01	1.2339E+02

BWR Isolation Condenser Air-Operated Valves
 ISO CONDENSER AOV FAIL TO OPEN/CLOSE

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.3333330	0.4285710	0.5000000	0.5555560	0.6000000
α_2	6.67E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		5.71E-01	0.00E+00	0.00E+00	0.00E+00
α_4			5.00E-01	2.22E-01	1.00E-01
α_5				2.22E-01	2.00E-01
α_6					1.00E-01

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	3.33E-01	4.29E-01	5.00E-01	5.56E-01	6.00E-01
Beta	6.67E-01	5.71E-01	5.00E-01	4.44E-01	4.00E-01
Gamma		1.00E+00	1.00E+00	1.00E+00	1.00E+00
Delta			1.00E+00	1.00E+00	1.00E+00
Epsilon				5.00E-01	7.50E-01
Mu					3.33E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.50	0.75	1.00	1.25	1.50
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	1.0000	0.0000	0.0000	0.0000	0.0000
N ₃		1.0000	0.0000	0.0000	0.0000
N ₄			1.0000	0.5000	0.2500
N ₅				0.5000	0.5000
N ₆					0.2500

1.4.2.2 ISO CONDENSER AOV FAIL TO OPEN

System : Isolation condenser
Component : Air Operated Valve
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8522320	0.9628000	0.9843830	0.9999320	1.0000000	1.1246E+01	4.3452E-01
α_2	7.00E-05	3.72E-02	1.56E-02	1.48E-01	0.00E+00	4.3452E-01	1.1246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9010680	0.9652240	0.9744830	0.9976820	1.0000000	3.0555E+01	1.1009E+00
α_2	8.43E-04	2.63E-02	1.72E-02	8.30E-02	0.00E+00	8.3366E-01	3.0822E+01
α_3	2.98E-07	8.44E-03	1.71E-03	4.00E-02	0.00E+00	2.6722E-01	3.1389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9095820	0.9621340	0.9682530	0.9937390	1.0000000	4.7136E+01	1.8551E+00
α_2	2.09E-03	2.51E-02	1.89E-02	6.90E-02	0.00E+00	1.2281E+00	4.7763E+01
α_3	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8587E+01
α_4	1.97E-08	4.55E-03	6.24E-04	2.28E-02	0.00E+00	2.2267E-01	4.8768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9304990	0.9648630	0.9678980	0.9888360	1.0000000	9.7161E+01	3.5382E+00
α_2	4.05E-03	2.10E-02	1.79E-02	4.85E-02	0.00E+00	2.1142E+00	9.8585E+01
α_3	4.74E-04	9.71E-03	6.71E-03	2.92E-02	0.00E+00	9.7738E-01	9.9722E+01
α_4	2.45E-06	3.72E-03	1.25E-03	1.58E-02	0.00E+00	3.7439E-01	1.0032E+02
α_5	5.93E-21	7.18E-04	4.06E-07	4.16E-03	0.00E+00	7.2277E-02	1.0063E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9341160	0.9649920	0.9674990	0.9872840	1.0000000	1.1794E+02	4.2787E+00
α_2	3.77E-03	1.83E-02	1.58E-02	4.16E-02	0.00E+00	2.2392E+00	1.1998E+02
α_3	6.58E-04	9.34E-03	6.84E-03	2.66E-02	0.00E+00	1.1418E+00	1.2108E+02
α_4	4.33E-05	4.85E-03	2.54E-03	1.75E-02	0.00E+00	5.9222E-01	1.2163E+02
α_5	7.60E-09	1.82E-03	2.47E-04	9.11E-03	0.00E+00	2.2220E-01	1.2200E+02
α_6	1.15E-18	6.81E-04	1.19E-06	3.98E-03	0.00E+00	8.3237E-02	1.2214E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	1.00	1.00	1.00	1.00	1.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.4.2.3 ISO CONDENSER AOV FAIL TO CLOSE

System : Isolation condenser
Component : Air Operated Valve
Failure Mode : Fail to close (reseat) on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.6956560	0.8771890	0.8985750	0.9851950	0.0000000	1.0246E+01	1.4345E+00
α_2	1.48E-02	1.23E-01	1.01E-01	3.04E-01	1.00E+00	1.4345E+00	1.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8495560	0.9336340	0.9426210	0.9869090	0.0000000	2.9555E+01	2.1009E+00
α_2	8.43E-04	2.63E-02	1.72E-02	8.30E-02	0.00E+00	8.3366E-01	3.0822E+01
α_3	3.59E-03	4.00E-02	3.08E-02	1.08E-01	1.00E+00	1.2672E+00	3.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8788090	0.9417220	0.9476570	0.9843040	0.0000000	4.6136E+01	2.8551E+00
α_2	2.09E-03	2.51E-02	1.89E-02	6.90E-02	0.00E+00	1.2281E+00	4.7763E+01
α_3	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8587E+01
α_4	2.06E-03	2.50E-02	1.88E-02	6.88E-02	1.00E+00	1.2227E+00	4.7768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9167220	0.9549330	0.9579160	0.9829300	0.0000000	9.6161E+01	4.5382E+00
α_2	4.05E-03	2.10E-02	1.79E-02	4.85E-02	0.00E+00	2.1142E+00	9.8585E+01
α_3	4.74E-04	9.71E-03	6.71E-03	2.92E-02	0.00E+00	9.7738E-01	9.9722E+01
α_4	3.14E-04	8.68E-03	5.72E-03	2.72E-02	5.00E-01	8.7439E-01	9.9825E+01
α_5	4.37E-05	5.68E-03	2.91E-03	2.07E-02	5.00E-01	5.7228E-01	1.0013E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9230310	0.9568100	0.9592860	0.9821410	0.0000000	1.1694E+02	5.2787E+00
α_2	3.77E-03	1.83E-02	1.58E-02	4.16E-02	0.00E+00	2.2392E+00	1.1998E+02
α_3	6.58E-04	9.34E-03	6.84E-03	2.66E-02	0.00E+00	1.1418E+00	1.2108E+02
α_4	2.23E-04	6.89E-03	4.45E-03	2.19E-02	2.50E-01	8.4222E-01	1.2138E+02
α_5	1.16E-04	5.91E-03	3.52E-03	1.98E-02	5.00E-01	7.2220E-01	1.2150E+02
α_6	7.30E-07	2.73E-03	7.85E-04	1.20E-02	2.50E-01	3.3324E-01	1.2189E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.0000000	0.0000000	0.0000000	0.0000000	0.0000000
α_2	1.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		1.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			1.00E+00	5.00E-01	2.50E-01
α_5				5.00E-01	5.00E-01
α_6					2.50E-01

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Gamma		1.00E+00	1.00E+00	1.00E+00	1.00E+00
Delta			1.00E+00	1.00E+00	1.00E+00
Epsilon				5.00E-01	7.50E-01
Mu					3.33E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	1.0000	0.0000	0.0000	0.0000	0.0000
N ₃		1.0000	0.0000	0.0000	0.0000
N ₄			1.0000	0.5000	0.2500
N ₅				0.5000	0.5000
N ₆					0.2500

1.4.3 PWR Auxiliary Feedwater Air-Operated Valves

1.4.3.1 AFW AOV FAIL TO OPEN/CLOSE SPAR: AOV-FO

Component :

Air Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Fail to Open/Close Mode Unspecified (demand based)

Fail to open on demand

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 213.10

Total Number of Common-Cause Failure Events: 11

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9331610	0.9644210	0.9669510	0.9870220	0.9649150	1.1670E+02	4.3052E+00
α_2	1.30E-02	3.56E-02	3.30E-02	6.68E-02	3.51E-02	4.3052E+00	1.1670E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9395680	0.9639620	0.9655560	0.9829220	0.9639370	1.8625E+02	6.9630E+00
α_2	8.13E-03	2.24E-02	2.07E-02	4.22E-02	2.15E-02	4.3208E+00	1.8889E+02
α_3	3.34E-03	1.37E-02	1.20E-02	2.96E-02	1.46E-02	2.6422E+00	1.9057E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9441460	0.9646650	0.9658430	0.9811630	0.9654090	2.5299E+02	9.2669E+00
α_2	6.80E-03	1.78E-02	1.66E-02	3.30E-02	1.61E-02	4.6774E+00	2.5758E+02
α_3	2.48E-03	1.01E-02	8.90E-03	2.19E-02	1.05E-02	2.6543E+00	2.5960E+02
α_4	1.26E-03	7.38E-03	6.17E-03	1.76E-02	7.99E-03	1.9352E+00	2.6032E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9503400	0.9670030	0.9678490	0.9807730	0.9679380	3.5335E+02	1.2057E+01
α_2	6.94E-03	1.60E-02	1.52E-02	2.81E-02	1.41E-02	5.8612E+00	3.5955E+02
α_3	1.70E-03	7.10E-03	6.23E-03	1.55E-02	6.09E-03	2.5952E+00	3.6281E+02
α_4	1.64E-03	6.98E-03	6.11E-03	1.53E-02	8.20E-03	2.5523E+00	3.6286E+02
α_5	1.66E-04	2.87E-03	2.03E-03	8.44E-03	3.67E-03	1.0486E+00	3.6436E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9543330	0.9690370	0.9697520	0.9813110	0.9706940	4.2465E+02	1.3568E+01
α_2	5.92E-03	1.36E-02	1.28E-02	2.37E-02	1.17E-02	5.9523E+00	4.3227E+02
α_3	1.56E-03	6.23E-03	5.49E-03	1.34E-02	5.01E-03	2.7294E+00	4.3549E+02
α_4	1.06E-03	5.16E-03	4.43E-03	1.18E-02	5.26E-03	2.2610E+00	4.3596E+02
α_5	7.75E-04	4.47E-03	3.74E-03	1.07E-02	5.48E-03	1.9584E+00	4.3626E+02
α_6	2.22E-05	1.52E-03	8.62E-04	5.27E-03	1.84E-03	6.6734E-01	4.3755E+02

PWR Auxiliary Feedwater Air-Operated Valves

AFW AOV FAIL TO OPEN/CLOSE SPAR: AOV-FO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9585020	0.9710430	0.9716070	0.9816660	0.9735660	5.4252E+02	1.6178E+01
α_2	5.23E-03	1.15E-02	1.10E-02	1.98E-02	9.12E-03	6.4461E+00	5.5225E+02
α_3	1.83E-03	6.05E-03	5.47E-03	1.23E-02	4.75E-03	3.3814E+00	5.5532E+02
α_4	8.93E-04	4.18E-03	3.61E-03	9.43E-03	3.66E-03	2.3358E+00	5.5636E+02
α_5	7.40E-04	3.83E-03	3.25E-03	8.88E-03	4.39E-03	2.1388E+00	5.5656E+02
α_6	3.03E-04	2.65E-03	2.08E-03	6.92E-03	3.51E-03	1.4781E+00	5.5722E+02
α_7	7.14E-07	7.12E-04	2.57E-04	2.96E-03	1.00E-03	3.9797E-01	5.5830E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9613450	0.9726590	0.9731440	0.9823110	0.9757040	6.2789E+02	1.7650E+01
α_2	4.62E-03	1.01E-02	9.63E-03	1.74E-02	7.62E-03	6.5394E+00	6.3900E+02
α_3	1.71E-03	5.47E-03	4.97E-03	1.10E-02	4.28E-03	3.5340E+00	6.4201E+02
α_4	8.15E-04	3.71E-03	3.21E-03	8.31E-03	2.98E-03	2.3957E+00	6.4314E+02
α_5	5.75E-04	3.16E-03	2.66E-03	7.43E-03	3.17E-03	2.0367E+00	6.4350E+02
α_6	4.32E-04	2.79E-03	2.30E-03	6.83E-03	3.42E-03	1.8007E+00	6.4374E+02
α_7	9.84E-05	1.65E-03	1.17E-03	4.83E-03	2.24E-03	1.0642E+00	6.4448E+02
α_8	2.32E-08	4.32E-04	9.32E-05	2.02E-03	5.86E-04	2.7902E-01	6.4526E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9649150	0.9639370	0.9654090	0.9679380	0.9706940	0.9735660	0.9757040
α_2	3.51E-02	2.15E-02	1.61E-02	1.41E-02	1.17E-02	9.12E-03	7.62E-03
α_3		1.46E-02	1.05E-02	6.09E-03	5.01E-03	4.75E-03	4.28E-03
α_4			7.99E-03	8.20E-03	5.26E-03	3.66E-03	2.98E-03
α_5				3.67E-03	5.48E-03	4.39E-03	3.17E-03
α_6					1.84E-03	3.51E-03	3.42E-03
α_7						1.00E-03	2.24E-03
α_8							5.86E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.65E-01	9.64E-01	9.65E-01	9.68E-01	9.71E-01	9.74E-01	9.76E-01
Beta	3.51E-02	3.61E-02	3.46E-02	3.21E-02	2.93E-02	2.64E-02	2.43E-02
Gamma		4.05E-01	5.35E-01	5.60E-01	6.00E-01	6.55E-01	6.86E-01
Delta			4.32E-01	6.61E-01	7.15E-01	7.25E-01	7.43E-01
Epsilon				3.10E-01	5.82E-01	7.09E-01	7.60E-01
Mu					2.52E-01	5.07E-01	6.64E-01
Upsilon						2.22E-01	4.53E-01
Sigma							2.07E-01

Air Operated Valves

2010

PWR Auxiliary Feedwater Air-Operated Valves

AFW AOV FAIL TO OPEN/CLOSE SPAR: AOV-FO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	101.96	152.94	203.92	254.90	305.89	356.87	407.85
N ₁	4.4919	3.7507	2.9348	2.2845	1.8163	1.6020	1.3101
N ₂	3.8707	3.4871	3.4493	3.7470	3.7131	3.3583	3.1947
N ₃		2.3750	2.2500	1.6178	1.5876	1.7502	1.7956
N ₄			1.7125	2.1779	1.6688	1.3469	1.2492
N ₅				0.9763	1.7362	1.6170	1.3284
N ₆					0.5841	1.2918	1.4337
N ₇						0.3689	0.9412
N ₈							0.2459

1.4.3.2 AFW AOV FAIL TO OPEN SPAR: AFW-AOV-CC

System : Auxiliary feedwater
Component : Air Operated Valve
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 29.10

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8922460	0.9663920	0.9785260	0.9990900	0.9723270	2.2628E+01	7.8692E-01
α_2	9.07E-04	3.36E-02	2.15E-02	1.08E-01	2.77E-02	7.8692E-01	2.2628E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9085350	0.9613400	0.9674070	0.9933620	0.9568340	4.7446E+01	1.9080E+00
α_2	3.75E-03	3.07E-02	2.46E-02	7.86E-02	3.65E-02	1.5158E+00	4.7838E+01
α_3	7.31E-06	7.95E-03	2.85E-03	3.32E-02	6.69E-03	3.9222E-01	4.8962E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9114200	0.9564500	0.9605930	0.9873070	0.9468580	6.9331E+01	3.1569E+00
α_2	6.27E-03	3.06E-02	2.64E-02	6.93E-02	4.04E-02	2.2174E+00	7.0270E+01
α_3	1.23E-04	9.03E-03	5.08E-03	3.13E-02	1.02E-02	6.5431E-01	7.1834E+01
α_4	2.63E-07	3.93E-03	8.88E-04	1.83E-02	2.55E-03	2.8517E-01	7.2203E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9265130	0.9586130	0.9609470	0.9827290	0.9391150	1.2449E+02	5.3747E+00
α_2	8.24E-03	2.66E-02	2.42E-02	5.31E-02	4.43E-02	3.4505E+00	1.2641E+02
α_3	8.98E-04	9.93E-03	7.55E-03	2.71E-02	1.04E-02	1.2899E+00	1.2857E+02
α_4	2.19E-05	4.09E-03	1.97E-03	1.53E-02	5.18E-03	5.3069E-01	1.2933E+02
α_5	1.30E-15	7.98E-04	5.85E-06	4.63E-03	1.04E-03	1.0358E-01	1.2976E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9278940	0.9572720	0.9592060	0.9800480	0.9320500	1.5022E+02	6.7051E+00
α_2	8.84E-03	2.55E-02	2.36E-02	4.91E-02	4.96E-02	4.0093E+00	1.5292E+02
α_3	1.04E-03	9.27E-03	7.28E-03	2.43E-02	8.75E-03	1.4543E+00	1.5547E+02
α_4	1.61E-04	5.27E-03	3.37E-03	1.68E-02	6.56E-03	8.2662E-01	1.5610E+02
α_5	3.44E-07	2.01E-03	5.35E-04	9.05E-03	2.63E-03	3.1600E-01	1.5661E+02
α_6	2.66E-16	6.30E-04	3.49E-06	3.66E-03	4.37E-04	9.8837E-02	1.5683E+02

PWR Auxiliary Feedwater Air-Operated Valves
 AFW AOV FAIL TO OPEN SPAR: AFW-AOV-CC
CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9375820	0.9605850	0.9619010	0.9790820	0.9347890	2.2257E+02	9.1325E+00
α_2	8.04E-03	2.07E-02	1.94E-02	3.81E-02	4.16E-02	4.8019E+00	2.2690E+02
α_3	1.73E-03	9.08E-03	7.71E-03	2.11E-02	1.15E-02	2.1046E+00	2.2960E+02
α_4	4.70E-04	5.45E-03	4.11E-03	1.50E-02	6.63E-03	1.2623E+00	2.3044E+02
α_5	4.79E-05	2.96E-03	1.71E-03	1.01E-02	3.98E-03	6.8587E-01	2.3102E+02
α_6	1.16E-08	1.04E-03	1.69E-04	5.09E-03	1.33E-03	2.4098E-01	2.3146E+02
α_7	1.30E-38	1.59E-04	1.71E-11	7.27E-04	1.89E-04	3.6871E-02	2.3167E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9410070	0.9617910	0.9629120	0.9787410	0.9364770	2.6244E+02	1.0426E+01
α_2	7.49E-03	1.87E-02	1.75E-02	3.38E-02	3.75E-02	5.0941E+00	2.6777E+02
α_3	1.74E-03	8.35E-03	7.18E-03	1.89E-02	1.15E-02	2.2772E+00	2.7059E+02
α_4	6.02E-04	5.35E-03	4.20E-03	1.40E-02	6.71E-03	1.4599E+00	2.7141E+02
α_5	1.44E-04	3.40E-03	2.29E-03	1.04E-02	4.69E-03	9.2713E-01	2.7194E+02
α_6	5.29E-06	1.75E-03	7.62E-04	6.82E-03	2.34E-03	4.7636E-01	2.7239E+02
α_7	8.55E-12	5.65E-04	2.61E-05	3.10E-03	6.71E-04	1.5427E-01	2.7271E+02
α_8	1.54E-38	1.36E-04	1.57E-11	6.22E-04	8.36E-05	3.7024E-02	2.7283E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9723270	0.9568340	0.9468580	0.9391150	0.9320500	0.9347890	0.9364770
α_2	2.77E-02	3.65E-02	4.04E-02	4.43E-02	4.96E-02	4.16E-02	3.75E-02
α_3		6.69E-03	1.02E-02	1.04E-02	8.75E-03	1.15E-02	1.15E-02
α_4			2.55E-03	5.18E-03	6.56E-03	6.63E-03	6.71E-03
α_5				1.04E-03	2.63E-03	3.98E-03	4.69E-03
α_6					4.37E-04	1.33E-03	2.34E-03
α_7						1.89E-04	6.71E-04
α_8							8.36E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.72E-01	9.57E-01	9.47E-01	9.39E-01	9.32E-01	9.35E-01	9.36E-01
Beta	2.77E-02	4.32E-02	5.31E-02	6.09E-02	6.79E-02	6.52E-02	6.35E-02
Gamma		1.55E-01	2.40E-01	2.72E-01	2.70E-01	3.62E-01	4.10E-01
Delta			2.00E-01	3.75E-01	5.24E-01	5.14E-01	5.57E-01
Epsilon				1.67E-01	3.18E-01	4.53E-01	5.37E-01
Mu					1.43E-01	2.76E-01	3.98E-01
Upsilon						1.25E-01	2.43E-01
Sigma							1.11E-01

Air Operated Valves

2010

PWR Auxiliary Feedwater Air-Operated Valves

AFW AOV FAIL TO OPEN SPAR: AFW-AOV-CC

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	10.92	16.38	21.84	27.30	32.76	38.22	43.68
N ₁	1.4619	1.5107	1.3548	1.0253	0.5223	0.3047	0.0313
N ₂	0.3524	0.6821	0.9893	1.3363	1.7701	1.7141	1.7494
N ₃		0.1250	0.2500	0.3125	0.3125	0.4734	0.5388
N ₄			0.0625	0.1563	0.2344	0.2734	0.3134
N ₅				0.0313	0.0938	0.1641	0.2188
N ₆					0.0156	0.0547	0.1094
N ₇						0.0078	0.0313
N ₈							0.0039

1.4.3.3 AFW AOV FAIL TO CLOSE SPAR: AFW-AOV-OO

System : Auxiliary feedwater
Component : Air Operated Valve
Failure Mode : Fail to close (reseat) on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 20.50

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9022980	0.9724260	0.9850050	0.9997270	0.9849480	2.1259E+01	6.0282E-01
α_2	2.75E-04	2.76E-02	1.50E-02	9.77E-02	1.51E-02	6.0282E-01	2.1259E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9147100	0.9659630	0.9723190	0.9954300	0.9694400	4.5575E+01	1.6059E+00
α_2	2.79E-03	2.84E-02	2.20E-02	7.57E-02	3.06E-02	1.3387E+00	4.5842E+01
α_3	1.98E-07	5.66E-03	1.14E-03	2.69E-02	0.00E+00	2.6722E-01	4.6914E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9139780	0.9588830	0.9632070	0.9889980	0.9534350	6.6816E+01	2.8651E+00
α_2	6.66E-03	3.21E-02	2.77E-02	7.25E-02	4.66E-02	2.2381E+00	6.7443E+01
α_3	6.53E-06	5.80E-03	2.15E-03	2.40E-02	0.00E+00	4.0431E-01	6.9277E+01
α_4	1.38E-08	3.20E-03	4.37E-04	1.60E-02	0.00E+00	2.2267E-01	6.9458E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9333610	0.9640160	0.9664390	0.9863940	0.9621790	1.2201E+02	4.5543E+00
α_2	5.72E-03	2.21E-02	1.96E-02	4.69E-02	2.54E-02	2.7965E+00	1.2377E+02
α_3	9.66E-04	1.04E-02	7.92E-03	2.81E-02	1.24E-02	1.3111E+00	1.2525E+02
α_4	1.94E-06	2.96E-03	9.96E-04	1.26E-02	0.00E+00	3.7439E-01	1.2619E+02
α_5	4.71E-21	5.71E-04	3.23E-07	3.30E-03	0.00E+00	7.2277E-02	1.2649E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9382390	0.9654020	0.9674080	0.9857100	0.9680500	1.4794E+02	5.3019E+00
α_2	4.42E-03	1.77E-02	1.56E-02	3.79E-02	1.46E-02	2.7060E+00	1.5054E+02
α_3	1.34E-03	1.04E-02	8.32E-03	2.63E-02	1.39E-02	1.5871E+00	1.5165E+02
α_4	8.16E-05	4.59E-03	2.69E-03	1.56E-02	3.47E-03	7.0332E-01	1.5254E+02
α_5	6.06E-09	1.45E-03	1.96E-04	7.26E-03	0.00E+00	2.2220E-01	1.5302E+02
α_6	9.20E-19	5.43E-04	9.50E-07	3.17E-03	0.00E+00	8.3237E-02	1.5316E+02

PWR Auxiliary Feedwater Air-Operated Valves
 AFW AOV FAIL TO CLOSE SPAR: AFW-AOV-OO
CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9457280	0.9671620	0.9685250	0.9839570	0.9722630	2.2021E+02	7.4767E+00
α_2	4.59E-03	1.50E-02	1.36E-02	3.02E-02	8.78E-03	3.4142E+00	2.2427E+02
α_3	1.71E-03	9.12E-03	7.73E-03	2.13E-02	1.20E-02	2.0772E+00	2.2561E+02
α_4	4.23E-04	5.32E-03	3.96E-03	1.49E-02	5.98E-03	1.2112E+00	2.2648E+02
α_5	1.68E-05	2.45E-03	1.23E-03	9.05E-03	9.95E-04	5.5877E-01	2.2713E+02
α_6	2.95E-10	8.18E-04	6.98E-05	4.29E-03	0.00E+00	1.8628E-01	2.2750E+02
α_7	0.00E+00	1.28E-04	1.12E-13	4.81E-04	0.00E+00	2.9071E-02	2.2766E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9490360	0.9683400	0.9694990	0.9836930	0.9754180	2.6004E+02	8.5022E+00
α_2	4.23E-03	1.33E-02	1.21E-02	2.65E-02	5.57E-03	3.5808E+00	2.6496E+02
α_3	1.54E-03	7.95E-03	6.77E-03	1.84E-02	9.39E-03	2.1360E+00	2.6641E+02
α_4	5.93E-04	5.37E-03	4.21E-03	1.41E-02	7.00E-03	1.4429E+00	2.6710E+02
α_5	8.49E-05	3.01E-03	1.90E-03	9.70E-03	2.33E-03	8.0713E-01	2.6774E+02
α_6	1.02E-06	1.41E-03	4.82E-04	5.97E-03	2.90E-04	3.7926E-01	2.6816E+02
α_7	6.06E-14	4.58E-04	8.23E-06	2.61E-03	0.00E+00	1.2297E-01	2.6842E+02
α_8	1.14E-42	1.23E-04	1.76E-12	5.21E-04	0.00E+00	3.3124E-02	2.6851E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9849480	0.9694400	0.9534350	0.9621790	0.9680500	0.9722630	0.9754180
α_2	1.51E-02	3.06E-02	4.66E-02	2.54E-02	1.46E-02	8.78E-03	5.57E-03
α_3		0.00E+00	0.00E+00	1.24E-02	1.39E-02	1.20E-02	9.39E-03
α_4			0.00E+00	0.00E+00	3.47E-03	5.98E-03	7.00E-03
α_5				0.00E+00	0.00E+00	9.95E-04	2.33E-03
α_6					0.00E+00	0.00E+00	2.90E-04
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.85E-01	9.69E-01	9.53E-01	9.62E-01	9.68E-01	9.72E-01	9.75E-01
Beta	1.51E-02	3.06E-02	4.66E-02	3.78E-02	3.19E-02	2.77E-02	2.46E-02
Gamma		0.00E+00	0.00E+00	3.28E-01	5.44E-01	6.84E-01	7.73E-01
Delta			0.00E+00	0.00E+00	2.00E-01	3.68E-01	5.06E-01
Epsilon				0.00E+00	0.00E+00	1.43E-01	2.73E-01
Mu					0.00E+00	0.00E+00	1.11E-01
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Air Operated Valves

2010

PWR Auxiliary Feedwater Air-Operated Valves

AFW AOV FAIL TO CLOSE SPAR: AFW-AOV-OO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	10.25	15.38	20.50	25.63	30.75	35.88	41.00
N ₁	0.7633	0.6400	0.1800	0.2175	0.2523	0.2845	0.3143
N ₂	0.1683	0.5050	1.0100	0.6823	0.4668	0.3264	0.2361
N ₃		0.0000	0.0000	0.3337	0.4453	0.4460	0.3976
N ₄			0.0000	0.0000	0.1111	0.2223	0.2964
N ₅				0.0000	0.0000	0.0370	0.0988
N ₆					0.0000	0.0000	0.0123
N ₇						0.0000	0.0000
N ₈							0.0000

High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated Valves

COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO OPEN/CLOSE

1.4.4 High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated Valves

1.4.4.1 COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO OPEN/CLOSE

System :	High pressure coolant injection Reactor core isolation
Component :	Air Operated Valve
Failure Mode :	Fail to close (reseat) on demand Fail to Open/Close Mode Unspecified (demand based)
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 3.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8734960	0.9682380	0.9867710	0.9999360	1.0000000	1.3246E+01	4.3452E-01
α_2	5.92E-05	3.18E-02	1.32E-02	1.27E-01	0.00E+00	4.3452E-01	1.3246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9068390	0.9672900	0.9760300	0.9978250	1.0000000	3.2555E+01	1.1009E+00
α_2	7.91E-04	2.48E-02	1.62E-02	7.82E-02	0.00E+00	8.3366E-01	3.2822E+01
α_3	2.80E-07	7.94E-03	1.61E-03	3.77E-02	0.00E+00	2.6722E-01	3.3389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9130680	0.9636200	0.9695110	0.9939910	1.0000000	4.9136E+01	1.8551E+00
α_2	2.00E-03	2.41E-02	1.82E-02	6.63E-02	0.00E+00	1.2281E+00	4.9763E+01
α_3	8.95E-06	7.93E-03	2.95E-03	3.27E-02	0.00E+00	4.0431E-01	5.0587E+01
α_4	1.89E-08	4.37E-03	5.99E-04	2.19E-02	0.00E+00	2.2267E-01	5.0768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9318350	0.9655480	0.9685320	0.9890570	1.0000000	9.9161E+01	3.5382E+00
α_2	3.97E-03	2.06E-02	1.76E-02	4.76E-02	0.00E+00	2.1142E+00	1.0059E+02
α_3	4.65E-04	9.52E-03	6.58E-03	2.86E-02	0.00E+00	9.7738E-01	1.0172E+02
α_4	2.40E-06	3.65E-03	1.23E-03	1.55E-02	0.00E+00	3.7439E-01	1.0232E+02
α_5	5.81E-21	7.04E-04	3.98E-07	4.08E-03	0.00E+00	7.2277E-02	1.0263E+02

High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated
Valves

COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO OPEN/CLOSE

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9351640	0.9655550	0.9680290	0.9874920	1.0000000	1.1994E+02	4.2787E+00
α_2	3.71E-03	1.80E-02	1.55E-02	4.10E-02	0.00E+00	2.2392E+00	1.2198E+02
α_3	6.48E-04	9.19E-03	6.73E-03	2.62E-02	0.00E+00	1.1418E+00	1.2308E+02
α_4	4.26E-05	4.77E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2363E+02
α_5	7.48E-09	1.79E-03	2.43E-04	8.96E-03	0.00E+00	2.2220E-01	1.2400E+02
α_6	1.14E-18	6.70E-04	1.17E-06	3.91E-03	0.00E+00	8.3237E-02	1.2414E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	3.00	3.00	3.00	3.00	3.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.4.4.2 COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO OPEN

System : High pressure coolant injection
 Reactor core isolation

Component : Air Operated Valve
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 3.00

Total Number of Common-Cause Failure Events: 0

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8734960	0.9682380	0.9867710	0.9999360	1.0000000	1.3246E+01	4.3452E-01
α_2	5.92E-05	3.18E-02	1.32E-02	1.27E-01	0.00E+00	4.3452E-01	1.3246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9068390	0.9672900	0.9760300	0.9978250	1.0000000	3.2555E+01	1.1009E+00
α_2	7.91E-04	2.48E-02	1.62E-02	7.82E-02	0.00E+00	8.3366E-01	3.2822E+01
α_3	2.80E-07	7.94E-03	1.61E-03	3.77E-02	0.00E+00	2.6722E-01	3.3389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9130680	0.9636200	0.9695110	0.9939910	1.0000000	4.9136E+01	1.8551E+00
α_2	2.00E-03	2.41E-02	1.82E-02	6.63E-02	0.00E+00	1.2281E+00	4.9763E+01
α_3	8.95E-06	7.93E-03	2.95E-03	3.27E-02	0.00E+00	4.0431E-01	5.0587E+01
α_4	1.89E-08	4.37E-03	5.99E-04	2.19E-02	0.00E+00	2.2267E-01	5.0768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9318350	0.9655480	0.9685320	0.9890570	1.0000000	9.9161E+01	3.5382E+00
α_2	3.97E-03	2.06E-02	1.76E-02	4.76E-02	0.00E+00	2.1142E+00	1.0059E+02
α_3	4.65E-04	9.52E-03	6.58E-03	2.86E-02	0.00E+00	9.7738E-01	1.0172E+02
α_4	2.40E-06	3.65E-03	1.23E-03	1.55E-02	0.00E+00	3.7439E-01	1.0232E+02
α_5	5.81E-21	7.04E-04	3.98E-07	4.08E-03	0.00E+00	7.2277E-02	1.0263E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9351640	0.9655550	0.9680290	0.9874920	1.0000000	1.1994E+02	4.2787E+00
α_2	3.71E-03	1.80E-02	1.55E-02	4.10E-02	0.00E+00	2.2392E+00	1.2198E+02
α_3	6.48E-04	9.19E-03	6.73E-03	2.62E-02	0.00E+00	1.1418E+00	1.2308E+02
α_4	4.26E-05	4.77E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2363E+02
α_5	7.48E-09	1.79E-03	2.43E-04	8.96E-03	0.00E+00	2.2220E-01	1.2400E+02
α_6	1.14E-18	6.70E-04	1.17E-06	3.91E-03	0.00E+00	8.3237E-02	1.2414E+02

COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO OPEN

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	3.00	3.00	3.00	3.00	3.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.4.4.3 COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO CLOSE

System : High pressure coolant injection
 Reactor core isolation

Component : Air Operated Valve

Failure Mode : Fail to close (reseat) on demand

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
α_2	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
α_2	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
α_3	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
α_2	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
α_3	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
α_4	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
α_2	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
α_3	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
α_4	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
α_5	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
α_2	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
α_3	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
α_4	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
α_5	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
α_6	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated
Valves

COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO CLOSE

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.5 Check Valves

1.5.1 Pooled Check Valves

1.5.1.1 CHECK VALVE FAIL TO OPEN ALL SYSTEMS SPAR: CKV-CC

Component : Check Valve
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 8.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9069840	0.9767390	0.9904340	0.9999540	1.0000000	1.8246E+01	4.3452E-01
α_2	4.27E-05	2.33E-02	9.56E-03	9.30E-02	0.00E+00	4.3452E-01	1.8246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9187120	0.9715210	0.9791840	0.9981180	1.0000000	3.7555E+01	1.1009E+00
α_2	6.87E-04	2.16E-02	1.40E-02	6.82E-02	0.00E+00	8.3366E-01	3.7822E+01
α_3	2.43E-07	6.91E-03	1.40E-03	3.28E-02	0.00E+00	2.6722E-01	3.8389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9207150	0.9668680	0.9722640	0.9945410	1.0000000	5.4136E+01	1.8551E+00
α_2	1.82E-03	2.19E-02	1.65E-02	6.05E-02	0.00E+00	1.2281E+00	5.4763E+01
α_3	8.14E-06	7.22E-03	2.68E-03	2.98E-02	0.00E+00	4.0431E-01	5.5587E+01
α_4	1.72E-08	3.98E-03	5.45E-04	1.99E-02	0.00E+00	2.2267E-01	5.5768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9349600	0.9671470	0.9699980	0.9895730	1.0000000	1.0416E+02	3.5382E+00
α_2	3.78E-03	1.96E-02	1.67E-02	4.54E-02	0.00E+00	2.1142E+00	1.0558E+02
α_3	4.43E-04	9.08E-03	6.27E-03	2.73E-02	0.00E+00	9.7738E-01	1.0672E+02
α_4	2.29E-06	3.48E-03	1.17E-03	1.48E-02	0.00E+00	3.7439E-01	1.0732E+02
α_5	5.54E-21	6.71E-04	3.80E-07	3.89E-03	0.00E+00	7.2277E-02	1.0763E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9376440	0.9668880	0.9692700	0.9879830	1.0000000	1.2494E+02	4.2787E+00
α_2	3.56E-03	1.73E-02	1.49E-02	3.94E-02	0.00E+00	2.2392E+00	1.2698E+02
α_3	6.22E-04	8.84E-03	6.46E-03	2.52E-02	0.00E+00	1.1418E+00	1.2808E+02
α_4	4.10E-05	4.58E-03	2.40E-03	1.65E-02	0.00E+00	5.9222E-01	1.2863E+02
α_5	7.19E-09	1.72E-03	2.33E-04	8.62E-03	0.00E+00	2.2220E-01	1.2900E+02
α_6	1.09E-18	6.44E-04	1.13E-06	3.76E-03	0.00E+00	8.3237E-02	1.2914E+02

Pooled Check Valves

CHECK VALVE FAIL TO OPEN ALL SYSTEMS SPAR: CKV-CC

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9445570	0.9675310	0.9690930	0.9851770	1.0000000	1.9205E+02	6.4450E+00
α_2	4.38E-03	1.56E-02	1.40E-02	3.22E-02	0.00E+00	3.0878E+00	1.9541E+02
α_3	1.11E-03	8.22E-03	6.64E-03	2.07E-02	0.00E+00	1.6312E+00	1.9686E+02
α_4	2.50E-04	4.98E-03	3.45E-03	1.49E-02	0.00E+00	9.8887E-01	1.9751E+02
α_5	1.29E-05	2.63E-03	1.24E-03	9.93E-03	0.00E+00	5.2177E-01	1.9797E+02
α_6	3.39E-10	9.38E-04	8.01E-05	4.93E-03	0.00E+00	1.8628E-01	1.9831E+02
α_7	0.00E+00	1.46E-04	1.28E-13	5.51E-04	0.00E+00	2.9071E-02	1.9847E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9473090	0.9681410	0.9694650	0.9844540	1.0000000	2.2673E+02	7.4610E+00
α_2	4.30E-03	1.43E-02	1.29E-02	2.89E-02	0.00E+00	3.3447E+00	2.3085E+02
α_3	1.10E-03	7.42E-03	6.08E-03	1.84E-02	0.00E+00	1.7384E+00	2.3245E+02
α_4	3.47E-04	4.90E-03	3.58E-03	1.39E-02	0.00E+00	1.1465E+00	2.3304E+02
α_5	5.51E-05	3.02E-03	1.78E-03	1.02E-02	0.00E+00	7.0833E-01	2.3348E+02
α_6	8.87E-07	1.57E-03	5.13E-04	6.70E-03	0.00E+00	3.6696E-01	2.3382E+02
α_7	6.95E-14	5.25E-04	9.44E-06	2.99E-03	0.00E+00	1.2297E-01	2.3407E+02
α_8	1.30E-42	1.41E-04	2.02E-12	5.98E-04	0.00E+00	3.3124E-02	2.3416E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Pooled Check Valves

CHECK VALVE FAIL TO OPEN ALL SYSTEMS SPAR: CKV-CC

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	8.00	8.00	8.00	8.00	8.00	8.00	8.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.5.1.2 CHECK VALVE FAIL TO CLOSE ALL SYSTEMS SPAR:CKV-OO**Component :**

Check Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 37.00

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8693950	0.9492330	0.9594150	0.9941760	0.9431720	2.7009E+01	1.4445E+00
α_2	5.82E-03	5.08E-02	4.06E-02	1.31E-01	5.68E-02	1.4445E+00	2.7009E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9142230	0.9625010	0.9678000	0.9926280	0.9606420	5.4680E+01	2.1303E+00
α_2	2.43E-03	2.40E-02	1.87E-02	6.38E-02	2.02E-02	1.3628E+00	5.5448E+01
α_3	3.28E-04	1.35E-02	8.38E-03	4.42E-02	1.91E-02	7.6752E-01	5.6043E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9263150	0.9646970	0.9683930	0.9904440	0.9693570	7.9595E+01	2.9128E+00
α_2	2.30E-03	1.86E-02	1.49E-02	4.77E-02	8.88E-03	1.5347E+00	8.0973E+01
α_3	4.38E-04	1.10E-02	7.35E-03	3.39E-02	1.45E-02	9.0541E-01	8.1602E+01
α_4	1.67E-05	5.73E-03	2.49E-03	2.24E-02	7.24E-03	4.7267E-01	8.2035E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9400120	0.9675070	0.9696700	0.9876020	0.9744740	1.3794E+02	4.6326E+00
α_2	3.51E-03	1.63E-02	1.41E-02	3.67E-02	5.05E-03	2.3306E+00	1.4024E+02
α_3	9.42E-04	9.51E-03	7.33E-03	2.55E-02	8.82E-03	1.3553E+00	1.4122E+02
α_4	1.17E-04	5.26E-03	3.20E-03	1.74E-02	8.75E-03	7.4939E-01	1.4182E+02
α_5	1.17E-09	1.38E-03	1.39E-04	7.16E-03	2.92E-03	1.9728E-01	1.4238E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9441460	0.9685840	0.9703780	0.9868810	0.9777680	1.6702E+02	5.4173E+00
α_2	3.17E-03	1.41E-02	1.23E-02	3.13E-02	3.82E-03	2.4346E+00	1.7000E+02
α_3	8.48E-04	8.10E-03	6.30E-03	2.15E-02	4.99E-03	1.3975E+00	1.7104E+02
α_4	2.66E-04	5.61E-03	3.85E-03	1.70E-02	7.32E-03	9.6722E-01	1.7147E+02
α_5	7.92E-06	2.74E-03	1.19E-03	1.07E-02	4.88E-03	4.7220E-01	1.7197E+02
α_6	4.32E-12	8.45E-04	3.16E-05	4.68E-03	1.22E-03	1.4574E-01	1.7229E+02

Pooled Check Valves

CHECK VALVE FAIL TO CLOSE ALL SYSTEMS SPAR:CKV-OO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9497250	0.9694660	0.9707080	0.9849580	0.9800170	2.4242E+02	7.6352E+00
α_2	3.92E-03	1.32E-02	1.19E-02	2.68E-02	3.55E-03	3.2991E+00	2.4676E+02
α_3	1.11E-03	7.19E-03	5.92E-03	1.76E-02	2.79E-03	1.7975E+00	2.4826E+02
α_4	4.77E-04	5.20E-03	3.96E-03	1.42E-02	5.25E-03	1.3014E+00	2.4875E+02
α_5	1.04E-04	3.34E-03	2.14E-03	1.06E-02	5.25E-03	8.3427E-01	2.4922E+02
α_6	4.58E-07	1.37E-03	4.09E-04	6.00E-03	2.62E-03	3.4258E-01	2.4971E+02
α_7	6.65E-25	2.41E-04	2.44E-08	1.36E-03	5.26E-04	6.0371E-02	2.4999E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9525820	0.9704220	0.9714810	0.9846380	0.9817730	2.8538E+02	8.6984E+00
α_2	3.85E-03	1.22E-02	1.11E-02	2.42E-02	3.42E-03	3.5771E+00	2.9050E+02
α_3	1.02E-03	6.30E-03	5.22E-03	1.53E-02	1.67E-03	1.8521E+00	2.9223E+02
α_4	4.80E-04	4.70E-03	3.63E-03	1.26E-02	3.46E-03	1.3815E+00	2.9270E+02
α_5	1.88E-04	3.47E-03	2.43E-03	1.03E-02	4.60E-03	1.0208E+00	2.9306E+02
α_6	1.95E-05	2.04E-03	1.08E-03	7.35E-03	3.45E-03	6.0136E-01	2.9348E+02
α_7	2.24E-09	7.37E-04	9.40E-05	3.72E-03	1.38E-03	2.1677E-01	2.9386E+02
α_8	3.95E-30	1.66E-04	1.32E-09	8.74E-04	2.30E-04	4.8724E-02	2.9403E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9431720	0.9606420	0.9693570	0.9744740	0.9777680	0.9800170	0.9817730
α_2	5.68E-02	2.02E-02	8.88E-03	5.05E-03	3.82E-03	3.55E-03	3.42E-03
α_3		1.91E-02	1.45E-02	8.82E-03	4.99E-03	2.79E-03	1.67E-03
α_4			7.24E-03	8.75E-03	7.32E-03	5.25E-03	3.46E-03
α_5				2.92E-03	4.88E-03	5.25E-03	4.60E-03
α_6					1.22E-03	2.62E-03	3.45E-03
α_7						5.26E-04	1.38E-03
α_8							2.30E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.43E-01	9.61E-01	9.69E-01	9.74E-01	9.78E-01	9.80E-01	9.82E-01
Beta	5.68E-02	3.94E-02	3.06E-02	2.55E-02	2.22E-02	2.00E-02	1.82E-02
Gamma		4.86E-01	7.10E-01	8.02E-01	8.28E-01	8.22E-01	8.12E-01
Delta			3.33E-01	5.70E-01	7.29E-01	8.30E-01	8.87E-01
Epsilon				2.50E-01	4.55E-01	6.15E-01	7.36E-01
Mu					2.00E-01	3.75E-01	5.24E-01
Upsilon						1.67E-01	3.18E-01
Sigma							1.43E-01

Pooled Check Valves

CHECK VALVE FAIL TO CLOSE ALL SYSTEMS SPAR:CKV-OO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	16.44	24.67	32.89	41.11	49.33	57.56	65.78
N ₁	0.3229	0.4551	0.5691	0.6657	0.7457	0.8100	0.8717
N ₂	1.0100	0.5291	0.3066	0.2164	0.1954	0.2113	0.2324
N ₃		0.5003	0.5011	0.3779	0.2557	0.1663	0.1137
N ₄			0.2500	0.3750	0.3750	0.3125	0.2350
N ₅				0.1250	0.2500	0.3125	0.3125
N ₆					0.0625	0.1563	0.2344
N ₇						0.0313	0.0938
N ₈							0.0156

1.5.1.3 CHECK VALVE FAIL TO REMAIN CLOSED ALL SYSTEMS SPAR:CKV-CO

Component :

Check Valve

Failure Mode :

Spurious operation open or close

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
α_2	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
α_2	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
α_3	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
α_2	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
α_3	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
α_4	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
α_2	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
α_3	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
α_4	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
α_5	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
α_2	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
α_3	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
α_4	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
α_5	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
α_6	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

Pooled Check Valves

CHECK VALVE FAIL TO REMAIN CLOSED ALL SYSTEMS SPAR:CKV-CO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9422570	0.9661670	0.9677850	0.9845420	1.0000000	1.8405E+02	6.4450E+00
α_2	4.57E-03	1.62E-02	1.45E-02	3.35E-02	0.00E+00	3.0878E+00	1.8741E+02
α_3	1.15E-03	8.56E-03	6.91E-03	2.16E-02	0.00E+00	1.6312E+00	1.8886E+02
α_4	2.60E-04	5.19E-03	3.59E-03	1.56E-02	0.00E+00	9.8887E-01	1.8951E+02
α_5	1.35E-05	2.74E-03	1.30E-03	1.04E-02	0.00E+00	5.2177E-01	1.8997E+02
α_6	3.53E-10	9.78E-04	8.35E-05	5.13E-03	0.00E+00	1.8628E-01	1.9031E+02
α_7	0.00E+00	1.53E-04	1.34E-13	5.75E-04	0.00E+00	2.9071E-02	1.9047E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9454620	0.9670150	0.9683850	0.9838980	1.0000000	2.1873E+02	7.4610E+00
α_2	4.45E-03	1.48E-02	1.34E-02	2.99E-02	0.00E+00	3.3447E+00	2.2285E+02
α_3	1.14E-03	7.69E-03	6.29E-03	1.90E-02	0.00E+00	1.7384E+00	2.2445E+02
α_4	3.59E-04	5.07E-03	3.71E-03	1.44E-02	0.00E+00	1.1465E+00	2.2504E+02
α_5	5.70E-05	3.13E-03	1.84E-03	1.06E-02	0.00E+00	7.0833E-01	2.2548E+02
α_6	9.18E-07	1.62E-03	5.31E-04	6.94E-03	0.00E+00	3.6696E-01	2.2582E+02
α_7	7.20E-14	5.44E-04	9.78E-06	3.10E-03	0.00E+00	1.2297E-01	2.2607E+02
α_8	1.35E-42	1.46E-04	2.09E-12	6.19E-04	0.00E+00	3.3124E-02	2.2616E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	0.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Pooled Check Valves

CHECK VALVE FAIL TO REMAIN CLOSED ALL SYSTEMS SPAR:CKV-CO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00	0.00	0.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.5.1.4 CKV FAIL TO REMAIN CLOSED (LEAKAGE) ALL SYSTEMS SPAR:CKV-CO

Component :

Check Valve

Failure Mode :

Fail to remain closed(detectable leakage)

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 44.50

Total Number of Common-Cause Failure Events: 7

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.7881420	0.8849500	0.8920470	0.9574400	0.8537550	3.1985E+01	4.1583E+00
α_2	4.26E-02	1.15E-01	1.08E-01	2.12E-01	1.46E-01	4.1583E+00	3.1985E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8497360	0.9125510	0.9166750	0.9612580	0.8684710	6.0683E+01	5.8152E+00
α_2	1.52E-02	4.99E-02	4.55E-02	9.99E-02	6.94E-02	3.3194E+00	6.3179E+01
α_3	8.78E-03	3.75E-02	3.30E-02	8.19E-02	6.22E-02	2.4958E+00	6.4002E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8686360	0.9192150	0.9221830	0.9596440	0.8751490	8.6291E+01	7.5837E+00
α_2	1.33E-02	4.00E-02	3.68E-02	7.78E-02	5.51E-02	3.7567E+00	9.0118E+01
α_3	6.36E-03	2.70E-02	2.37E-02	5.88E-02	4.64E-02	2.5329E+00	9.1342E+01
α_4	1.26E-03	1.38E-02	1.05E-02	3.75E-02	2.34E-02	1.2941E+00	9.2581E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8988560	0.9343250	0.9361810	0.9634390	0.8802890	1.4518E+02	1.0205E+01
α_2	1.17E-02	3.03E-02	2.83E-02	5.58E-02	4.66E-02	4.7094E+00	1.5068E+02
α_3	5.36E-03	1.94E-02	1.74E-02	4.03E-02	3.66E-02	3.0131E+00	1.5237E+02
α_4	2.03E-03	1.22E-02	1.02E-02	2.92E-02	2.73E-02	1.8923E+00	1.5349E+02
α_5	3.34E-05	3.80E-03	1.98E-03	1.37E-02	9.30E-03	5.9018E-01	1.5479E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9085170	0.9395700	0.9411390	0.9652700	0.8930000	1.7536E+02	1.1279E+01
α_2	7.75E-03	2.20E-02	2.04E-02	4.21E-02	2.87E-02	4.1142E+00	1.8252E+02
α_3	5.49E-03	1.81E-02	1.64E-02	3.65E-02	3.41E-02	3.3739E+00	1.8326E+02
α_4	2.49E-03	1.21E-02	1.04E-02	2.74E-02	2.54E-02	2.2529E+00	1.8439E+02
α_5	5.07E-04	6.45E-03	4.80E-03	1.81E-02	1.50E-02	1.2043E+00	1.8543E+02
α_6	4.77E-07	1.79E-03	5.13E-04	7.89E-03	3.82E-03	3.3324E-01	1.8631E+02

Pooled Check Valves

CKV FAIL TO REMAIN CLOSED (LEAKAGE) ALL SYSTEMS SPAR:CKV-CO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9255470	0.9493890	0.9505160	0.9693910	0.9068650	2.5221E+02	1.3445E+01
α_2	6.33E-03	1.70E-02	1.58E-02	3.17E-02	1.90E-02	4.5128E+00	2.6114E+02
α_3	3.45E-03	1.20E-02	1.08E-02	2.46E-02	2.06E-02	3.1812E+00	2.6247E+02
α_4	3.00E-03	1.11E-02	9.91E-03	2.33E-02	2.61E-02	2.9514E+00	2.6270E+02
α_5	1.19E-03	7.14E-03	5.95E-03	1.72E-02	1.83E-02	1.8968E+00	2.6376E+02
α_6	6.23E-05	2.82E-03	1.71E-03	9.35E-03	7.48E-03	7.4878E-01	2.6491E+02
α_7	8.57E-12	5.80E-04	2.67E-05	3.18E-03	1.66E-03	1.5407E-01	2.6550E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9323950	0.9535150	0.9544860	0.9713300	0.9175500	2.9663E+02	1.4461E+01
α_2	5.26E-03	1.43E-02	1.32E-02	2.68E-02	1.29E-02	4.4378E+00	3.0665E+02
α_3	2.74E-03	9.83E-03	8.80E-03	2.04E-02	1.56E-02	3.0590E+00	3.0803E+02
α_4	1.75E-03	7.82E-03	6.79E-03	1.74E-02	1.51E-02	2.4321E+00	3.0866E+02
α_5	2.35E-03	9.07E-03	8.04E-03	1.93E-02	2.49E-02	2.8214E+00	3.0827E+02
α_6	2.62E-04	3.69E-03	2.70E-03	1.05E-02	9.20E-03	1.1483E+00	3.0994E+02
α_7	4.06E-06	1.50E-03	6.42E-04	5.90E-03	4.05E-03	4.6677E-01	3.1062E+02
α_8	4.83E-17	3.07E-04	1.39E-06	1.79E-03	7.36E-04	9.5624E-02	3.1100E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.8537550	0.8684710	0.8751490	0.8802890	0.8930000	0.9068650	0.9175500
α_2	1.46E-01	6.94E-02	5.51E-02	4.66E-02	2.87E-02	1.90E-02	1.29E-02
α_3		6.22E-02	4.64E-02	3.66E-02	3.41E-02	2.06E-02	1.56E-02
α_4			2.34E-02	2.73E-02	2.54E-02	2.61E-02	1.51E-02
α_5				9.30E-03	1.50E-02	1.83E-02	2.49E-02
α_6					3.82E-03	7.48E-03	9.20E-03
α_7						1.66E-03	4.05E-03
α_8							7.36E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	8.54E-01	8.68E-01	8.75E-01	8.80E-01	8.93E-01	9.07E-01	9.18E-01
Beta	1.46E-01	1.32E-01	1.25E-01	1.20E-01	1.07E-01	9.31E-02	8.24E-02
Gamma		4.73E-01	5.59E-01	6.11E-01	7.32E-01	7.96E-01	8.44E-01
Delta			3.35E-01	5.00E-01	5.64E-01	7.22E-01	7.76E-01
Epsilon				2.54E-01	4.26E-01	5.12E-01	7.20E-01
Mu					2.03E-01	3.33E-01	3.60E-01
Upsilon						1.82E-01	3.42E-01
Sigma							1.54E-01

Pooled Check Valves

CKV FAIL TO REMAIN CLOSED (LEAKAGE) ALL SYSTEMS SPAR:CKV-CO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	19.47	29.21	38.95	48.69	58.42	68.16	77.90
N ₁	2.2690	1.9179	1.2048	0.3333	0.0000	0.0000	0.0000
N ₂	3.7238	2.4857	2.5286	2.5952	1.8750	1.4250	1.0931
N ₃		2.2286	2.1286	2.0357	2.2321	1.5500	1.3206
N ₄			1.0714	1.5179	1.6607	1.9625	1.2856
N ₅				0.5179	0.9821	1.3750	2.1131
N ₆					0.2500	0.5625	0.7813
N ₇						0.1250	0.3438
N ₈							0.0625

BWR Residual Heat Removal Check Valves

BWR RHR CHECK VALVE FAIL TO OPEN

1.5.2 BWR Residual Heat Removal Check Valves**1.5.2.1 BWR RHR CHECK VALVE FAIL TO OPEN**

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Check Valve
Failure Mode :	Fail to open on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
α_2	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
α_2	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
α_3	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
α_2	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
α_3	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
α_4	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9311740	0.9652090	0.9682200	0.9889480	1.0000000	9.8161E+01	3.5382E+00
α_2	4.01E-03	2.08E-02	1.77E-02	4.80E-02	0.00E+00	2.1142E+00	9.9585E+01
α_3	4.70E-04	9.61E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0072E+02
α_4	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0132E+02
α_5	5.87E-21	7.11E-04	4.02E-07	4.12E-03	0.00E+00	7.2277E-02	1.0163E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9346440	0.9652760	0.9677640	0.9873890	1.0000000	1.1894E+02	4.2787E+00
α_2	3.74E-03	1.82E-02	1.56E-02	4.13E-02	0.00E+00	2.2392E+00	1.2098E+02
α_3	6.53E-04	9.27E-03	6.78E-03	2.64E-02	0.00E+00	1.1418E+00	1.2208E+02
α_4	4.30E-05	4.81E-03	2.52E-03	1.73E-02	0.00E+00	5.9222E-01	1.2263E+02
α_5	7.54E-09	1.80E-03	2.45E-04	9.04E-03	0.00E+00	2.2220E-01	1.2300E+02
α_6	1.14E-18	6.76E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2314E+02

BWR Residual Heat Removal Check Valves

BWR RHR CHECK VALVE FAIL TO OPEN

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9428470	0.9665190	0.9681250	0.9847050	1.0000000	1.8605E+02	6.4450E+00
α_2	4.52E-03	1.60E-02	1.44E-02	3.32E-02	0.00E+00	3.0878E+00	1.8941E+02
α_3	1.14E-03	8.47E-03	6.84E-03	2.14E-02	0.00E+00	1.6312E+00	1.9086E+02
α_4	2.57E-04	5.14E-03	3.56E-03	1.54E-02	0.00E+00	9.8887E-01	1.9151E+02
α_5	1.33E-05	2.71E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9197E+02
α_6	3.49E-10	9.68E-04	8.26E-05	5.08E-03	0.00E+00	1.8628E-01	1.9231E+02
α_7	0.00E+00	1.51E-04	1.32E-13	5.69E-04	0.00E+00	2.9071E-02	1.9247E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9459360	0.9673040	0.9686640	0.9840410	1.0000000	2.2073E+02	7.4610E+00
α_2	4.41E-03	1.47E-02	1.33E-02	2.97E-02	0.00E+00	3.3447E+00	2.2485E+02
α_3	1.13E-03	7.62E-03	6.24E-03	1.88E-02	0.00E+00	1.7384E+00	2.2645E+02
α_4	3.56E-04	5.02E-03	3.67E-03	1.43E-02	0.00E+00	1.1465E+00	2.2704E+02
α_5	5.65E-05	3.10E-03	1.82E-03	1.05E-02	0.00E+00	7.0833E-01	2.2748E+02
α_6	9.10E-07	1.61E-03	5.27E-04	6.88E-03	0.00E+00	3.6696E-01	2.2782E+02
α_7	7.14E-14	5.39E-04	9.69E-06	3.07E-03	0.00E+00	1.2297E-01	2.2807E+02
α_8	1.34E-42	1.45E-04	2.07E-12	6.14E-04	0.00E+00	3.3124E-02	2.2816E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

BWR Residual Heat Removal Check Valves

BWR RHR CHECK VALVE FAIL TO OPEN

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.00	2.00	2.00	2.00	2.00	2.00	2.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

BWR Residual Heat Removal Check Valves

BWR RHR CHECK VALVE FAIL TO CLOSE

1.5.2.2 BWR RHR CHECK VALVE FAIL TO CLOSE

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Check Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8959650	0.9739500	0.9892430	0.9999480	1.0000000	1.6246E+01	4.3452E-01
α_2	4.81E-05	2.60E-02	1.08E-02	1.04E-01	0.00E+00	4.3452E-01	1.6246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9143470	0.9699670	0.9780280	0.9980130	1.0000000	3.5555E+01	1.1009E+00
α_2	7.25E-04	2.27E-02	1.48E-02	7.18E-02	0.00E+00	8.3366E-01	3.5822E+01
α_3	2.56E-07	7.29E-03	1.48E-03	3.46E-02	0.00E+00	2.6722E-01	3.6389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9178250	0.9656410	0.9712250	0.9943340	1.0000000	5.2136E+01	1.8551E+00
α_2	1.89E-03	2.27E-02	1.72E-02	6.27E-02	0.00E+00	1.2281E+00	5.2763E+01
α_3	8.45E-06	7.49E-03	2.78E-03	3.09E-02	0.00E+00	4.0431E-01	5.3587E+01
α_4	1.78E-08	4.12E-03	5.66E-04	2.07E-02	0.00E+00	2.2267E-01	5.3768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9337450	0.9665250	0.9694270	0.9893730	1.0000000	1.0216E+02	3.5382E+00
α_2	3.85E-03	2.00E-02	1.71E-02	4.62E-02	0.00E+00	2.1142E+00	1.0358E+02
α_3	4.52E-04	9.25E-03	6.39E-03	2.78E-02	0.00E+00	9.7738E-01	1.0472E+02
α_4	2.33E-06	3.54E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0532E+02
α_5	5.65E-21	6.84E-04	3.87E-07	3.96E-03	0.00E+00	7.2277E-02	1.0563E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9366750	0.9663680	0.9687880	0.9877920	1.0000000	1.2294E+02	4.2787E+00
α_2	3.62E-03	1.76E-02	1.51E-02	4.00E-02	0.00E+00	2.2392E+00	1.2498E+02
α_3	6.32E-04	8.98E-03	6.57E-03	2.55E-02	0.00E+00	1.1418E+00	1.2608E+02
α_4	4.16E-05	4.66E-03	2.44E-03	1.68E-02	0.00E+00	5.9222E-01	1.2663E+02
α_5	7.30E-09	1.75E-03	2.37E-04	8.75E-03	0.00E+00	2.2220E-01	1.2700E+02
α_6	1.11E-18	6.54E-04	1.14E-06	3.82E-03	0.00E+00	8.3237E-02	1.2714E+02

BWR Residual Heat Removal Check Valves

BWR RHR CHECK VALVE FAIL TO CLOSE

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9439980	0.9672000	0.9687770	0.9850250	1.0000000	1.9005E+02	6.4450E+00
α_2	4.43E-03	1.57E-02	1.41E-02	3.25E-02	0.00E+00	3.0878E+00	1.9341E+02
α_3	1.12E-03	8.30E-03	6.70E-03	2.10E-02	0.00E+00	1.6312E+00	1.9486E+02
α_4	2.52E-04	5.03E-03	3.48E-03	1.51E-02	0.00E+00	9.8887E-01	1.9551E+02
α_5	1.31E-05	2.66E-03	1.26E-03	1.00E-02	0.00E+00	5.2177E-01	1.9597E+02
α_6	3.42E-10	9.48E-04	8.09E-05	4.98E-03	0.00E+00	1.8628E-01	1.9631E+02
α_7	0.00E+00	1.48E-04	1.30E-13	5.57E-04	0.00E+00	2.9071E-02	1.9647E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9468590	0.9678670	0.9692050	0.9843190	1.0000000	2.2473E+02	7.4610E+00
α_2	4.33E-03	1.44E-02	1.30E-02	2.92E-02	0.00E+00	3.3447E+00	2.2885E+02
α_3	1.11E-03	7.49E-03	6.13E-03	1.85E-02	0.00E+00	1.7384E+00	2.3045E+02
α_4	3.50E-04	4.94E-03	3.61E-03	1.41E-02	0.00E+00	1.1465E+00	2.3104E+02
α_5	5.55E-05	3.05E-03	1.79E-03	1.03E-02	0.00E+00	7.0833E-01	2.3148E+02
α_6	8.95E-07	1.58E-03	5.17E-04	6.76E-03	0.00E+00	3.6696E-01	2.3182E+02
α_7	7.01E-14	5.30E-04	9.53E-06	3.02E-03	0.00E+00	1.2297E-01	2.3207E+02
α_8	1.31E-42	1.43E-04	2.03E-12	6.03E-04	0.00E+00	3.3124E-02	2.3216E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

BWR Residual Heat Removal Check Valves

BWR RHR CHECK VALVE FAIL TO CLOSE

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	6.00	6.00	6.00	6.00	6.00	6.00	6.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

PWR Auxiliary Feedwater Check Valves

CHECK VALVE FAIL TO OPEN SPAR: AFW-CKV-CC

1.5.3 PWR Auxiliary Feedwater Check Valves

1.5.3.1 CHECK VALVE FAIL TO OPEN SPAR: AFW-CKV-CC

System :	Auxiliary feedwater
Component :	Check Valve
Failure Mode :	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
α_2	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
α_2	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
α_3	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
α_2	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
α_3	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
α_4	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9311740	0.9652090	0.9682200	0.9889480	1.0000000	9.8161E+01	3.5382E+00
α_2	4.01E-03	2.08E-02	1.77E-02	4.80E-02	0.00E+00	2.1142E+00	9.9585E+01
α_3	4.70E-04	9.61E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0072E+02
α_4	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0132E+02
α_5	5.87E-21	7.11E-04	4.02E-07	4.12E-03	0.00E+00	7.2277E-02	1.0163E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9346440	0.9652760	0.9677640	0.9873890	1.0000000	1.1894E+02	4.2787E+00
α_2	3.74E-03	1.82E-02	1.56E-02	4.13E-02	0.00E+00	2.2392E+00	1.2098E+02
α_3	6.53E-04	9.27E-03	6.78E-03	2.64E-02	0.00E+00	1.1418E+00	1.2208E+02
α_4	4.30E-05	4.81E-03	2.52E-03	1.73E-02	0.00E+00	5.9222E-01	1.2263E+02
α_5	7.54E-09	1.80E-03	2.45E-04	9.04E-03	0.00E+00	2.2220E-01	1.2300E+02
α_6	1.14E-18	6.76E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2314E+02

PWR Auxiliary Feedwater Check Valves

CHECK VALVE FAIL TO OPEN SPAR: AFW-CKV-CC

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9428470	0.9665190	0.9681250	0.9847050	1.0000000	1.8605E+02	6.4450E+00
α_2	4.52E-03	1.60E-02	1.44E-02	3.32E-02	0.00E+00	3.0878E+00	1.8941E+02
α_3	1.14E-03	8.47E-03	6.84E-03	2.14E-02	0.00E+00	1.6312E+00	1.9086E+02
α_4	2.57E-04	5.14E-03	3.56E-03	1.54E-02	0.00E+00	9.8887E-01	1.9151E+02
α_5	1.33E-05	2.71E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9197E+02
α_6	3.49E-10	9.68E-04	8.26E-05	5.08E-03	0.00E+00	1.8628E-01	1.9231E+02
α_7	0.00E+00	1.51E-04	1.32E-13	5.69E-04	0.00E+00	2.9071E-02	1.9247E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9459360	0.9673040	0.9686640	0.9840410	1.0000000	2.2073E+02	7.4610E+00
α_2	4.41E-03	1.47E-02	1.33E-02	2.97E-02	0.00E+00	3.3447E+00	2.2485E+02
α_3	1.13E-03	7.62E-03	6.24E-03	1.88E-02	0.00E+00	1.7384E+00	2.2645E+02
α_4	3.56E-04	5.02E-03	3.67E-03	1.43E-02	0.00E+00	1.1465E+00	2.2704E+02
α_5	5.65E-05	3.10E-03	1.82E-03	1.05E-02	0.00E+00	7.0833E-01	2.2748E+02
α_6	9.10E-07	1.61E-03	5.27E-04	6.88E-03	0.00E+00	3.6696E-01	2.2782E+02
α_7	7.14E-14	5.39E-04	9.69E-06	3.07E-03	0.00E+00	1.2297E-01	2.2807E+02
α_8	1.34E-42	1.45E-04	2.07E-12	6.14E-04	0.00E+00	3.3124E-02	2.2816E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

PWR Auxiliary Feedwater Check Valves

CHECK VALVE FAIL TO OPEN SPAR: AFW-CKV-CC

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.00	2.00	2.00	2.00	2.00	2.00	2.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

PWR Auxiliary Feedwater Check Valves

CHECK VALVE FAIL TO CLOSE SPAR: AFW-CKV-OO

1.5.3.2 CHECK VALVE FAIL TO CLOSE SPAR: AFW-CKV-OO

System : Auxiliary feedwater
Component : Check Valve
Failure Mode : Fail to close (reseat) on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 5.00

Total Number of Common-Cause Failure Events: 1

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8591660	0.9642770	0.9846980	0.9999250	0.9943280	1.1999E+01	4.4452E-01
α_2	7.69E-05	3.57E-02	1.53E-02	1.41E-01	5.67E-03	4.4452E-01	1.1999E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9042200	0.9660380	0.9748750	0.9976030	0.9887980	3.2150E+01	1.1303E+00
α_2	9.18E-04	2.59E-02	1.72E-02	8.08E-02	1.11E-02	8.6276E-01	3.2418E+01
α_3	2.87E-07	8.04E-03	1.63E-03	3.81E-02	1.14E-04	2.6752E-01	3.3013E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9120970	0.9628430	0.9686800	0.9936070	0.9834520	4.9565E+01	1.9128E+00
α_2	2.27E-03	2.50E-02	1.91E-02	6.77E-02	1.62E-02	1.2847E+00	5.0193E+01
α_3	9.05E-06	7.88E-03	2.94E-03	3.25E-02	3.15E-04	4.0541E-01	5.1072E+01
α_4	1.87E-08	4.33E-03	5.94E-04	2.17E-02	0.00E+00	2.2267E-01	5.1255E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9314140	0.9650830	0.9680270	0.9886850	0.9782220	1.0040E+02	3.6325E+00
α_2	4.29E-03	2.12E-02	1.82E-02	4.83E-02	2.11E-02	2.2056E+00	1.0183E+02
α_3	4.64E-04	9.42E-03	6.52E-03	2.83E-02	6.70E-04	9.8028E-01	1.0305E+02
α_4	2.37E-06	3.60E-03	1.21E-03	1.53E-02	0.00E+00	3.7439E-01	1.0366E+02
α_5	5.74E-21	6.95E-04	3.93E-07	4.02E-03	0.00E+00	7.2277E-02	1.0396E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9347590	0.9650530	0.9674780	0.9870430	0.9732140	1.2198E+02	4.4173E+00
α_2	4.11E-03	1.88E-02	1.63E-02	4.19E-02	2.57E-02	2.3721E+00	1.2403E+02
α_3	6.46E-04	9.08E-03	6.65E-03	2.58E-02	1.10E-03	1.1475E+00	1.2525E+02
α_4	4.19E-05	4.69E-03	2.45E-03	1.69E-02	0.00E+00	5.9222E-01	1.2581E+02
α_5	7.35E-09	1.76E-03	2.38E-04	8.81E-03	0.00E+00	2.2220E-01	1.2618E+02
α_6	1.12E-18	6.59E-04	1.15E-06	3.84E-03	0.00E+00	8.3237E-02	1.2631E+02

PWR Auxiliary Feedwater Check Valves

CHECK VALVE FAIL TO CLOSE SPAR: AFW-CKV-OO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9427360	0.9662330	0.9678020	0.9843570	0.9683330	1.8986E+02	6.6350E+00
α_2	4.92E-03	1.66E-02	1.50E-02	3.39E-02	3.00E-02	3.2678E+00	1.9323E+02
α_3	1.14E-03	8.35E-03	6.75E-03	2.10E-02	1.67E-03	1.6412E+00	1.9485E+02
α_4	2.52E-04	5.03E-03	3.48E-03	1.51E-02	0.00E+00	9.8887E-01	1.9551E+02
α_5	1.31E-05	2.66E-03	1.26E-03	1.00E-02	0.00E+00	5.2177E-01	1.9597E+02
α_6	3.42E-10	9.48E-04	8.09E-05	4.98E-03	0.00E+00	1.8628E-01	1.9631E+02
α_7	0.00E+00	1.48E-04	1.30E-13	5.57E-04	0.00E+00	2.9071E-02	1.9647E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9457360	0.9669610	0.9682920	0.9836540	0.9652000	2.2531E+02	7.6983E+00
α_2	4.83E-03	1.53E-02	1.39E-02	3.04E-02	3.18E-02	3.5615E+00	2.2945E+02
α_3	1.13E-03	7.55E-03	6.19E-03	1.86E-02	2.92E-03	1.7583E+00	2.3125E+02
α_4	3.49E-04	4.92E-03	3.60E-03	1.40E-02	8.80E-05	1.1471E+00	2.3186E+02
α_5	5.53E-05	3.04E-03	1.79E-03	1.03E-02	0.00E+00	7.0833E-01	2.3230E+02
α_6	8.91E-07	1.57E-03	5.16E-04	6.74E-03	0.00E+00	3.6696E-01	2.3264E+02
α_7	6.99E-14	5.28E-04	9.49E-06	3.00E-03	0.00E+00	1.2297E-01	2.3289E+02
α_8	1.31E-42	1.42E-04	2.03E-12	6.01E-04	0.00E+00	3.3124E-02	2.3298E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9943280	0.9887980	0.9834520	0.9782220	0.9732140	0.9683330	0.9652000
α_2	5.67E-03	1.11E-02	1.62E-02	2.11E-02	2.57E-02	3.00E-02	3.18E-02
α_3		1.14E-04	3.15E-04	6.70E-04	1.10E-03	1.67E-03	2.92E-03
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.80E-05
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.94E-01	9.89E-01	9.83E-01	9.78E-01	9.73E-01	9.68E-01	9.65E-01
Beta	5.67E-03	1.12E-02	1.65E-02	2.18E-02	2.68E-02	3.17E-02	3.48E-02
Gamma		1.02E-02	1.91E-02	3.08E-02	4.11E-02	5.26E-02	8.64E-02
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.93E-02
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

PWR Auxiliary Feedwater Check Valves

CHECK VALVE FAIL TO CLOSE SPAR: AFW-CKV-OO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	1.43	2.14	2.86	3.57	4.29	5.00	5.71
N ₁	0.3229	0.4551	0.5691	0.6657	0.7457	0.8100	0.8717
N ₂	0.0100	0.0291	0.0566	0.0914	0.1329	0.1800	0.2168
N ₃		0.0003	0.0011	0.0029	0.0057	0.0100	0.0199
N ₄			0.0000	0.0000	0.0000	0.0000	0.0006
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

PWR High Pressure Safety Injection Check Valves

HIGH PRESSURE INJECTION CHECK VALVE FAIL TO OPEN

1.5.4 PWR High Pressure Safety Injection Check Valves

1.5.4.1 HIGH PRESSURE INJECTION CHECK VALVE FAIL TO OPEN

System :	Chemical and volume control
	High pressure injection
Component :	Check Valve
Failure Mode :	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 3.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8734960	0.9682380	0.9867710	0.9999360	1.0000000	1.3246E+01	4.3452E-01
α_2	5.92E-05	3.18E-02	1.32E-02	1.27E-01	0.00E+00	4.3452E-01	1.3246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9068390	0.9672900	0.9760300	0.9978250	1.0000000	3.2555E+01	1.1009E+00
α_2	7.91E-04	2.48E-02	1.62E-02	7.82E-02	0.00E+00	8.3366E-01	3.2822E+01
α_3	2.80E-07	7.94E-03	1.61E-03	3.77E-02	0.00E+00	2.6722E-01	3.3389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9130680	0.9636200	0.9695110	0.9939910	1.0000000	4.9136E+01	1.8551E+00
α_2	2.00E-03	2.41E-02	1.82E-02	6.63E-02	0.00E+00	1.2281E+00	4.9763E+01
α_3	8.95E-06	7.93E-03	2.95E-03	3.27E-02	0.00E+00	4.0431E-01	5.0587E+01
α_4	1.89E-08	4.37E-03	5.99E-04	2.19E-02	0.00E+00	2.2267E-01	5.0768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9318350	0.9655480	0.9685320	0.9890570	1.0000000	9.9161E+01	3.5382E+00
α_2	3.97E-03	2.06E-02	1.76E-02	4.76E-02	0.00E+00	2.1142E+00	1.0059E+02
α_3	4.65E-04	9.52E-03	6.58E-03	2.86E-02	0.00E+00	9.7738E-01	1.0172E+02
α_4	2.40E-06	3.65E-03	1.23E-03	1.55E-02	0.00E+00	3.7439E-01	1.0232E+02
α_5	5.81E-21	7.04E-04	3.98E-07	4.08E-03	0.00E+00	7.2277E-02	1.0263E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9351640	0.9655550	0.9680290	0.9874920	1.0000000	1.1994E+02	4.2787E+00
α_2	3.71E-03	1.80E-02	1.55E-02	4.10E-02	0.00E+00	2.2392E+00	1.2198E+02
α_3	6.48E-04	9.19E-03	6.73E-03	2.62E-02	0.00E+00	1.1418E+00	1.2308E+02
α_4	4.26E-05	4.77E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2363E+02
α_5	7.48E-09	1.79E-03	2.43E-04	8.96E-03	0.00E+00	2.2220E-01	1.2400E+02
α_6	1.14E-18	6.70E-04	1.17E-06	3.91E-03	0.00E+00	8.3237E-02	1.2414E+02

PWR High Pressure Safety Injection Check Valves

HIGH PRESSURE INJECTION CHECK VALVE FAIL TO OPEN

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	3.00	3.00	3.00	3.00	3.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

PWR High Pressure Safety Injection Check Valves

HIGH PRESSURE INJECTION CHECK VALVE FAIL TO CLOSE

1.5.4.2 HIGH PRESSURE INJECTION CHECK VALVE FAIL TO CLOSE

System : Chemical and volume control
 High pressure injection

Component : Check Valve

Failure Mode : Fail to close (reseat) on demand

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 8.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9093850	0.9773460	0.9906920	0.9999550	1.0000000	1.8746E+01	4.3452E-01
α_2	4.16E-05	2.27E-02	9.31E-03	9.06E-02	0.00E+00	4.3452E-01	1.8746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9197350	0.9718850	0.9794540	0.9981430	1.0000000	3.8055E+01	1.1009E+00
α_2	6.78E-04	2.13E-02	1.39E-02	6.73E-02	0.00E+00	8.3366E-01	3.8322E+01
α_3	2.40E-07	6.82E-03	1.38E-03	3.24E-02	0.00E+00	2.6722E-01	3.8889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9214020	0.9671620	0.9725130	0.9945900	1.0000000	5.4636E+01	1.8551E+00
α_2	1.80E-03	2.17E-02	1.64E-02	6.00E-02	0.00E+00	1.2281E+00	5.5263E+01
α_3	8.07E-06	7.16E-03	2.66E-03	2.96E-02	0.00E+00	4.0431E-01	5.6087E+01
α_4	1.70E-08	3.94E-03	5.40E-04	1.97E-02	0.00E+00	2.2267E-01	5.6268E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9352570	0.9672990	0.9701370	0.9896220	1.0000000	1.0466E+02	3.5382E+00
α_2	3.76E-03	1.95E-02	1.67E-02	4.52E-02	0.00E+00	2.1142E+00	1.0608E+02
α_3	4.41E-04	9.03E-03	6.24E-03	2.72E-02	0.00E+00	9.7738E-01	1.0722E+02
α_4	2.28E-06	3.46E-03	1.17E-03	1.47E-02	0.00E+00	3.7439E-01	1.0782E+02
α_5	5.52E-21	6.68E-04	3.78E-07	3.87E-03	0.00E+00	7.2277E-02	1.0813E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9378820	0.9670160	0.9693880	0.9880300	1.0000000	1.2544E+02	4.2787E+00
α_2	3.55E-03	1.73E-02	1.48E-02	3.92E-02	0.00E+00	2.2392E+00	1.2748E+02
α_3	6.20E-04	8.80E-03	6.44E-03	2.51E-02	0.00E+00	1.1418E+00	1.2858E+02
α_4	4.08E-05	4.57E-03	2.39E-03	1.65E-02	0.00E+00	5.9222E-01	1.2913E+02
α_5	7.16E-09	1.71E-03	2.32E-04	8.58E-03	0.00E+00	2.2220E-01	1.2950E+02
α_6	1.09E-18	6.42E-04	1.12E-06	3.75E-03	0.00E+00	8.3237E-02	1.2964E+02

PWR High Pressure Safety Injection Check Valves

HIGH PRESSURE INJECTION CHECK VALVE FAIL TO CLOSE

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	8.50	8.50	8.50	8.50	8.50
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO OPEN

1.5.5 PWR Residual Heat Removal Check Valves**1.5.5.1 PWR RHR CHECK VALVE FAIL TO OPEN**

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Check Valve
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
α_2	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
α_2	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
α_3	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
α_2	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
α_3	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
α_4	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
α_2	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
α_3	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
α_4	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
α_5	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
α_2	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
α_3	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
α_4	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
α_5	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
α_6	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO OPEN

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9422570	0.9661670	0.9677850	0.9845420	1.0000000	1.8405E+02	6.4450E+00
α_2	4.57E-03	1.62E-02	1.45E-02	3.35E-02	0.00E+00	3.0878E+00	1.8741E+02
α_3	1.15E-03	8.56E-03	6.91E-03	2.16E-02	0.00E+00	1.6312E+00	1.8886E+02
α_4	2.60E-04	5.19E-03	3.59E-03	1.56E-02	0.00E+00	9.8887E-01	1.8951E+02
α_5	1.35E-05	2.74E-03	1.30E-03	1.04E-02	0.00E+00	5.2177E-01	1.8997E+02
α_6	3.53E-10	9.78E-04	8.35E-05	5.13E-03	0.00E+00	1.8628E-01	1.9031E+02
α_7	0.00E+00	1.53E-04	1.34E-13	5.75E-04	0.00E+00	2.9071E-02	1.9047E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9454620	0.9670150	0.9683850	0.9838980	1.0000000	2.1873E+02	7.4610E+00
α_2	4.45E-03	1.48E-02	1.34E-02	2.99E-02	0.00E+00	3.3447E+00	2.2285E+02
α_3	1.14E-03	7.69E-03	6.29E-03	1.90E-02	0.00E+00	1.7384E+00	2.2445E+02
α_4	3.59E-04	5.07E-03	3.71E-03	1.44E-02	0.00E+00	1.1465E+00	2.2504E+02
α_5	5.70E-05	3.13E-03	1.84E-03	1.06E-02	0.00E+00	7.0833E-01	2.2548E+02
α_6	9.18E-07	1.62E-03	5.31E-04	6.94E-03	0.00E+00	3.6696E-01	2.2582E+02
α_7	7.20E-14	5.44E-04	9.78E-06	3.10E-03	0.00E+00	1.2297E-01	2.2607E+02
α_8	1.35E-42	1.46E-04	2.09E-12	6.19E-04	0.00E+00	3.3124E-02	2.2616E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	0.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO OPEN

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00	0.00	0.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO CLOSE

1.5.5.2 PWR RHR CHECK VALVE FAIL TO CLOSE

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Check Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 6.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8989610	0.9747090	0.9895680	0.9999500	1.0000000	1.6746E+01	4.3452E-01
α_2	4.66E-05	2.53E-02	1.04E-02	1.01E-01	0.00E+00	4.3452E-01	1.6746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9154810	0.9703710	0.9783290	0.9980400	1.0000000	3.6055E+01	1.1009E+00
α_2	7.15E-04	2.24E-02	1.46E-02	7.09E-02	0.00E+00	8.3366E-01	3.6322E+01
α_3	2.53E-07	7.19E-03	1.45E-03	3.41E-02	0.00E+00	2.6722E-01	3.6889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9185670	0.9659560	0.9714920	0.9943870	1.0000000	5.2636E+01	1.8551E+00
α_2	1.87E-03	2.25E-02	1.70E-02	6.21E-02	0.00E+00	1.2281E+00	5.3263E+01
α_3	8.37E-06	7.42E-03	2.76E-03	3.06E-02	0.00E+00	4.0431E-01	5.4087E+01
α_4	1.77E-08	4.09E-03	5.60E-04	2.05E-02	0.00E+00	2.2267E-01	5.4268E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9340530	0.9666830	0.9695720	0.9894240	1.0000000	1.0266E+02	3.5382E+00
α_2	3.84E-03	1.99E-02	1.70E-02	4.60E-02	0.00E+00	2.1142E+00	1.0408E+02
α_3	4.50E-04	9.20E-03	6.36E-03	2.77E-02	0.00E+00	9.7738E-01	1.0522E+02
α_4	2.32E-06	3.53E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0582E+02
α_5	5.62E-21	6.81E-04	3.85E-07	3.94E-03	0.00E+00	7.2277E-02	1.0613E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9369200	0.9664990	0.9689110	0.9878400	1.0000000	1.2344E+02	4.2787E+00
α_2	3.60E-03	1.75E-02	1.51E-02	3.98E-02	0.00E+00	2.2392E+00	1.2548E+02
α_3	6.30E-04	8.94E-03	6.54E-03	2.55E-02	0.00E+00	1.1418E+00	1.2658E+02
α_4	4.15E-05	4.64E-03	2.43E-03	1.67E-02	0.00E+00	5.9222E-01	1.2713E+02
α_5	7.27E-09	1.74E-03	2.36E-04	8.72E-03	0.00E+00	2.2220E-01	1.2750E+02
α_6	1.10E-18	6.52E-04	1.14E-06	3.80E-03	0.00E+00	8.3237E-02	1.2764E+02

PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO CLOSE

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9441390	0.9672830	0.9688570	0.9850630	1.0000000	1.9055E+02	6.4450E+00
α_2	4.42E-03	1.57E-02	1.41E-02	3.24E-02	0.00E+00	3.0878E+00	1.9391E+02
α_3	1.12E-03	8.28E-03	6.69E-03	2.09E-02	0.00E+00	1.6312E+00	1.9536E+02
α_4	2.52E-04	5.02E-03	3.48E-03	1.51E-02	0.00E+00	9.8887E-01	1.9601E+02
α_5	1.30E-05	2.65E-03	1.25E-03	1.00E-02	0.00E+00	5.2177E-01	1.9647E+02
α_6	3.41E-10	9.46E-04	8.07E-05	4.96E-03	0.00E+00	1.8628E-01	1.9681E+02
α_7	0.00E+00	1.48E-04	1.29E-13	5.56E-04	0.00E+00	2.9071E-02	1.9697E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9469720	0.9679360	0.9692720	0.9843530	1.0000000	2.2523E+02	7.4610E+00
α_2	4.32E-03	1.44E-02	1.30E-02	2.91E-02	0.00E+00	3.3447E+00	2.2935E+02
α_3	1.11E-03	7.47E-03	6.11E-03	1.85E-02	0.00E+00	1.7384E+00	2.3095E+02
α_4	3.49E-04	4.93E-03	3.60E-03	1.40E-02	0.00E+00	1.1465E+00	2.3154E+02
α_5	5.54E-05	3.04E-03	1.79E-03	1.03E-02	0.00E+00	7.0833E-01	2.3198E+02
α_6	8.93E-07	1.58E-03	5.16E-04	6.75E-03	0.00E+00	3.6696E-01	2.3232E+02
α_7	7.00E-14	5.28E-04	9.50E-06	3.01E-03	0.00E+00	1.2297E-01	2.3257E+02
α_8	1.31E-42	1.42E-04	2.03E-12	6.02E-04	0.00E+00	3.3124E-02	2.3266E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO CLOSE

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	6.50	6.50	6.50	6.50	6.50	6.50	6.50
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.5.6 BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check Valves

1.5.6.1 COMBINED HPCI AND RCIC CHECK VALVE FAIL TO OPEN

System :	High pressure coolant injection Reactor core isolation
Component :	Check Valve
Failure Mode :	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8522320	0.9628000	0.9843830	0.9999320	1.0000000	1.1246E+01	4.3452E-01
α_2	7.00E-05	3.72E-02	1.56E-02	1.48E-01	0.00E+00	4.3452E-01	1.1246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9010680	0.9652240	0.9744830	0.9976820	1.0000000	3.0555E+01	1.1009E+00
α_2	8.43E-04	2.63E-02	1.72E-02	8.30E-02	0.00E+00	8.3366E-01	3.0822E+01
α_3	2.98E-07	8.44E-03	1.71E-03	4.00E-02	0.00E+00	2.6722E-01	3.1389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9095820	0.9621340	0.9682530	0.9937390	1.0000000	4.7136E+01	1.8551E+00
α_2	2.09E-03	2.51E-02	1.89E-02	6.90E-02	0.00E+00	1.2281E+00	4.7763E+01
α_3	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8587E+01
α_4	1.97E-08	4.55E-03	6.24E-04	2.28E-02	0.00E+00	2.2267E-01	4.8768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9304990	0.9648630	0.9678980	0.9888360	1.0000000	9.7161E+01	3.5382E+00
α_2	4.05E-03	2.10E-02	1.79E-02	4.85E-02	0.00E+00	2.1142E+00	9.8585E+01
α_3	4.74E-04	9.71E-03	6.71E-03	2.92E-02	0.00E+00	9.7738E-01	9.9722E+01
α_4	2.45E-06	3.72E-03	1.25E-03	1.58E-02	0.00E+00	3.7439E-01	1.0032E+02
α_5	5.93E-21	7.18E-04	4.06E-07	4.16E-03	0.00E+00	7.2277E-02	1.0063E+02

BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check
Valves

COMBINED HPCI AND RCIC CHECK VALVE FAIL TO OPEN

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9341160	0.9649920	0.9674990	0.9872840	1.0000000	1.1794E+02	4.2787E+00
α_2	3.77E-03	1.83E-02	1.58E-02	4.16E-02	0.00E+00	2.2392E+00	1.1998E+02
α_3	6.58E-04	9.34E-03	6.84E-03	2.66E-02	0.00E+00	1.1418E+00	1.2108E+02
α_4	4.33E-05	4.85E-03	2.54E-03	1.75E-02	0.00E+00	5.9222E-01	1.2163E+02
α_5	7.60E-09	1.82E-03	2.47E-04	9.11E-03	0.00E+00	2.2220E-01	1.2200E+02
α_6	1.15E-18	6.81E-04	1.19E-06	3.98E-03	0.00E+00	8.3237E-02	1.2214E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	1.00	1.00	1.00	1.00	1.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

COMBINED HPCI AND RCIC CHECK VALVE FAIL TO CLOSE

1.5.6.2 COMBINED HPCI AND RCIC CHECK VALVE FAIL TO CLOSE

System : High pressure coolant injection
Reactor core isolation

Component : Check Valve

Failure Mode : Fail to close (reseat) on demand

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 4.00

Total Number of Common-Cause Failure Events: 0

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8819910	0.9704020	0.9877120	0.9999410	1.0000000	1.4246E+01	4.3452E-01
α_2	5.49E-05	2.96E-02	1.23E-02	1.18E-01	0.00E+00	4.3452E-01	1.4246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9094830	0.9682340	0.9767350	0.9978890	1.0000000	3.3555E+01	1.1009E+00
α_2	7.68E-04	2.41E-02	1.57E-02	7.59E-02	0.00E+00	8.3366E-01	3.3822E+01
α_3	2.71E-07	7.71E-03	1.56E-03	3.66E-02	0.00E+00	2.6722E-01	3.4389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9147120	0.9643190	0.9701040	0.9941100	1.0000000	5.0136E+01	1.8551E+00
α_2	1.96E-03	2.36E-02	1.78E-02	6.51E-02	0.00E+00	1.2281E+00	5.0763E+01
α_3	8.78E-06	7.78E-03	2.89E-03	3.21E-02	0.00E+00	4.0431E-01	5.1587E+01
α_4	1.85E-08	4.28E-03	5.88E-04	2.15E-02	0.00E+00	2.2267E-01	5.1768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9324830	0.9658790	0.9688380	0.9891640	1.0000000	1.0016E+02	3.5382E+00
α_2	3.93E-03	2.04E-02	1.74E-02	4.71E-02	0.00E+00	2.1142E+00	1.0158E+02
α_3	4.61E-04	9.43E-03	6.51E-03	2.83E-02	0.00E+00	9.7738E-01	1.0272E+02
α_4	2.37E-06	3.61E-03	1.22E-03	1.53E-02	0.00E+00	3.7439E-01	1.0332E+02
α_5	5.76E-21	6.97E-04	3.94E-07	4.04E-03	0.00E+00	7.2277E-02	1.0363E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9356760	0.9658310	0.9682860	0.9875940	1.0000000	1.2094E+02	4.2787E+00
α_2	3.68E-03	1.79E-02	1.54E-02	4.06E-02	0.00E+00	2.2392E+00	1.2298E+02
α_3	6.42E-04	9.12E-03	6.67E-03	2.60E-02	0.00E+00	1.1418E+00	1.2408E+02
α_4	4.23E-05	4.73E-03	2.48E-03	1.71E-02	0.00E+00	5.9222E-01	1.2463E+02
α_5	7.42E-09	1.77E-03	2.41E-04	8.89E-03	0.00E+00	2.2220E-01	1.2500E+02
α_6	1.13E-18	6.65E-04	1.16E-06	3.88E-03	0.00E+00	8.3237E-02	1.2514E+02

BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check
Valves

COMBINED HPCI AND RCIC CHECK VALVE FAIL TO CLOSE

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	4.00	4.00	4.00	4.00	4.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.6 Strainers, Trash Racks, and Filters

1.6.1 Pooled Strainers (Non-ESW)

1.6.1.1 GENERIC CLEAN DISCHARGE STRAINER PLUGS

System :	Chemical and volume control Component cooling water Control rod drive High pressure injection Standby liquid control
Component :	Strainer
Failure Mode :	No flow/plugged
Component Group :	Passive filter/strainer
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8386830	0.9593170	0.9828300	0.9999250	0.9888200	1.0246E+01	4.3452E-01
α_2	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8979020	0.9640890	0.9736330	0.9976040	0.9888200	2.9555E+01	1.1009E+00
α_2	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
α_3	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9077330	0.9613450	0.9675780	0.9936050	0.9888200	4.6136E+01	1.8551E+00
α_2	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
α_3	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
α_4	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9298110	0.9645110	0.9675740	0.9887220	0.9888200	9.6161E+01	3.5382E+00
α_2	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
α_3	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
α_4	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
α_5	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

Strainers, Trash Racks, and Filters
 Pooled Strainers (Non-ESW)
 GENERIC CLEAN DISCHARGE STRAINER PLUGS
CCCG = 6

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9335790	0.9647030	0.9672350	0.9871780	0.9888200	1.1694E+02	4.2787E+00
α_2	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
α_3	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
α_4	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
α_5	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
α_6	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9888200	0.9888200	0.9888200	0.9888200	0.9888200
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.6.2 Emergency Service Water Strainers

1.6.2.1 SERVICE WATER TSA FTO NON ENVIRONMENTAL SPAR:TS-FO

System :	Normally operating service water Standby service water
Component :	Strainer
Failure Mode :	Fail to Operate (General operation failure, rate based)
Component Group :	Traveling Screen
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 28.00

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9206260	0.9793800	0.9906270	0.9999260	0.9960990	2.3013E+01	4.8452E-01
α_2	7.07E-05	2.06E-02	9.37E-03	7.94E-02	3.90E-03	4.8452E-01	2.3013E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9312830	0.9748850	0.9809220	0.9978300	0.9921670	4.8555E+01	1.2509E+00
α_2	9.91E-04	1.97E-02	1.38E-02	5.89E-02	7.83E-03	9.8366E-01	4.8822E+01
α_3	1.88E-07	5.37E-03	1.08E-03	2.54E-02	0.00E+00	2.6722E-01	4.9539E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9328590	0.9706490	0.9748180	0.9941830	0.9882040	7.1269E+01	2.1551E+00
α_2	2.56E-03	2.08E-02	1.66E-02	5.33E-02	1.18E-02	1.5281E+00	7.1896E+01
α_3	6.19E-06	5.51E-03	2.04E-03	2.28E-02	0.00E+00	4.0431E-01	7.3020E+01
α_4	1.31E-08	3.03E-03	4.15E-04	1.52E-02	0.00E+00	2.2267E-01	7.3201E+01

Strainers, Trash Racks, and Filters
 Emergency Service Water Strainers
 SERVICE WATER TSA FTO NON ENVIRONMENTAL SPAR:TSF-FO
CCCG = 5

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9412660	0.9693120	0.9716620	0.9893090	0.9844230	1.2734E+02	4.0315E+00
α_2	4.79E-03	1.98E-02	1.74E-02	4.30E-02	1.55E-02	2.6042E+00	1.2877E+02
α_3	3.67E-04	7.46E-03	5.16E-03	2.24E-02	1.04E-04	9.8068E-01	1.3039E+02
α_4	1.87E-06	2.85E-03	9.59E-04	1.21E-02	0.00E+00	3.7439E-01	1.3100E+02
α_5	4.54E-21	5.50E-04	3.11E-07	3.18E-03	0.00E+00	7.2277E-02	1.3130E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9429390	0.9684980	0.9704410	0.9874090	0.9806530	1.5406E+02	5.0111E+00
α_2	5.07E-03	1.86E-02	1.66E-02	3.89E-02	1.91E-02	2.9631E+00	1.5611E+02
α_3	5.17E-04	7.23E-03	5.30E-03	2.05E-02	2.22E-04	1.1502E+00	1.5792E+02
α_4	3.33E-05	3.72E-03	1.95E-03	1.34E-02	2.64E-06	5.9232E-01	1.5848E+02
α_5	5.84E-09	1.40E-03	1.89E-04	7.00E-03	0.00E+00	2.2220E-01	1.5885E+02
α_6	8.86E-19	5.23E-04	9.15E-07	3.05E-03	0.00E+00	8.3237E-02	1.5899E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9960990	0.9921670	0.9882040	0.9844230	0.9806530
α_2	3.90E-03	7.83E-03	1.18E-02	1.55E-02	1.91E-02
α_3		0.00E+00	0.00E+00	1.04E-04	2.22E-04
α_4			0.00E+00	0.00E+00	2.64E-06
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.96E-01	9.92E-01	9.88E-01	9.84E-01	9.81E-01
Beta	3.90E-03	7.83E-03	1.18E-02	1.56E-02	1.93E-02
Gamma		0.00E+00	0.00E+00	6.69E-03	1.16E-02
Delta			0.00E+00	0.00E+00	1.18E-02
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	11.20	16.80	22.40	28.00	33.60
N₁	1.5667	2.2000	2.7333	3.1750	3.5230
N₂	0.0500	0.1500	0.3000	0.4900	0.7239
N₃		0.0000	0.0000	0.0033	0.0084
N₄			0.0000	0.0000	0.0001
N₅				0.0000	0.0000
N₆					0.0000

1.6.2.2 SERVICE WATER TSA PLUG NON ENVIRONMENTAL SPAR:TSAPG

System :	Normally operating service water Standby service water
Component :	Strainer
Failure Mode :	No flow/plugged
Component Group :	Traveling Screen
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8522320	0.9628000	0.9843830	0.9999320	1.0000000	1.1246E+01	4.3452E-01
α_2	7.00E-05	3.72E-02	1.56E-02	1.48E-01	0.00E+00	4.3452E-01	1.1246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9010680	0.9652240	0.9744830	0.9976820	1.0000000	3.0555E+01	1.1009E+00
α_2	8.43E-04	2.63E-02	1.72E-02	8.30E-02	0.00E+00	8.3366E-01	3.0822E+01
α_3	2.98E-07	8.44E-03	1.71E-03	4.00E-02	0.00E+00	2.6722E-01	3.1389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9095820	0.9621340	0.9682530	0.9937390	1.0000000	4.7136E+01	1.8551E+00
α_2	2.09E-03	2.51E-02	1.89E-02	6.90E-02	0.00E+00	1.2281E+00	4.7763E+01
α_3	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8587E+01
α_4	1.97E-08	4.55E-03	6.24E-04	2.28E-02	0.00E+00	2.2267E-01	4.8768E+01

Strainers, Trash Racks, and Filters
 Emergency Service Water Strainers
 SERVICE WATER TSA PLUG NON ENVIRONMENTAL SPAR:TSA-PG
CCCG = 5

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9304990	0.9648630	0.9678980	0.9888360	1.0000000	9.7161E+01	3.5382E+00
α_2	4.05E-03	2.10E-02	1.79E-02	4.85E-02	0.00E+00	2.1142E+00	9.8585E+01
α_3	4.74E-04	9.71E-03	6.71E-03	2.92E-02	0.00E+00	9.7738E-01	9.9722E+01
α_4	2.45E-06	3.72E-03	1.25E-03	1.58E-02	0.00E+00	3.7439E-01	1.0032E+02
α_5	5.93E-21	7.18E-04	4.06E-07	4.16E-03	0.00E+00	7.2277E-02	1.0063E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9341160	0.9649920	0.9674990	0.9872840	1.0000000	1.1794E+02	4.2787E+00
α_2	3.77E-03	1.83E-02	1.58E-02	4.16E-02	0.00E+00	2.2392E+00	1.1998E+02
α_3	6.58E-04	9.34E-03	6.84E-03	2.66E-02	0.00E+00	1.1418E+00	1.2108E+02
α_4	4.33E-05	4.85E-03	2.54E-03	1.75E-02	0.00E+00	5.9222E-01	1.2163E+02
α_5	7.60E-09	1.82E-03	2.47E-04	9.11E-03	0.00E+00	2.2220E-01	1.2200E+02
α_6	1.15E-18	6.81E-04	1.19E-06	3.98E-03	0.00E+00	8.3237E-02	1.2214E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	1.00	1.00	1.00	1.00	1.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.6.2.3 SERVICE WATER STRAINER PLUG NON ENVIRONMENTAL SPAR:STR-PG

System :	Normally operating service water Standby service water
Component :	Strainer
Failure Mode :	High dP across filter No flow/plugged
Component Group :	Self-Cleaning filter/strainer
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 37.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9633370	0.9908870	0.9963330	0.9999820	1.0000000	4.7246E+01	4.3452E-01
α_2	1.63E-05	9.11E-03	3.67E-03	3.67E-02	0.00E+00	4.3452E-01	4.7246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9532560	0.9837280	0.9881890	0.9989340	1.0000000	6.6555E+01	1.1009E+00
α_2	3.88E-04	1.23E-02	7.96E-03	3.91E-02	0.00E+00	8.3366E-01	6.6822E+01
α_3	1.38E-07	3.95E-03	7.93E-04	1.87E-02	0.00E+00	2.6722E-01	6.7389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9474900	0.9781730	0.9818070	0.9964330	1.0000000	8.3136E+01	1.8551E+00
α_2	1.19E-03	1.44E-02	1.09E-02	4.00E-02	0.00E+00	1.2281E+00	8.3763E+01
α_3	5.34E-06	4.76E-03	1.76E-03	1.97E-02	0.00E+00	4.0431E-01	8.4587E+01
α_4	1.13E-08	2.62E-03	3.58E-04	1.31E-02	0.00E+00	2.2267E-01	8.4768E+01

Strainers, Trash Racks, and Filters
Emergency Service Water Strainers

2010

SERVICE WATER STRAINER PLUG NON ENVIRONMENTAL SPAR:STR-PG
CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9486250	0.9741160	0.9763980	0.9918180	1.0000000	1.3316E+02	3.5382E+00
α_2	2.97E-03	1.55E-02	1.32E-02	3.58E-02	0.00E+00	2.1142E+00	1.3458E+02
α_3	3.49E-04	7.15E-03	4.93E-03	2.15E-02	0.00E+00	9.7738E-01	1.3572E+02
α_4	1.80E-06	2.74E-03	9.22E-04	1.16E-02	0.00E+00	3.7439E-01	1.3632E+02
α_5	4.36E-21	5.29E-04	2.99E-07	3.06E-03	0.00E+00	7.2277E-02	1.3663E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9489700	0.9729570	0.9749300	0.9902120	1.0000000	1.5394E+02	4.2787E+00
α_2	2.90E-03	1.42E-02	1.22E-02	3.22E-02	0.00E+00	2.2392E+00	1.5598E+02
α_3	5.07E-04	7.22E-03	5.27E-03	2.06E-02	0.00E+00	1.1418E+00	1.5708E+02
α_4	3.34E-05	3.74E-03	1.96E-03	1.35E-02	0.00E+00	5.9222E-01	1.5763E+02
α_5	5.87E-09	1.40E-03	1.90E-04	7.04E-03	0.00E+00	2.2220E-01	1.5800E+02
α_6	8.91E-19	5.26E-04	9.20E-07	3.07E-03	0.00E+00	8.3237E-02	1.5814E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	37.00	37.00	37.00	37.00	37.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

ESW STRAINER PLUG POOLED CAUSES SPAR:ESW-STR-POOL-PG

1.6.2.4 ESW STRAINER PLUG POOLED CAUSES SPAR:ESW-STR-POOL-PG

System :	Normally operating service water Standby service water
Component :	Strainer
Failure Mode :	High dP across filter No flow/plugged
Component Group :	Self-Cleaning filter/strainer
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 37.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9633370	0.9908870	0.9963330	0.9999820	1.0000000	4.7246E+01	4.3452E-01
α_2	1.63E-05	9.11E-03	3.67E-03	3.67E-02	0.00E+00	4.3452E-01	4.7246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9532560	0.9837280	0.9881890	0.9989340	1.0000000	6.6555E+01	1.1009E+00
α_2	3.88E-04	1.23E-02	7.96E-03	3.91E-02	0.00E+00	8.3366E-01	6.6822E+01
α_3	1.38E-07	3.95E-03	7.93E-04	1.87E-02	0.00E+00	2.6722E-01	6.7389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9474900	0.9781730	0.9818070	0.9964330	1.0000000	8.3136E+01	1.8551E+00
α_2	1.19E-03	1.44E-02	1.09E-02	4.00E-02	0.00E+00	1.2281E+00	8.3763E+01
α_3	5.34E-06	4.76E-03	1.76E-03	1.97E-02	0.00E+00	4.0431E-01	8.4587E+01
α_4	1.13E-08	2.62E-03	3.58E-04	1.31E-02	0.00E+00	2.2267E-01	8.4768E+01

Strainers, Trash Racks, and Filters
 Emergency Service Water Strainers
 ESW STRAINER PLUG POOLED CAUSES SPAR:ESW-STR-POOL-PG
CCCG = 5

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9486250	0.9741160	0.9763980	0.9918180	1.0000000	1.3316E+02	3.5382E+00
α_2	2.97E-03	1.55E-02	1.32E-02	3.58E-02	0.00E+00	2.1142E+00	1.3458E+02
α_3	3.49E-04	7.15E-03	4.93E-03	2.15E-02	0.00E+00	9.7738E-01	1.3572E+02
α_4	1.80E-06	2.74E-03	9.22E-04	1.16E-02	0.00E+00	3.7439E-01	1.3632E+02
α_5	4.36E-21	5.29E-04	2.99E-07	3.06E-03	0.00E+00	7.2277E-02	1.3663E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9489700	0.9729570	0.9749300	0.9902120	1.0000000	1.5394E+02	4.2787E+00
α_2	2.90E-03	1.42E-02	1.22E-02	3.22E-02	0.00E+00	2.2392E+00	1.5598E+02
α_3	5.07E-04	7.22E-03	5.27E-03	2.06E-02	0.00E+00	1.1418E+00	1.5708E+02
α_4	3.34E-05	3.74E-03	1.96E-03	1.35E-02	0.00E+00	5.9222E-01	1.5763E+02
α_5	5.87E-09	1.40E-03	1.90E-04	7.04E-03	0.00E+00	2.2220E-01	1.5800E+02
α_6	8.91E-19	5.26E-04	9.20E-07	3.07E-03	0.00E+00	8.3237E-02	1.5814E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	37.00	37.00	37.00	37.00	37.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.6.3 Pooled Sump Strainers

1.6.3.1 SUMP SUCTION PLUGGED

System :	Containment spray recirculation High pressure core spray High pressure coolant injection Low pressure core spray Reactor core isolation Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Strainer
Failure Mode :	High dP across filter No flow/plugged
Component Group :	Sump Strainer Filter
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 1.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8581890	0.9643270	0.9850590	0.9999350	1.0000000	1.1746E+01	4.3452E-01
α_2	6.69E-05	3.57E-02	1.49E-02	1.42E-01	0.00E+00	4.3452E-01	1.1746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9025780	0.9657640	0.9748880	0.9977200	1.0000000	3.1055E+01	1.1009E+00
α_2	8.29E-04	2.59E-02	1.69E-02	8.18E-02	0.00E+00	8.3366E-01	3.1322E+01
α_3	2.93E-07	8.31E-03	1.69E-03	3.94E-02	0.00E+00	2.6722E-01	3.1889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9104790	0.9625170	0.9685780	0.9938040	1.0000000	4.7636E+01	1.8551E+00
α_2	2.06E-03	2.48E-02	1.87E-02	6.83E-02	0.00E+00	1.2281E+00	4.8263E+01
α_3	9.23E-06	8.17E-03	3.04E-03	3.37E-02	0.00E+00	4.0431E-01	4.9087E+01
α_4	1.95E-08	4.50E-03	6.18E-04	2.25E-02	0.00E+00	2.2267E-01	4.9268E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9308380	0.9650370	0.9680620	0.9888920	1.0000000	9.7661E+01	3.5382E+00
α_2	4.03E-03	2.09E-02	1.78E-02	4.83E-02	0.00E+00	2.1142E+00	9.9085E+01
α_3	4.72E-04	9.66E-03	6.68E-03	2.90E-02	0.00E+00	9.7738E-01	1.0022E+02
α_4	2.43E-06	3.70E-03	1.25E-03	1.57E-02	0.00E+00	3.7439E-01	1.0082E+02
α_5	5.90E-21	7.14E-04	4.04E-07	4.14E-03	0.00E+00	7.2277E-02	1.0113E+02

Pooled Sump Strainers

SUMP SUCTION PLUGGED

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9343810	0.9651340	0.9676320	0.9873370	1.0000000	1.1844E+02	4.2787E+00
α_2	3.75E-03	1.82E-02	1.57E-02	4.15E-02	0.00E+00	2.2392E+00	1.2048E+02
α_3	6.56E-04	9.30E-03	6.81E-03	2.65E-02	0.00E+00	1.1418E+00	1.2158E+02
α_4	4.32E-05	4.83E-03	2.53E-03	1.74E-02	0.00E+00	5.9222E-01	1.2213E+02
α_5	7.57E-09	1.81E-03	2.46E-04	9.07E-03	0.00E+00	2.2220E-01	1.2250E+02
α_6	1.15E-18	6.78E-04	1.19E-06	3.96E-03	0.00E+00	8.3237E-02	1.2264E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	1.50	1.50	1.50	1.50	1.50
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.6.4 PWR Containment Sump Strainers

1.6.4.1 CONTAINMENT SPRAY SUMP STRAINER PLUG STR-PG

System :	Containment spray recirculation
Component :	Strainer
Failure Mode :	High dP across filter No flow/plugged
Component Group :	Sump Strainer Filter
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
α_2	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	0.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	0.00
N₁	0.0000
N₂	0.0000

1.6.5 BWR Suppression Pool Strainers

1.6.5.1 BWR RHR SUMP STRAINER PLUG

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Strainer
Failure Mode :	High dP across filter No flow/plugged
Component Group :	Sump Strainer Filter
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8386830	0.9593170	0.9828300	0.9999250	0.9877750	1.0246E+01	4.3452E-01
α_2	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8979020	0.9640890	0.9736330	0.9976040	0.9877750	2.9555E+01	1.1009E+00
α_2	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
α_3	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9077330	0.9613450	0.9675780	0.9936050	0.9877750	4.6136E+01	1.8551E+00
α_2	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
α_3	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
α_4	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9298110	0.9645110	0.9675740	0.9887220	0.9877750	9.6161E+01	3.5382E+00
α_2	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
α_3	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
α_4	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
α_5	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

Strainers, Trash Racks, and Filters
 BWR Suppression Pool Strainers
 BWR RHR SUMP STRAINER PLUG
CCCG = 6

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9335790	0.9647030	0.9672350	0.9871780	0.9877750	1.1694E+02	4.2787E+00
α_2	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
α_3	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
α_4	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
α_5	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
α_6	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9877750	0.9877750	0.9877750	0.9877750	0.9877750
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.6.6 Extreme Environmental Event CCF Distributions

1.6.6.1 CIRCULATING WATER TSA EXTREME ENVIRONMENTAL PLUG

System :	Circulating water system
Component :	Strainer
Failure Mode :	No flow/plugged
Component Group :	Traveling Screen
Prox. Cause :	Extreme environmental stress
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 20.00

Total Number of Common-Cause Failure Events: 16

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.5679640	0.7008240	0.7047340	0.8202940	0.5852780	2.4231E+01	1.0344E+01
α_2	1.80E-01	2.99E-01	2.95E-01	4.32E-01	4.15E-01	1.0344E+01	2.4231E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.6819680	0.7747750	0.7778270	0.8571340	0.5787480	4.6689E+01	1.3572E+01
α_2	4.71E-02	1.02E-01	9.81E-02	1.73E-01	1.80E-01	6.1766E+00	5.4085E+01
α_3	6.16E-02	1.23E-01	1.19E-01	1.98E-01	2.41E-01	7.3958E+00	5.2866E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.7215890	0.7978290	0.8002440	0.8658210	0.5705780	6.5839E+01	1.6684E+01
α_2	3.84E-02	8.11E-02	7.77E-02	1.35E-01	1.58E-01	6.6924E+00	7.5830E+01
α_3	3.16E-02	7.13E-02	6.79E-02	1.23E-01	1.59E-01	5.8853E+00	7.6637E+01
α_4	1.77E-02	4.98E-02	4.62E-02	9.41E-02	1.12E-01	4.1060E+00	7.8417E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8093550	0.8603590	0.8620920	0.9054540	0.5954810	1.1950E+02	1.9396E+01
α_2	1.78E-02	4.12E-02	3.90E-02	7.21E-02	9.22E-02	5.7273E+00	1.3317E+02
α_3	2.43E-02	5.08E-02	4.86E-02	8.46E-02	1.55E-01	7.0548E+00	1.3184E+02
α_4	1.29E-02	3.36E-02	3.14E-02	6.19E-02	1.09E-01	4.6661E+00	1.3423E+02
α_5	2.43E-03	1.40E-02	1.18E-02	3.33E-02	4.78E-02	1.9473E+00	1.3695E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8327830	0.8771430	0.8786640	0.9163030	0.6350360	1.4478E+02	2.0279E+01
α_2	5.97E-03	2.00E-02	1.81E-02	4.05E-02	2.42E-02	3.2997E+00	1.6176E+02
α_3	2.19E-02	4.49E-02	4.31E-02	7.41E-02	1.43E-01	7.4077E+00	1.5765E+02
α_4	1.43E-02	3.38E-02	3.19E-02	5.96E-02	1.14E-01	5.5783E+00	1.5948E+02
α_5	4.92E-03	1.80E-02	1.61E-02	3.76E-02	6.27E-02	2.9722E+00	1.6209E+02
α_6	3.36E-04	6.18E-03	4.34E-03	1.83E-02	2.14E-02	1.0207E+00	1.6404E+02

Strainers, Trash Racks, and Filters
 Extreme Environmental Event CCF Distributions
 CIRCULATING WATER TSA EXTREME ENVIRONMENTAL PLUG
ALPHA FACTOR and MGL PARAMETERS

2010

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.5852780	0.5787480	0.5705780	0.5954810	0.6350360
α_2	4.15E-01	1.80E-01	1.58E-01	9.22E-02	2.42E-02
α_3		2.41E-01	1.59E-01	1.55E-01	1.43E-01
α_4			1.12E-01	1.09E-01	1.14E-01
α_5				4.78E-02	6.27E-02
α_6					2.14E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	5.85E-01	5.79E-01	5.71E-01	5.95E-01	6.35E-01
Beta	4.15E-01	4.21E-01	4.29E-01	4.05E-01	3.65E-01
Gamma		5.72E-01	6.32E-01	7.72E-01	9.34E-01
Delta			4.15E-01	5.04E-01	5.81E-01
Epsilon				3.04E-01	4.25E-01
Mu					2.54E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	9.28	13.92	18.56	23.20	27.84
N ₁	4.7048	3.2143	1.1429	0.1429	0.0000
N ₂	9.9095	5.3429	5.4643	3.6131	1.0605
N ₃		7.1286	5.4810	6.0774	6.2659
N ₄			3.8833	4.2917	4.9861
N ₅				1.8750	2.7500
N ₆					0.9375

Strainers, Trash Racks, and Filters
 Extreme Environmental Event CCF Distributions
 CIRCULATING WATER TSA NON ENVIRONMENTAL PLUG SPAR:CWS-PG

2010

1.6.6.2 CIRCULATING WATER TSA NON ENVIRONMENTAL PLUG SPAR:CWS-PG

System :	Circulating water system
Component :	Strainer
Failure Mode :	No flow/plugged
Component Group :	Traveling Screen
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part Unknown
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 8.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9069840	0.9767390	0.9904340	0.9999540	1.0000000	1.8246E+01	4.3452E-01
α_2	4.27E-05	2.33E-02	9.56E-03	9.30E-02	0.00E+00	4.3452E-01	1.8246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9187120	0.9715210	0.9791840	0.9981180	1.0000000	3.7555E+01	1.1009E+00
α_2	6.87E-04	2.16E-02	1.40E-02	6.82E-02	0.00E+00	8.3366E-01	3.7822E+01
α_3	2.43E-07	6.91E-03	1.40E-03	3.28E-02	0.00E+00	2.6722E-01	3.8389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9207150	0.9668680	0.9722640	0.9945410	1.0000000	5.4136E+01	1.8551E+00
α_2	1.82E-03	2.19E-02	1.65E-02	6.05E-02	0.00E+00	1.2281E+00	5.4763E+01
α_3	8.14E-06	7.22E-03	2.68E-03	2.98E-02	0.00E+00	4.0431E-01	5.5587E+01
α_4	1.72E-08	3.98E-03	5.45E-04	1.99E-02	0.00E+00	2.2267E-01	5.5768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9349600	0.9671470	0.9699980	0.9895730	1.0000000	1.0416E+02	3.5382E+00
α_2	3.78E-03	1.96E-02	1.67E-02	4.54E-02	0.00E+00	2.1142E+00	1.0558E+02
α_3	4.43E-04	9.08E-03	6.27E-03	2.73E-02	0.00E+00	9.7738E-01	1.0672E+02
α_4	2.29E-06	3.48E-03	1.17E-03	1.48E-02	0.00E+00	3.7439E-01	1.0732E+02
α_5	5.54E-21	6.71E-04	3.80E-07	3.89E-03	0.00E+00	7.2277E-02	1.0763E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9376440	0.9668880	0.9692700	0.9879830	1.0000000	1.2494E+02	4.2787E+00
α_2	3.56E-03	1.73E-02	1.49E-02	3.94E-02	0.00E+00	2.2392E+00	1.2698E+02
α_3	6.22E-04	8.84E-03	6.46E-03	2.52E-02	0.00E+00	1.1418E+00	1.2808E+02
α_4	4.10E-05	4.58E-03	2.40E-03	1.65E-02	0.00E+00	5.9222E-01	1.2863E+02
α_5	7.19E-09	1.72E-03	2.33E-04	8.62E-03	0.00E+00	2.2220E-01	1.2900E+02
α_6	1.09E-18	6.44E-04	1.13E-06	3.76E-03	0.00E+00	8.3237E-02	1.2914E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	8.00	8.00	8.00	8.00	8.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.6.6.3 SERVICE WATER STRAINER PLUG ENVIRONMENTAL SPAR:STR-EE-PG

System :	Normally operating service water
	Standby service water
Component :	Strainer
Failure Mode :	High dP across filter
	No flow/plugged
Component Group :	Self-Cleaning filter/strainer
Prox. Cause :	Extreme environmental stress
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 21.50

Total Number of Common-Cause Failure Events: 4

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8630170	0.9448060	0.9547470	0.9925020	0.9363500	2.7409E+01	1.6012E+00
α_2	7.50E-03	5.52E-02	4.53E-02	1.37E-01	6.36E-02	1.6012E+00	2.7409E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8683090	0.9306610	0.9356900	0.9758180	0.8913750	5.2805E+01	3.9342E+00
α_2	1.80E-02	5.88E-02	5.36E-02	1.17E-01	9.58E-02	3.3337E+00	5.3406E+01
α_3	1.01E-04	1.06E-02	5.64E-03	3.79E-02	1.28E-02	6.0052E-01	5.6139E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8801540	0.9312460	0.9347590	0.9703330	0.8881660	7.5917E+01	5.6050E+00
α_2	1.49E-02	4.52E-02	4.15E-02	8.81E-02	7.33E-02	3.6864E+00	7.7836E+01
α_3	2.09E-03	1.81E-02	1.43E-02	4.70E-02	3.19E-02	1.4737E+00	8.0048E+01
α_4	1.12E-05	5.46E-03	2.24E-03	2.18E-02	6.63E-03	4.4487E-01	8.1077E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113660	0.9458520	0.9479600	0.9731450	0.9003610	1.3297E+02	7.6123E+00
α_2	9.57E-03	2.80E-02	2.58E-02	5.40E-02	4.45E-02	3.9348E+00	1.3665E+02
α_3	3.89E-03	1.73E-02	1.51E-02	3.83E-02	3.56E-02	2.4311E+00	1.3815E+02
α_4	4.02E-04	7.30E-03	5.13E-03	2.16E-02	1.59E-02	1.0260E+00	1.3956E+02
α_5	5.90E-09	1.57E-03	2.08E-04	7.87E-03	3.62E-03	2.2038E-01	1.4036E+02

Strainers, Trash Racks, and Filters
 Extreme Environmental Event CCF Distributions
 SERVICE WATER STRAINER PLUG ENVIRONMENTAL SPAR:STR-EE-PG
CCCG = 6

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9187530	0.9491320	0.9508900	0.9734970	0.9099760	1.6080E+02	8.6179E+00
α_2	7.04E-03	2.17E-02	1.98E-02	4.27E-02	2.98E-02	3.6747E+00	1.6574E+02
α_3	3.62E-03	1.52E-02	1.33E-02	3.32E-02	2.97E-02	2.5753E+00	1.6684E+02
α_4	1.11E-03	9.06E-03	7.21E-03	2.33E-02	1.96E-02	1.5346E+00	1.6788E+02
α_5	5.10E-05	3.84E-03	2.15E-03	1.34E-02	8.90E-03	6.5130E-01	1.6877E+02
α_6	2.72E-10	1.07E-03	8.58E-05	5.67E-03	2.05E-03	1.8204E-01	1.6924E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9363500	0.8913750	0.8881660	0.9003610	0.9099760
α_2	6.36E-02	9.58E-02	7.33E-02	4.45E-02	2.98E-02
α_3		1.28E-02	3.19E-02	3.56E-02	2.97E-02
α_4			6.63E-03	1.59E-02	1.96E-02
α_5				3.62E-03	8.90E-03
α_6					2.05E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.36E-01	8.91E-01	8.88E-01	9.00E-01	9.10E-01
Beta	6.36E-02	1.09E-01	1.12E-01	9.96E-02	9.00E-02
Gamma		1.18E-01	3.44E-01	5.53E-01	6.69E-01
Delta			1.72E-01	3.55E-01	5.06E-01
Epsilon				1.85E-01	3.59E-01
Mu					1.87E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	14.33	21.50	28.67	35.83	43.00
N₁	2.8333	1.7500	1.1111	0.9838	0.8623
N₂	1.1667	2.5000	2.4583	1.8206	1.4355
N₃		0.3333	1.0694	1.4537	1.4335
N₄			0.2222	0.6516	0.9424
N₅				0.1481	0.4291
N₆					0.0988

1.6.6.4 SERVICE WATER TSA PLUG ENVIRONMENTAL SPAR:TS-EE-PG

System :	Circulating water system
	Normally operating service water
	Standby service water
Component :	Strainer
Failure Mode :	No flow/plugged
Component Group :	Traveling Screen
Prox. Cause :	Extreme environmental stress
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 25.00

Total Number of Common-Cause Failure Events: 17

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.5912630	0.7166530	0.7205040	0.8288590	0.6211870	2.7111E+01	1.0719E+01
α_2	1.71E-01	2.83E-01	2.79E-01	4.09E-01	3.79E-01	1.0719E+01	2.7111E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.6911370	0.7799070	0.7827980	0.8587870	0.6144970	5.0530E+01	1.4260E+01
α_2	4.87E-02	1.03E-01	9.85E-02	1.70E-01	1.70E-01	6.6453E+00	5.8145E+01
α_3	5.96E-02	1.18E-01	1.14E-01	1.89E-01	2.15E-01	7.6145E+00	5.7175E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.7278580	0.8010860	0.8033680	0.8665220	0.6101540	7.0714E+01	1.7559E+01
α_2	3.88E-02	8.01E-02	7.69E-02	1.32E-01	1.45E-01	7.0674E+00	8.1205E+01
α_3	3.24E-02	7.09E-02	6.77E-02	1.20E-01	1.45E-01	6.2603E+00	8.2012E+01
α_4	1.74E-02	4.79E-02	4.45E-02	9.01E-02	9.95E-02	4.2310E+00	8.4042E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8108090	0.8605090	0.8621610	0.9045780	0.6358340	1.2551E+02	2.0346E+01
α_2	1.80E-02	4.08E-02	3.87E-02	7.08E-02	8.32E-02	5.9523E+00	1.3990E+02
α_3	2.50E-02	5.09E-02	4.89E-02	8.39E-02	1.40E-01	7.4298E+00	1.3843E+02
α_4	1.34E-02	3.39E-02	3.18E-02	6.15E-02	9.89E-02	4.9411E+00	1.4091E+02
α_5	2.52E-03	1.39E-02	1.17E-02	3.26E-02	4.23E-02	2.0223E+00	1.4383E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8339720	0.8772210	0.8786710	0.9155100	0.6732390	1.5194E+02	2.1266E+01
α_2	6.09E-03	1.98E-02	1.80E-02	3.97E-02	2.29E-02	3.4272E+00	1.6978E+02
α_3	2.21E-02	4.44E-02	4.27E-02	7.27E-02	1.26E-01	7.6927E+00	1.6551E+02
α_4	1.49E-02	3.41E-02	3.24E-02	5.94E-02	1.02E-01	5.9133E+00	1.6729E+02
α_5	5.27E-03	1.83E-02	1.65E-02	3.75E-02	5.66E-02	3.1672E+00	1.7004E+02
α_6	3.70E-04	6.15E-03	4.39E-03	1.80E-02	1.89E-02	1.0657E+00	1.7214E+02

Strainers, Trash Racks, and Filters
 Extreme Environmental Event CCF Distributions
 SERVICE WATER TSA PLUG ENVIRONMENTAL SPAR:TS-EE-PG
ALPHA FACTOR and MGL PARAMETERS

2010

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.6211870	0.6144970	0.6101540	0.6358340	0.6732390
α_2	3.79E-01	1.70E-01	1.45E-01	8.32E-02	2.29E-02
α_3		2.15E-01	1.45E-01	1.40E-01	1.26E-01
α_4			9.95E-02	9.89E-02	1.02E-01
α_5				4.23E-02	5.66E-02
α_6					1.89E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	6.21E-01	6.14E-01	6.10E-01	6.36E-01	6.73E-01
Beta	3.79E-01	3.86E-01	3.90E-01	3.64E-01	3.27E-01
Gamma		5.58E-01	6.28E-01	7.72E-01	9.30E-01
Delta			4.06E-01	5.02E-01	5.85E-01
Epsilon				2.99E-01	4.25E-01
Mu					2.50E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	11.66	17.48	23.31	29.14	34.97
N ₁	5.2048	3.4955	1.2679	0.2054	0.0300
N ₂	10.2845	5.8116	5.8393	3.8381	1.1880
N ₃		7.3473	5.8560	6.4524	6.5509
N ₄			4.0083	4.5667	5.3211
N ₅				1.9500	2.9450
N ₆					0.9825

1.7 Heat Exchangers

1.7.1 PWR HEAT EXCHANGER LOSS OF HEAT TRANSFER

1.7.1.1 PWR RHR HEAT EXCHANGER PLUG/LOSS OF HEAT TRANSFER

System : Residual Heat Removal (LCI in BWRs, LPI in PWRs)

Component : Heat Exchanger

Failure Mode : High dP across filter

Loss of heat transfer capabilities in heat exchangers

No flow/plugged

Plant Type : PWR

Start Date : 1997/01/01

Data Version : 2010/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
α_2	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
α_2	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
α_3	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
α_2	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
α_3	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
α_4	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

PWR HEAT EXCHANGER LOSS OF HEAT TRANSFER

PWR RHR HEAT EXCHANGER PLUG/LOSS OF HEAT TRANSFER

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	2.00	2.00	2.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

Pooled Heat Exchanger Plugged or Failure to Transfer Heat

HEAT EXCHANGER PLUGGED ALL SYSTEMS NON ENVIRO SPAR:HTX-PG

1.7.2 Pooled Heat Exchanger Plugged or Failure to Transfer Heat

1.7.2.1 HEAT EXCHANGER PLUGGED ALL SYSTEMS NON ENVIRO SPAR:HTX-PG

Component :	Heat Exchanger
Failure Mode :	Loss of heat transfer capabilities in heat exchangers
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part Unknown
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 19.60

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8999170	0.9748730	0.9895490	0.9999470	0.9994530	1.7002E+01	4.3822E-01
α_2	4.87E-05	2.51E-02	1.04E-02	1.00E-01	5.47E-04	4.3822E-01	1.7002E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9224360	0.9727520	0.9800330	0.9981620	0.9989450	3.9683E+01	1.1116E+00
α_2	6.84E-04	2.07E-02	1.35E-02	6.52E-02	1.05E-03	8.4426E-01	3.9950E+01
α_3	2.31E-07	6.55E-03	1.32E-03	3.11E-02	9.86E-06	2.6732E-01	4.0527E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9271730	0.9694980	0.9744410	0.9949080	0.9984460	5.9630E+01	1.8761E+00
α_2	1.74E-03	2.03E-02	1.54E-02	5.57E-02	1.52E-03	1.2486E+00	6.0257E+01
α_3	7.48E-06	6.58E-03	2.45E-03	2.72E-02	3.70E-05	4.0481E-01	6.1101E+01
α_4	1.56E-08	3.62E-03	4.96E-04	1.81E-02	0.00E+00	2.2267E-01	6.1283E+01

Pooled Heat Exchanger Plugged or Failure to Transfer Heat

HEAT EXCHANGER PLUGGED ALL SYSTEMS NON ENVIRO SPAR:HTX-PG

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9994530	0.9989450	0.9984460
α_2	5.47E-04	1.05E-03	1.52E-03
α_3		9.86E-06	3.70E-05
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.99E-01	9.99E-01	9.98E-01
Beta	5.47E-04	1.06E-03	1.55E-03
Gamma		9.35E-03	2.38E-02
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	6.53	9.80	13.07
N ₁	0.2260	0.3284	0.4242
N ₂	0.0037	0.0106	0.0205
N ₃		0.0001	0.0005
N ₄			0.0000

1.7.3 Containment Spray Heat Exchanger

1.7.3.1 CONTAINMENT SPRAY HTX LOSS OF HEAT TRANSFER

System :	Containment spray recirculation
Component :	Heat Exchanger
Failure Mode :	Fail to Operate (General operation failure, rate based) Loss of heat transfer capabilities in heat exchangers No flow/plugged
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8687700	0.9670330	0.9862440	0.9999400	1.0000000	1.2746E+01	4.3452E-01
α_2	6.16E-05	3.30E-02	1.38E-02	1.31E-01	0.00E+00	4.3452E-01	1.2746E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
α_1	1.0000000
α_2	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	2.50
N_1	0.0000
N_2	0.0000

1.7.4 BWR Residual Heat Removal Heat Exchanger

1.7.4.1 BWR RHR HEAT EXCHANGER LOSS OF HEAT TRANSFER CAPABILITIES

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Heat Exchanger
Failure Mode :	High dP across filter Loss of heat transfer capabilities in heat exchangers No flow/plugged
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
α_2	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
α_2	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
α_3	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
α_2	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
α_3	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
α_4	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

BWR Residual Heat Removal Heat Exchanger

BWR RHR HEAT EXCHANGER LOSS OF HEAT TRANSFER CAPABILITIES

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	2.00	2.00	2.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.7.5 BWR Isolation Condenser Heat Exchanger

1.7.5.1 ISO CONDENSER HEAT EXCHANGER PLUG/LOSS OF HEAT TRANSFER

System :	Isolation condenser
Component :	Heat Exchanger
Failure Mode :	High dP across filter Loss of heat transfer capabilities in heat exchangers No flow/plugged
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8386830	0.9593170	0.9828300	0.9999250	0.0000000	1.0246E+01	4.3452E-01
α_2	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8979020	0.9640890	0.9736330	0.9976040	0.0000000	2.9555E+01	1.1009E+00
α_2	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
α_3	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9077330	0.9613450	0.9675780	0.9936050	0.0000000	4.6136E+01	1.8551E+00
α_2	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
α_3	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
α_4	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.0000000	0.0000000	0.0000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

BWR Isolation Condenser Heat Exchanger

ISO CONDENSER HEAT EXCHANGER PLUG/LOSS OF HEAT TRANSFER

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	0.00	0.00	0.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

Component Cooling Heat Exchanger

CCW HEAT EXCHANGER LOSS OF HEAT TRANSFER SPAR: CCW-HTX-PG

1.7.6 Component Cooling Heat Exchanger

1.7.6.1 CCW HEAT EXCHANGER LOSS OF HEAT TRANSFER SPAR: CCW-HTX-PG

System :	Component cooling water
Component :	Heat Exchanger
Failure Mode :	Fail to Operate (General operation failure, rate based) Loss of heat transfer capabilities in heat exchangers No flow/plugged
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 20.60

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8930490	0.9697340	0.9834560	0.9996960	0.9816940	1.9379E+01	6.0482E-01
α_2	3.07E-04	3.03E-02	1.65E-02	1.07E-01	1.83E-02	6.0482E-01	1.9379E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9091620	0.9636650	0.9704010	0.9950860	0.9627200	4.2743E+01	1.6116E+00
α_2	3.01E-03	3.03E-02	2.36E-02	8.07E-02	3.73E-02	1.3443E+00	4.3010E+01
α_3	2.12E-07	6.03E-03	1.22E-03	2.86E-02	7.30E-06	2.6732E-01	4.4087E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9089030	0.9563680	0.9609160	0.9882680	0.9430410	6.3040E+01	2.8761E+00
α_2	7.12E-03	3.41E-02	2.95E-02	7.69E-02	5.69E-02	2.2486E+00	6.3667E+01
α_3	6.97E-06	6.14E-03	2.28E-03	2.54E-02	2.79E-05	4.0481E-01	6.5511E+01
α_4	1.46E-08	3.38E-03	4.62E-04	1.69E-02	0.00E+00	2.2267E-01	6.5693E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9816940	0.9627200	0.9430410
α_2	1.83E-02	3.73E-02	5.69E-02
α_3		7.30E-06	2.79E-05
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.82E-01	9.63E-01	9.43E-01
Beta	1.83E-02	3.73E-02	5.70E-02
Gamma		1.96E-04	4.90E-04
Delta			0.00E+00

Component Cooling Heat Exchanger

CCW HEAT EXCHANGER LOSS OF HEAT TRANSFER SPAR: CCW-HTX-PG

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	8.24	12.36	16.48
N ₁	0.8927	0.8284	0.4242
N ₂	0.1703	0.5106	1.0205
N ₃		0.0001	0.0005
N ₄			0.0000

1.8 Safety and Relief Valves

1.8.1 Pooled Safety Valves

1.8.1.1 SAFETY VALVES (DIRECT ACTING) FAIL TO OPEN ALL SYS

Component : Safety Valve (Single Acting)
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 3.00

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8416100	0.9581450	0.9801360	0.9998350	0.9467440	1.1284E+01	4.9292E-01
α_2	1.63E-04	4.19E-02	1.99E-02	1.58E-01	5.33E-02	4.9292E-01	1.1284E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8939080	0.9608260	0.9699400	0.9965220	0.8964810	3.0948E+01	1.2618E+00
α_2	1.57E-03	3.07E-02	2.16E-02	9.08E-02	9.90E-02	9.8746E-01	3.1222E+01
α_3	3.93E-07	8.52E-03	1.81E-03	4.01E-02	4.57E-03	2.7432E-01	3.1935E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9020960	0.9569720	0.9629390	0.9914180	0.8508220	4.7819E+01	2.1501E+00
α_2	3.58E-03	2.99E-02	2.39E-02	7.69E-02	1.36E-01	1.4962E+00	4.8473E+01
α_3	1.46E-05	8.62E-03	3.44E-03	3.48E-02	1.34E-02	4.3071E-01	4.9538E+01
α_4	1.99E-08	4.47E-03	6.16E-04	2.24E-02	2.53E-04	2.2317E-01	4.9746E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9252350	0.9609280	0.9639040	0.9864380	0.8096950	9.8074E+01	3.9878E+00
α_2	5.70E-03	2.45E-02	2.15E-02	5.37E-02	1.64E-01	2.5006E+00	9.9561E+01
α_3	5.77E-04	1.02E-02	7.20E-03	2.99E-02	2.56E-02	1.0378E+00	1.0102E+02
α_4	2.56E-06	3.69E-03	1.26E-03	1.56E-02	1.14E-03	3.7709E-01	1.0168E+02
α_5	5.85E-21	7.08E-04	4.01E-07	4.10E-03	0.00E+00	7.2277E-02	1.0199E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9282440	0.9605120	0.9629670	0.9843880	0.7732650	1.1904E+02	4.8939E+00
α_2	5.60E-03	2.21E-02	1.96E-02	4.72E-02	1.83E-01	2.7363E+00	1.2120E+02
α_3	8.61E-04	1.01E-02	7.61E-03	2.78E-02	4.05E-02	1.2517E+00	1.2268E+02
α_4	4.60E-05	4.84E-03	2.56E-03	1.74E-02	3.02E-03	6.0042E-01	1.2333E+02
α_5	7.50E-09	1.79E-03	2.43E-04	8.98E-03	0.00E+00	2.2220E-01	1.2371E+02
α_6	1.14E-18	6.72E-04	1.18E-06	3.92E-03	0.00E+00	8.3237E-02	1.2385E+02

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9378850	0.9626420	0.9642250	0.9819880	0.7408230	1.8629E+02	7.2294E+00
α_2	6.17E-03	1.90E-02	1.74E-02	3.74E-02	1.96E-01	3.6799E+00	1.8984E+02
α_3	1.46E-03	9.32E-03	7.70E-03	2.28E-02	5.72E-02	1.8043E+00	1.9172E+02
α_4	2.74E-04	5.21E-03	3.63E-03	1.55E-02	6.34E-03	1.0081E+00	1.9251E+02
α_5	1.33E-05	2.70E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9300E+02
α_6	3.47E-10	9.63E-04	8.22E-05	5.05E-03	0.00E+00	1.8628E-01	1.9333E+02
α_7	0.00E+00	1.50E-04	1.32E-13	5.66E-04	0.00E+00	2.9071E-02	1.9349E+02

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9409490	0.9633480	0.9646850	0.9811730	0.7140320	2.2110E+02	8.4121E+00
α_2	6.03E-03	1.75E-02	1.61E-02	3.36E-02	2.00E-01	4.0111E+00	2.2550E+02
α_3	1.53E-03	8.65E-03	7.27E-03	2.05E-02	7.40E-02	1.9846E+00	2.2753E+02
α_4	3.92E-04	5.16E-03	3.82E-03	1.45E-02	1.16E-02	1.1850E+00	2.2833E+02
α_5	5.62E-05	3.09E-03	1.81E-03	1.04E-02	0.00E+00	7.0833E-01	2.2880E+02
α_6	9.05E-07	1.60E-03	5.24E-04	6.84E-03	0.00E+00	3.6696E-01	2.2915E+02
α_7	7.10E-14	5.36E-04	9.64E-06	3.05E-03	0.00E+00	1.2297E-01	2.2939E+02
α_8	1.33E-42	1.44E-04	2.06E-12	6.10E-04	0.00E+00	3.3124E-02	2.2948E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9467440	0.8964810	0.8508220	0.8096950	0.7732650	0.7408230	0.7140320
α_2	5.33E-02	9.90E-02	1.36E-01	1.64E-01	1.83E-01	1.96E-01	2.00E-01
α_3		4.57E-03	1.34E-02	2.56E-02	4.05E-02	5.72E-02	7.40E-02
α_4			2.53E-04	1.14E-03	3.02E-03	6.34E-03	1.16E-02
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.47E-01	8.96E-01	8.51E-01	8.10E-01	7.73E-01	7.41E-01	7.14E-01
Beta	5.33E-02	1.04E-01	1.49E-01	1.90E-01	2.27E-01	2.59E-01	2.86E-01
Gamma		4.41E-02	9.12E-02	1.40E-01	1.92E-01	2.45E-01	2.99E-01
Delta			1.86E-02	4.28E-02	6.94E-02	9.98E-02	1.35E-01
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

SAFETY VALVES (DIRECT ACTING) FAIL TO OPEN ALL SYS

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.38	0.56	0.75	0.94	1.13	1.31	1.50
N ₁	0.6582	0.8334	0.9325	0.9725	0.9681	0.9321	0.8748
N ₂	0.0584	0.1538	0.2681	0.3864	0.4971	0.5921	0.6664
N ₃		0.0071	0.0264	0.0604	0.1099	0.1731	0.2462
N ₄			0.0005	0.0027	0.0082	0.0192	0.0385
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.8.1.2 SAFETY VALVES (DIRECT ACTING) FAIL TO CLOSE ALL SYS

Component :	Safety Valve (Single Acting)
Failure Mode :	Fail to close (reseat) on demand
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 7.00

Total Number of Common-Cause Failure Events: 1

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8520040	0.9624790	0.9839450	0.9999230	0.9926000	1.1359E+01	4.4282E-01
α_2	7.92E-05	3.75E-02	1.61E-02	1.48E-01	7.40E-03	4.4282E-01	1.1359E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9016600	0.9651600	0.9742450	0.9975600	0.9849400	3.1190E+01	1.1259E+00
α_2	9.29E-04	2.66E-02	1.76E-02	8.29E-02	1.51E-02	8.5866E-01	3.1457E+01
α_3	2.91E-07	8.27E-03	1.68E-03	3.92E-02	0.00E+00	2.6722E-01	3.2049E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9101260	0.9620430	0.9680200	0.9935000	0.9772730	4.8286E+01	1.9051E+00
α_2	2.29E-03	2.55E-02	1.95E-02	6.92E-02	2.27E-02	1.2781E+00	4.8913E+01
α_3	9.10E-06	8.06E-03	3.00E-03	3.33E-02	0.00E+00	4.0431E-01	4.9787E+01
α_4	1.92E-08	4.44E-03	6.09E-04	2.22E-02	0.00E+00	2.2267E-01	4.9968E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9305070	0.9646440	0.9676270	0.9885670	0.9695050	9.8809E+01	3.6215E+00
α_2	4.33E-03	2.15E-02	1.84E-02	4.90E-02	3.05E-02	2.1975E+00	1.0023E+02
α_3	4.66E-04	9.54E-03	6.60E-03	2.87E-02	0.00E+00	9.7738E-01	1.0145E+02
α_4	2.40E-06	3.66E-03	1.23E-03	1.55E-02	0.00E+00	3.7439E-01	1.0206E+02
α_5	5.83E-21	7.06E-04	3.99E-07	4.09E-03	0.00E+00	7.2277E-02	1.0236E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9339130	0.9646220	0.9670870	0.9869070	0.9615980	1.2007E+02	4.4037E+00
α_2	4.15E-03	1.90E-02	1.65E-02	4.24E-02	3.84E-02	2.3642E+00	1.2211E+02
α_3	6.46E-04	9.17E-03	6.71E-03	2.61E-02	0.00E+00	1.1418E+00	1.2333E+02
α_4	4.26E-05	4.76E-03	2.49E-03	1.72E-02	0.00E+00	5.9222E-01	1.2388E+02
α_5	7.47E-09	1.79E-03	2.42E-04	8.94E-03	0.00E+00	2.2220E-01	1.2425E+02
α_6	1.13E-18	6.69E-04	1.17E-06	3.90E-03	0.00E+00	8.3237E-02	1.2439E+02

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9421820	0.9659200	0.9675070	0.9842320	0.9534570	1.8763E+02	6.6200E+00
α_2	4.96E-03	1.68E-02	1.52E-02	3.42E-02	4.65E-02	3.2628E+00	1.9099E+02
α_3	1.13E-03	8.40E-03	6.78E-03	2.12E-02	0.00E+00	1.6312E+00	1.9262E+02
α_4	2.55E-04	5.09E-03	3.52E-03	1.53E-02	0.00E+00	9.8887E-01	1.9326E+02
α_5	1.32E-05	2.69E-03	1.27E-03	1.02E-02	0.00E+00	5.2177E-01	1.9373E+02
α_6	3.46E-10	9.59E-04	8.19E-05	5.03E-03	0.00E+00	1.8628E-01	1.9406E+02
α_7	0.00E+00	1.50E-04	1.31E-13	5.63E-04	0.00E+00	2.9071E-02	1.9422E+02

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9451620	0.9666130	0.9679560	0.9834840	0.9453190	2.2276E+02	7.6943E+00
α_2	4.93E-03	1.55E-02	1.41E-02	3.08E-02	5.47E-02	3.5780E+00	2.2688E+02
α_3	1.12E-03	7.54E-03	6.17E-03	1.87E-02	0.00E+00	1.7384E+00	2.2872E+02
α_4	3.52E-04	4.97E-03	3.64E-03	1.42E-02	0.00E+00	1.1465E+00	2.2931E+02
α_5	5.60E-05	3.07E-03	1.81E-03	1.04E-02	0.00E+00	7.0833E-01	2.2975E+02
α_6	9.01E-07	1.59E-03	5.21E-04	6.81E-03	0.00E+00	3.6696E-01	2.3009E+02
α_7	7.07E-14	5.34E-04	9.60E-06	3.04E-03	0.00E+00	1.2297E-01	2.3033E+02
α_8	1.32E-42	1.44E-04	2.05E-12	6.07E-04	0.00E+00	3.3124E-02	2.3042E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9926000	0.9849400	0.9772730	0.9695050	0.9615980	0.9534570	0.9453190
α_2	7.40E-03	1.51E-02	2.27E-02	3.05E-02	3.84E-02	4.65E-02	5.47E-02
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.93E-01	9.85E-01	9.77E-01	9.70E-01	9.62E-01	9.53E-01	9.45E-01
Beta	7.40E-03	1.51E-02	2.27E-02	3.05E-02	3.84E-02	4.65E-02	5.47E-02
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.88	1.31	1.75	2.19	2.63	3.06	3.50
N ₁	0.2333	0.3250	0.4000	0.4583	0.5000	0.5250	0.5333
N ₂	0.0083	0.0250	0.0500	0.0833	0.1250	0.1750	0.2333
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.8.2 PWR Steam Generator Safety Valves

1.8.2.1 PWR MAIN STEAM CODE SAFETIES FAIL TO OPEN

System :	Main steam
Component :	Safety Valve (Single Acting)
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8382550	0.9572370	0.9796800	0.9998310	0.9310180	1.1034E+01	4.9292E-01
α_2	1.67E-04	4.28E-02	2.03E-02	1.62E-01	6.90E-02	4.9292E-01	1.1034E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8927010	0.9603710	0.9695830	0.9964800	0.8641390	3.0578E+01	1.2618E+00
α_2	1.59E-03	3.10E-02	2.18E-02	9.18E-02	1.30E-01	9.8746E-01	3.0852E+01
α_3	3.97E-07	8.62E-03	1.83E-03	4.05E-02	6.00E-03	2.7432E-01	3.1565E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9011290	0.9565370	0.9625600	0.9913290	0.8003380	4.7319E+01	2.1501E+00
α_2	3.62E-03	3.02E-02	2.42E-02	7.77E-02	1.81E-01	1.4962E+00	4.7973E+01
α_3	1.48E-05	8.71E-03	3.47E-03	3.51E-02	1.79E-02	4.3071E-01	4.9038E+01
α_4	2.01E-08	4.51E-03	6.23E-04	2.26E-02	3.38E-04	2.2317E-01	4.9246E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9310180	0.8641390	0.8003380
α_2	6.90E-02	1.30E-01	1.81E-01
α_3		6.00E-03	1.79E-02
α_4			3.38E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.31E-01	8.64E-01	8.00E-01
Beta	6.90E-02	1.36E-01	2.00E-01
Gamma		4.41E-02	9.12E-02
Delta			1.86E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	0.13	0.19	0.25
N ₁	0.6582	0.8334	0.9325
N ₂	0.0584	0.1538	0.2681
N ₃		0.0071	0.0264
N ₄			0.0005

1.8.2.2 PWR MAIN STEAM CODE SAFETIES FAIL TO CLOSE

System :	Main steam
Component :	Safety Valve (Single Acting)
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8503880	0.9620610	0.9837560	0.9999220	0.9916300	1.1229E+01	4.4282E-01
α_2	8.01E-05	3.79E-02	1.62E-02	1.50E-01	8.37E-03	4.4282E-01	1.1229E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9011190	0.9649650	0.9740980	0.9975450	0.9831080	3.1010E+01	1.1259E+00
α_2	9.34E-04	2.67E-02	1.77E-02	8.33E-02	1.69E-02	8.5866E-01	3.1277E+01
α_3	2.93E-07	8.32E-03	1.69E-03	3.94E-02	0.00E+00	2.6722E-01	3.1869E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9096840	0.9618530	0.9678530	0.9934660	0.9743590	4.8036E+01	1.9051E+00
α_2	2.30E-03	2.56E-02	1.96E-02	6.95E-02	2.56E-02	1.2781E+00	4.8663E+01
α_3	9.14E-06	8.10E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9537E+01
α_4	1.93E-08	4.46E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9718E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9302990	0.9645370	0.9675290	0.9885310	0.9656010	9.8499E+01	3.6215E+00
α_2	4.34E-03	2.15E-02	1.85E-02	4.91E-02	3.44E-02	2.1975E+00	9.9923E+01
α_3	4.68E-04	9.57E-03	6.62E-03	2.88E-02	0.00E+00	9.7738E-01	1.0114E+02
α_4	2.41E-06	3.67E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0175E+02
α_5	5.85E-21	7.08E-04	4.00E-07	4.10E-03	0.00E+00	7.2277E-02	1.0205E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9337130	0.9645130	0.9669850	0.9868660	0.9565220	1.1969E+02	4.4037E+00
α_2	4.16E-03	1.91E-02	1.65E-02	4.26E-02	4.35E-02	2.3642E+00	1.2173E+02
α_3	6.48E-04	9.20E-03	6.73E-03	2.62E-02	0.00E+00	1.1418E+00	1.2295E+02
α_4	4.27E-05	4.77E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2350E+02
α_5	7.49E-09	1.79E-03	2.43E-04	8.97E-03	0.00E+00	2.2220E-01	1.2387E+02
α_6	1.14E-18	6.71E-04	1.17E-06	3.92E-03	0.00E+00	8.3237E-02	1.2401E+02

PWR Steam Generator Safety Valves

PWR MAIN STEAM CODE SAFETIES FAIL TO CLOSE

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9420580	0.9658460	0.9674360	0.9841980	0.9474470	1.8721E+02	6.6200E+00
α_2	4.97E-03	1.68E-02	1.52E-02	3.43E-02	5.26E-02	3.2628E+00	1.9057E+02
α_3	1.13E-03	8.42E-03	6.80E-03	2.12E-02	0.00E+00	1.6312E+00	1.9220E+02
α_4	2.56E-04	5.10E-03	3.53E-03	1.53E-02	0.00E+00	9.8887E-01	1.9284E+02
α_5	1.32E-05	2.69E-03	1.27E-03	1.02E-02	0.00E+00	5.2177E-01	1.9331E+02
α_6	3.47E-10	9.61E-04	8.21E-05	5.04E-03	0.00E+00	1.8628E-01	1.9364E+02
α_7	0.00E+00	1.50E-04	1.31E-13	5.65E-04	0.00E+00	2.9071E-02	1.9380E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9450440	0.9665400	0.9678870	0.9834470	0.9380610	2.2226E+02	7.6943E+00
α_2	4.94E-03	1.56E-02	1.42E-02	3.09E-02	6.19E-02	3.5780E+00	2.2638E+02
α_3	1.12E-03	7.56E-03	6.19E-03	1.87E-02	0.00E+00	1.7384E+00	2.2822E+02
α_4	3.53E-04	4.99E-03	3.64E-03	1.42E-02	0.00E+00	1.1465E+00	2.2881E+02
α_5	5.61E-05	3.08E-03	1.81E-03	1.04E-02	0.00E+00	7.0833E-01	2.2925E+02
α_6	9.03E-07	1.60E-03	5.22E-04	6.83E-03	0.00E+00	3.6696E-01	2.2959E+02
α_7	7.08E-14	5.35E-04	9.62E-06	3.04E-03	0.00E+00	1.2297E-01	2.2983E+02
α_8	1.33E-42	1.44E-04	2.05E-12	6.09E-04	0.00E+00	3.3124E-02	2.2992E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9916300	0.9831080	0.9743590	0.9656010	0.9565220	0.9474470	0.9380610
α_2	8.37E-03	1.69E-02	2.56E-02	3.44E-02	4.35E-02	5.26E-02	6.19E-02
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.92E-01	9.83E-01	9.74E-01	9.66E-01	9.57E-01	9.47E-01	9.38E-01
Beta	8.37E-03	1.69E-02	2.56E-02	3.44E-02	4.35E-02	5.26E-02	6.19E-02
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.75	1.13	1.50	1.88	2.25	2.63	3.00
N ₁	0.2333	0.3250	0.4000	0.4583	0.5000	0.5250	0.5333
N ₂	0.0083	0.0250	0.0500	0.0833	0.1250	0.1750	0.2333
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.8.3 BWR Safety Relief Valves

1.8.3.1 SAFETY RELIEF VALVE FAIL TO OPEN SPAR: SRV-CC

Component : Safety Relief Valve (Dual Actuation)
Failure Mode : Fail to open on demand
Plant Type : BWR
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 21.00

Total Number of Common-Cause Failure Events: 5

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8791940	0.9662980	0.9820640	0.9997190	0.9777850	1.6593E+01	5.7872E-01
α_2	2.83E-04	3.37E-02	1.79E-02	1.21E-01	2.22E-02	5.7872E-01	1.6593E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040050	0.9623710	0.9697670	0.9953930	0.9568450	3.8670E+01	1.5120E+00
α_2	2.59E-03	3.07E-02	2.33E-02	8.42E-02	4.20E-02	1.2341E+00	3.8948E+01
α_3	3.62E-07	6.92E-03	1.50E-03	3.24E-02	1.12E-03	2.7792E-01	3.9904E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9066350	0.9563910	0.9613440	0.9891940	0.9372740	5.7794E+01	2.6353E+00
α_2	5.78E-03	3.25E-02	2.75E-02	7.65E-02	5.93E-02	1.9663E+00	5.8463E+01
α_3	1.55E-05	7.38E-03	3.04E-03	2.94E-02	3.35E-03	4.4601E-01	5.9983E+01
α_4	1.62E-08	3.69E-03	5.07E-04	1.85E-02	2.41E-05	2.2297E-01	6.0206E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9251620	0.9592340	0.9618760	0.9842800	0.9247780	1.1028E+02	4.6868E+00
α_2	7.75E-03	2.71E-02	2.44E-02	5.57E-02	6.58E-02	3.1182E+00	1.1185E+02
α_3	6.59E-04	9.75E-03	7.09E-03	2.79E-02	9.37E-03	1.1204E+00	1.1385E+02
α_4	2.21E-06	3.27E-03	1.11E-03	1.39E-02	9.82E-05	3.7589E-01	1.1459E+02
α_5	5.19E-21	6.29E-04	3.55E-07	3.64E-03	0.00E+00	7.2277E-02	1.1489E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9271430	0.9581910	0.9603680	0.9817880	0.9143510	1.3341E+02	5.8212E+00
α_2	7.84E-03	2.51E-02	2.28E-02	5.00E-02	6.95E-02	3.4903E+00	1.3574E+02
α_3	1.10E-03	1.02E-02	7.98E-03	2.69E-02	1.55E-02	1.4216E+00	1.3781E+02
α_4	4.22E-05	4.34E-03	2.30E-03	1.55E-02	6.44E-04	6.0382E-01	1.3863E+02
α_5	6.67E-09	1.60E-03	2.16E-04	8.00E-03	0.00E+00	2.2220E-01	1.3901E+02
α_6	1.01E-18	5.98E-04	1.05E-06	3.49E-03	0.00E+00	8.3237E-02	1.3915E+02

Safety and Relief Valves
 BWR Safety Relief Valves
 SAFETY RELIEF VALVE FAIL TO OPEN SPAR: SRV-CC
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9360390	0.9602910	0.9617340	0.9796090	0.9061800	2.0279E+02	8.3856E+00
α_2	8.06E-03	2.15E-02	2.00E-02	4.00E-02	7.02E-02	4.5393E+00	2.0664E+02
α_3	1.87E-03	9.89E-03	8.39E-03	2.30E-02	2.21E-02	2.0887E+00	2.0909E+02
α_4	2.61E-04	4.83E-03	3.38E-03	1.43E-02	1.47E-03	1.0193E+00	2.1016E+02
α_5	1.23E-05	2.48E-03	1.17E-03	9.35E-03	5.80E-05	5.2297E-01	2.1065E+02
α_6	3.18E-10	8.82E-04	7.53E-05	4.63E-03	0.00E+00	1.8628E-01	2.1099E+02
α_7	0.00E+00	1.38E-04	1.20E-13	5.18E-04	0.00E+00	2.9071E-02	2.1115E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9387250	0.9607840	0.9620120	0.9786510	0.9003310	2.3972E+02	9.7847E+00
α_2	7.77E-03	1.97E-02	1.85E-02	3.60E-02	6.78E-02	4.9258E+00	2.4458E+02
α_3	2.16E-03	9.69E-03	8.42E-03	2.16E-02	2.91E-02	2.4180E+00	2.4709E+02
α_4	3.80E-04	4.83E-03	3.59E-03	1.35E-02	2.51E-03	1.2051E+00	2.4830E+02
α_5	5.31E-05	2.86E-03	1.68E-03	9.64E-03	1.80E-04	7.1253E-01	2.4879E+02
α_6	8.36E-07	1.47E-03	4.82E-04	6.29E-03	8.58E-06	3.6716E-01	2.4914E+02
α_7	6.53E-14	4.93E-04	8.86E-06	2.81E-03	0.00E+00	1.2297E-01	2.4938E+02
α_8	1.22E-42	1.33E-04	1.89E-12	5.61E-04	0.00E+00	3.3124E-02	2.4947E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9777850	0.9568450	0.9372740	0.9247780	0.9143510	0.9061800	0.9003310
α_2	2.22E-02	4.20E-02	5.93E-02	6.58E-02	6.95E-02	7.02E-02	6.78E-02
α_3		1.12E-03	3.35E-03	9.37E-03	1.55E-02	2.21E-02	2.91E-02
α_4			2.41E-05	9.82E-05	6.44E-04	1.47E-03	2.51E-03
α_5				0.00E+00	0.00E+00	5.80E-05	1.80E-04
α_6					0.00E+00	0.00E+00	8.58E-06
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.78E-01	9.57E-01	9.37E-01	9.25E-01	9.14E-01	9.06E-01	9.00E-01
Beta	2.22E-02	4.32E-02	6.27E-02	7.52E-02	8.56E-02	9.38E-02	9.97E-02
Gamma		2.60E-02	5.38E-02	1.26E-01	1.89E-01	2.52E-01	3.20E-01
Delta			7.14E-03	1.04E-02	3.98E-02	6.46E-02	8.48E-02
Epsilon				0.00E+00	0.00E+00	3.80E-02	6.98E-02
Mu					0.00E+00	0.00E+00	4.55E-02
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Safety and Relief Valves
 BWR Safety Relief Valves
 SAFETY RELIEF VALVE FAIL TO OPEN SPAR: SRV-CC

2010

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	4.67	7.00	9.33	11.67	14.00	16.33	18.67
N₁	1.6770	2.1151	2.3281	2.4497	2.4670	2.4137	2.3205
N₂	0.1442	0.4004	0.7382	1.0040	1.2511	1.4515	1.5811
N₃		0.0107	0.0417	0.1430	0.2798	0.4575	0.6796
N₄			0.0003	0.0015	0.0116	0.0304	0.0586
N₅				0.0000	0.0000	0.0012	0.0042
N₆					0.0000	0.0000	0.0002
N₇						0.0000	0.0000
N₈							0.0000

Safety and Relief Valves
 BWR Safety Relief Valves
 SAFETY RELIEF VALVE FAIL TO CLOSE SPAR: SRV-OO

2010

1.8.3.2 SAFETY RELIEF VALVE FAIL TO CLOSE SPAR: SRV-OO

Component :	Safety Relief Valve (Dual Actuation)
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8959650	0.9739500	0.9892430	0.9999480	1.0000000	1.6246E+01	4.3452E-01
α_2	4.81E-05	2.60E-02	1.08E-02	1.04E-01	0.00E+00	4.3452E-01	1.6246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9143470	0.9699670	0.9780280	0.9980130	1.0000000	3.5555E+01	1.1009E+00
α_2	7.25E-04	2.27E-02	1.48E-02	7.18E-02	0.00E+00	8.3366E-01	3.5822E+01
α_3	2.56E-07	7.29E-03	1.48E-03	3.46E-02	0.00E+00	2.6722E-01	3.6389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9178250	0.9656410	0.9712250	0.9943340	1.0000000	5.2136E+01	1.8551E+00
α_2	1.89E-03	2.27E-02	1.72E-02	6.27E-02	0.00E+00	1.2281E+00	5.2763E+01
α_3	8.45E-06	7.49E-03	2.78E-03	3.09E-02	0.00E+00	4.0431E-01	5.3587E+01
α_4	1.78E-08	4.12E-03	5.66E-04	2.07E-02	0.00E+00	2.2267E-01	5.3768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9337450	0.9665250	0.9694270	0.9893730	1.0000000	1.0216E+02	3.5382E+00
α_2	3.85E-03	2.00E-02	1.71E-02	4.62E-02	0.00E+00	2.1142E+00	1.0358E+02
α_3	4.52E-04	9.25E-03	6.39E-03	2.78E-02	0.00E+00	9.7738E-01	1.0472E+02
α_4	2.33E-06	3.54E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0532E+02
α_5	5.65E-21	6.84E-04	3.87E-07	3.96E-03	0.00E+00	7.2277E-02	1.0563E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9366750	0.9663680	0.9687880	0.9877920	1.0000000	1.2294E+02	4.2787E+00
α_2	3.62E-03	1.76E-02	1.51E-02	4.00E-02	0.00E+00	2.2392E+00	1.2498E+02
α_3	6.32E-04	8.98E-03	6.57E-03	2.55E-02	0.00E+00	1.1418E+00	1.2608E+02
α_4	4.16E-05	4.66E-03	2.44E-03	1.68E-02	0.00E+00	5.9222E-01	1.2663E+02
α_5	7.30E-09	1.75E-03	2.37E-04	8.75E-03	0.00E+00	2.2220E-01	1.2700E+02
α_6	1.11E-18	6.54E-04	1.14E-06	3.82E-03	0.00E+00	8.3237E-02	1.2714E+02

Safety and Relief Valves
 BWR Safety Relief Valves
 SAFETY RELIEF VALVE FAIL TO CLOSE SPAR: SRV-OO
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9439980	0.9672000	0.9687770	0.9850250	1.0000000	1.9005E+02	6.4450E+00
α_2	4.43E-03	1.57E-02	1.41E-02	3.25E-02	0.00E+00	3.0878E+00	1.9341E+02
α_3	1.12E-03	8.30E-03	6.70E-03	2.10E-02	0.00E+00	1.6312E+00	1.9486E+02
α_4	2.52E-04	5.03E-03	3.48E-03	1.51E-02	0.00E+00	9.8887E-01	1.9551E+02
α_5	1.31E-05	2.66E-03	1.26E-03	1.00E-02	0.00E+00	5.2177E-01	1.9597E+02
α_6	3.42E-10	9.48E-04	8.09E-05	4.98E-03	0.00E+00	1.8628E-01	1.9631E+02
α_7	0.00E+00	1.48E-04	1.30E-13	5.57E-04	0.00E+00	2.9071E-02	1.9647E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9468590	0.9678670	0.9692050	0.9843190	1.0000000	2.2473E+02	7.4610E+00
α_2	4.33E-03	1.44E-02	1.30E-02	2.92E-02	0.00E+00	3.3447E+00	2.2885E+02
α_3	1.11E-03	7.49E-03	6.13E-03	1.85E-02	0.00E+00	1.7384E+00	2.3045E+02
α_4	3.50E-04	4.94E-03	3.61E-03	1.41E-02	0.00E+00	1.1465E+00	2.3104E+02
α_5	5.55E-05	3.05E-03	1.79E-03	1.03E-02	0.00E+00	7.0833E-01	2.3148E+02
α_6	8.95E-07	1.58E-03	5.17E-04	6.76E-03	0.00E+00	3.6696E-01	2.3182E+02
α_7	7.01E-14	5.30E-04	9.53E-06	3.02E-03	0.00E+00	1.2297E-01	2.3207E+02
α_8	1.31E-42	1.43E-04	2.03E-12	6.03E-04	0.00E+00	3.3124E-02	2.3216E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

SAFETY RELIEF VALVE FAIL TO CLOSE SPAR: SRV-OO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	6.00	6.00	6.00	6.00	6.00	6.00	6.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.8.4 PWR Pressurizer Safety Valve

1.8.4.1 PWR PRESSURIZER CODE SAFETIES FAIL TO OPEN

System :	Reactor coolant
Component :	Safety Valve (Single Acting)
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
α_2	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
α_2	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
α_3	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
α_2	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
α_3	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
α_4	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9311740	0.9652090	0.9682200	0.9889480	1.0000000	9.8161E+01	3.5382E+00
α_2	4.01E-03	2.08E-02	1.77E-02	4.80E-02	0.00E+00	2.1142E+00	9.9585E+01
α_3	4.70E-04	9.61E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0072E+02
α_4	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0132E+02
α_5	5.87E-21	7.11E-04	4.02E-07	4.12E-03	0.00E+00	7.2277E-02	1.0163E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9346440	0.9652760	0.9677640	0.9873890	1.0000000	1.1894E+02	4.2787E+00
α_2	3.74E-03	1.82E-02	1.56E-02	4.13E-02	0.00E+00	2.2392E+00	1.2098E+02
α_3	6.53E-04	9.27E-03	6.78E-03	2.64E-02	0.00E+00	1.1418E+00	1.2208E+02
α_4	4.30E-05	4.81E-03	2.52E-03	1.73E-02	0.00E+00	5.9222E-01	1.2263E+02
α_5	7.54E-09	1.80E-03	2.45E-04	9.04E-03	0.00E+00	2.2220E-01	1.2300E+02
α_6	1.14E-18	6.76E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2314E+02

PWR Pressurizer Safety Valve

PWR PRESSURIZER CODE SAFETIES FAIL TO OPEN

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9428470	0.9665190	0.9681250	0.9847050	1.0000000	1.8605E+02	6.4450E+00
α_2	4.52E-03	1.60E-02	1.44E-02	3.32E-02	0.00E+00	3.0878E+00	1.8941E+02
α_3	1.14E-03	8.47E-03	6.84E-03	2.14E-02	0.00E+00	1.6312E+00	1.9086E+02
α_4	2.57E-04	5.14E-03	3.56E-03	1.54E-02	0.00E+00	9.8887E-01	1.9151E+02
α_5	1.33E-05	2.71E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9197E+02
α_6	3.49E-10	9.68E-04	8.26E-05	5.08E-03	0.00E+00	1.8628E-01	1.9231E+02
α_7	0.00E+00	1.51E-04	1.32E-13	5.69E-04	0.00E+00	2.9071E-02	1.9247E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9459360	0.9673040	0.9686640	0.9840410	1.0000000	2.2073E+02	7.4610E+00
α_2	4.41E-03	1.47E-02	1.33E-02	2.97E-02	0.00E+00	3.3447E+00	2.2485E+02
α_3	1.13E-03	7.62E-03	6.24E-03	1.88E-02	0.00E+00	1.7384E+00	2.2645E+02
α_4	3.56E-04	5.02E-03	3.67E-03	1.43E-02	0.00E+00	1.1465E+00	2.2704E+02
α_5	5.65E-05	3.10E-03	1.82E-03	1.05E-02	0.00E+00	7.0833E-01	2.2748E+02
α_6	9.10E-07	1.61E-03	5.27E-04	6.88E-03	0.00E+00	3.6696E-01	2.2782E+02
α_7	7.14E-14	5.39E-04	9.69E-06	3.07E-03	0.00E+00	1.2297E-01	2.2807E+02
α_8	1.34E-42	1.45E-04	2.07E-12	6.14E-04	0.00E+00	3.3124E-02	2.2816E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.00	2.00	2.00	2.00	2.00	2.00	2.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.8.4.2 PWR PRESSURIZER CODE SAFETIES FAIL TO CLOSE

System :	Reactor coolant
Component :	Safety Valve (Single Acting)
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8522320	0.9628000	0.9843830	0.9999320	1.0000000	1.1246E+01	4.3452E-01
α_2	7.00E-05	3.72E-02	1.56E-02	1.48E-01	0.00E+00	4.3452E-01	1.1246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9010680	0.9652240	0.9744830	0.9976820	1.0000000	3.0555E+01	1.1009E+00
α_2	8.43E-04	2.63E-02	1.72E-02	8.30E-02	0.00E+00	8.3366E-01	3.0822E+01
α_3	2.98E-07	8.44E-03	1.71E-03	4.00E-02	0.00E+00	2.6722E-01	3.1389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9095820	0.9621340	0.9682530	0.9937390	1.0000000	4.7136E+01	1.8551E+00
α_2	2.09E-03	2.51E-02	1.89E-02	6.90E-02	0.00E+00	1.2281E+00	4.7763E+01
α_3	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8587E+01
α_4	1.97E-08	4.55E-03	6.24E-04	2.28E-02	0.00E+00	2.2267E-01	4.8768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	1.00	1.00	1.00
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.9 PORVs

1.9.1 Pooled PORVs

1.9.1.1 POWER OPERATED RELIEF VALVES FAIL TO OPEN ALL SYSTEMS

Component : Power Operated Relief Valve
Failure Mode : Fail to open on demand
Op. Mode : CCF Event Can Only Happen During Power Operation
 CCF Event May Occur During Both Power Operation & Shutdown
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 99.80
 Total Number of Common-Cause Failure Events: 8

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9312520	0.9745140	0.9804040	0.9976200	0.9785230	4.9849E+01	1.3037E+00
α_2	2.38E-03	2.55E-02	1.96E-02	6.87E-02	2.15E-02	1.3037E+00	4.9849E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9293350	0.9655040	0.9688890	0.9901000	0.9662310	8.7244E+01	3.1171E+00
α_2	6.73E-03	2.83E-02	2.49E-02	6.15E-02	2.88E-02	2.5542E+00	8.7807E+01
α_3	4.44E-05	6.23E-03	3.15E-03	2.29E-02	4.95E-03	5.6292E-01	8.9798E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9369540	0.96666090	0.9690390	0.9879640	0.9698160	1.2256E+02	4.2338E+00
α_2	4.40E-03	1.93E-02	1.69E-02	4.27E-02	1.55E-02	2.4533E+00	1.2434E+02
α_3	1.12E-03	1.09E-02	8.45E-03	2.90E-02	1.24E-02	1.3814E+00	1.2541E+02
α_4	3.23E-06	3.15E-03	1.14E-03	1.31E-02	2.24E-03	3.9907E-01	1.2639E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9458650	0.9685690	0.9701370	0.9859100	0.9727030	1.9134E+02	6.2092E+00
α_2	4.50E-03	1.58E-02	1.42E-02	3.26E-02	1.03E-02	3.1228E+00	1.9443E+02
α_3	1.61E-03	9.61E-03	8.02E-03	2.31E-02	9.42E-03	1.8993E+00	1.9565E+02
α_4	2.77E-04	5.15E-03	3.60E-03	1.53E-02	6.57E-03	1.0169E+00	1.9653E+02
α_5	7.35E-11	8.61E-04	5.58E-05	4.62E-03	1.00E-03	1.7018E-01	1.9738E+02

Pooled PORVs

POWER OPERATED RELIEF VALVES FAIL TO OPEN ALL SYSTEMS

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9492920	0.9695440	0.9708490	0.9853270	0.9745680	2.3078E+02	7.2494E+00
α_2	4.10E-03	1.38E-02	1.25E-02	2.81E-02	8.99E-03	3.2896E+00	2.3474E+02
α_3	1.14E-03	7.46E-03	6.13E-03	1.83E-02	5.42E-03	1.7754E+00	2.3625E+02
α_4	6.30E-04	5.93E-03	4.61E-03	1.57E-02	7.01E-03	1.4112E+00	2.3662E+02
α_5	3.35E-05	2.69E-03	1.49E-03	9.45E-03	3.59E-03	6.4100E-01	2.3739E+02
α_6	3.80E-13	5.56E-04	1.39E-05	3.13E-03	4.19E-04	1.3224E-01	2.3790E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9531740	0.9701180	0.9710770	0.9837970	0.9756610	3.1649E+02	9.7488E+00
α_2	4.83E-03	1.33E-02	1.23E-02	2.51E-02	9.23E-03	4.3403E+00	3.2190E+02
α_3	1.14E-03	6.24E-03	5.26E-03	1.47E-02	2.97E-03	2.0350E+00	3.2420E+02
α_4	7.09E-04	5.11E-03	4.14E-03	1.28E-02	4.99E-03	1.6660E+00	3.2457E+02
α_5	2.96E-04	3.72E-03	2.77E-03	1.04E-02	5.09E-03	1.2128E+00	3.2503E+02
α_6	2.77E-06	1.36E-03	5.55E-04	5.45E-03	1.90E-03	4.4458E-01	3.2579E+02
α_7	1.86E-29	1.53E-04	1.75E-09	8.18E-04	1.55E-04	5.0071E-02	3.2619E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9553170	0.9707620	0.9715850	0.9834100	0.9762440	3.6966E+02	1.1134E+01
α_2	5.00E-03	1.28E-02	1.20E-02	2.35E-02	9.90E-03	4.8748E+00	3.7592E+02
α_3	9.91E-04	5.39E-03	4.55E-03	1.26E-02	2.02E-03	2.0512E+00	3.7874E+02
α_4	5.25E-04	4.13E-03	3.30E-03	1.06E-02	2.76E-03	1.5731E+00	3.7922E+02
α_5	3.95E-04	3.71E-03	2.89E-03	9.85E-03	4.56E-03	1.4135E+00	3.7938E+02
α_6	9.79E-05	2.40E-03	1.61E-03	7.42E-03	3.54E-03	9.1486E-01	3.7988E+02
α_7	2.31E-08	6.99E-04	1.38E-04	3.32E-03	9.26E-04	2.6607E-01	3.8053E+02
α_8	5.73E-36	1.05E-04	4.80E-11	5.07E-04	4.53E-05	4.0124E-02	3.8075E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9785230	0.9662310	0.9698160	0.9727030	0.9745680	0.9756610	0.9762440
α_2	2.15E-02	2.88E-02	1.55E-02	1.03E-02	8.99E-03	9.23E-03	9.90E-03
α_3		4.95E-03	1.24E-02	9.42E-03	5.42E-03	2.97E-03	2.02E-03
α_4			2.24E-03	6.57E-03	7.01E-03	4.99E-03	2.76E-03
α_5				1.00E-03	3.59E-03	5.09E-03	4.56E-03
α_6					4.19E-04	1.90E-03	3.54E-03
α_7						1.55E-04	9.26E-04
α_8							4.53E-05

Pooled PORVs

POWER OPERATED RELIEF VALVES FAIL TO OPEN ALL SYSTEMS

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.79E-01	9.66E-01	9.70E-01	9.73E-01	9.75E-01	9.76E-01	9.76E-01
Beta	2.15E-02	3.38E-02	3.02E-02	2.73E-02	2.54E-02	2.43E-02	2.38E-02
Gamma		1.47E-01	4.85E-01	6.22E-01	6.46E-01	6.21E-01	5.83E-01
Delta			1.53E-01	4.45E-01	6.70E-01	8.03E-01	8.54E-01
Epsilon				1.32E-01	3.64E-01	5.89E-01	7.67E-01
Mu					1.05E-01	2.88E-01	4.97E-01
Upsilon						7.52E-02	2.15E-01
Sigma							4.66E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	36.29	54.44	72.58	90.73	108.87	127.02	145.16
N ₁	3.3129	3.2489	3.8484	4.4453	4.9747	5.4152	5.7670
N ₂	0.8692	1.7205	1.2252	1.0086	1.0504	1.2525	1.5301
N ₃		0.2957	0.9771	0.9219	0.6336	0.4038	0.3128
N ₄			0.1764	0.6425	0.8190	0.6771	0.4266
N ₅				0.0979	0.4188	0.6910	0.7052
N ₆					0.0490	0.2583	0.5479
N ₇						0.0210	0.1431
N ₈							0.0070

1.9.1.2 POWER OPERATED RELIEF VALVES FAIL TO CLOSE ALL SYSTEMS

Component :

Power Operated Relief Valve

Failure Mode :

Fail to close (reseat) on demand

Op. Mode :

CCF Event Can Only Happen During Power Operation

CCF Event May Occur During Both Power Operation & Shutdown

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 31.10

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9336460	0.9834320	0.9932310	0.9999660	0.9998910	2.5893E+01	4.3622E-01
α_2	3.08E-05	1.66E-02	6.77E-03	6.64E-02	1.09E-04	4.3622E-01	2.5893E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9415350	0.9795700	0.9851170	0.9986480	0.9997870	5.3025E+01	1.1059E+00
α_2	4.99E-04	1.55E-02	1.01E-02	4.90E-02	2.13E-04	8.3866E-01	5.3292E+01
α_3	1.73E-07	4.94E-03	9.94E-04	2.34E-02	0.00E+00	2.6722E-01	5.3864E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9435460	0.9764750	0.9803590	0.9961230	0.9996800	7.7416E+01	1.8651E+00
α_2	1.31E-03	1.56E-02	1.18E-02	4.31E-02	3.20E-04	1.2381E+00	7.8043E+01
α_3	5.73E-06	5.10E-03	1.89E-03	2.11E-02	0.00E+00	4.0431E-01	7.8877E+01
α_4	1.21E-08	2.81E-03	3.84E-04	1.41E-02	0.00E+00	2.2267E-01	7.9058E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9492370	0.9743960	0.9766440	0.9918800	0.9995910	1.3526E+02	3.5542E+00
α_2	2.97E-03	1.53E-02	1.31E-02	3.54E-02	4.01E-04	2.1299E+00	1.3668E+02
α_3	3.44E-04	7.04E-03	4.86E-03	2.12E-02	7.67E-06	9.7768E-01	1.3784E+02
α_4	1.77E-06	2.70E-03	9.07E-04	1.15E-02	0.00E+00	3.7439E-01	1.3844E+02
α_5	4.29E-21	5.21E-04	2.94E-07	3.01E-03	0.00E+00	7.2277E-02	1.3874E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9517600	0.9744150	0.9762770	0.9907130	0.9995060	1.6384E+02	4.3019E+00
α_2	2.79E-03	1.35E-02	1.16E-02	3.05E-02	4.77E-04	2.2616E+00	1.6588E+02
α_3	4.78E-04	6.80E-03	4.97E-03	1.94E-02	1.70E-05	1.1426E+00	1.6700E+02
α_4	3.15E-05	3.52E-03	1.84E-03	1.27E-02	0.00E+00	5.9222E-01	1.6755E+02
α_5	5.52E-09	1.32E-03	1.79E-04	6.62E-03	0.00E+00	2.2220E-01	1.6792E+02
α_6	8.38E-19	4.95E-04	8.65E-07	2.89E-03	0.00E+00	8.3237E-02	1.6806E+02

Pooled PORVs

POWER OPERATED RELIEF VALVES FAIL TO CLOSE ALL SYSTEMS

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9548720	0.9735890	0.9748690	0.9879420	0.9994210	2.3875E+02	6.4767E+00
α_2	3.61E-03	1.27E-02	1.14E-02	2.63E-02	5.50E-04	3.1179E+00	2.4211E+02
α_3	8.98E-04	6.66E-03	5.37E-03	1.68E-02	2.92E-05	1.6328E+00	2.4359E+02
α_4	2.02E-04	4.03E-03	2.79E-03	1.21E-02	0.00E+00	9.8887E-01	2.4424E+02
α_5	1.05E-05	2.13E-03	1.01E-03	8.04E-03	0.00E+00	5.2177E-01	2.4470E+02
α_6	2.74E-10	7.60E-04	6.48E-05	3.99E-03	0.00E+00	1.8628E-01	2.4504E+02
α_7	0.00E+00	1.19E-04	1.04E-13	4.46E-04	0.00E+00	2.9071E-02	2.4520E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9570100	0.9740180	0.9751080	0.9873170	0.9993430	2.8124E+02	7.5021E+00
α_2	3.55E-03	1.17E-02	1.06E-02	2.37E-02	6.15E-04	3.3832E+00	2.8536E+02
α_3	8.93E-04	6.03E-03	4.93E-03	1.49E-02	4.00E-05	1.7409E+00	2.8700E+02
α_4	2.81E-04	3.97E-03	2.90E-03	1.13E-02	1.60E-06	1.1466E+00	2.8760E+02
α_5	4.46E-05	2.45E-03	1.44E-03	8.30E-03	0.00E+00	7.0833E-01	2.8803E+02
α_6	7.19E-07	1.27E-03	4.16E-04	5.44E-03	0.00E+00	3.6696E-01	2.8838E+02
α_7	5.64E-14	4.26E-04	7.66E-06	2.42E-03	0.00E+00	1.2297E-01	2.8862E+02
α_8	1.06E-42	1.15E-04	1.63E-12	4.85E-04	0.00E+00	3.3124E-02	2.8871E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9998910	0.9997870	0.9996800	0.9995910	0.9995060	0.9994210	0.9993430
α_2	1.09E-04	2.13E-04	3.20E-04	4.01E-04	4.77E-04	5.50E-04	6.15E-04
α_3		0.00E+00	0.00E+00	7.67E-06	1.70E-05	2.92E-05	4.00E-05
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.60E-06
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	9.99E-01	9.99E-01
Beta	1.09E-04	2.13E-04	3.20E-04	4.09E-04	4.94E-04	5.79E-04	6.57E-04
Gamma		0.00E+00	0.00E+00	1.88E-02	3.45E-02	5.05E-02	6.33E-02
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.85E-02
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Pooled PORVs

POWER OPERATED RELIEF VALVES FAIL TO CLOSE ALL SYSTEMS

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	15.55	23.33	31.10	38.88	46.65	54.42	62.20
N ₁	0.0967	0.1400	0.1800	0.2175	0.2523	0.2845	0.3143
N ₂	0.0017	0.0050	0.0100	0.0157	0.0224	0.0301	0.0385
N ₃		0.0000	0.0000	0.0003	0.0008	0.0016	0.0025
N ₄			0.0000	0.0000	0.0000	0.0000	0.0001
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO OPEN SPAR: ADV-CC

1.9.2 PWR Steam Generator PORV

1.9.2.1 PWR MAIN STEAM PORV FAIL TO OPEN SPAR: ADV-CC

System :	Main steam
Component :	Power Operated Relief Valve
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 78.70

Total Number of Common-Cause Failure Events: 6

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9089810	0.9662920	0.9740850	0.9969210	0.9690100	3.6799E+01	1.2837E+00
α_2	3.08E-03	3.37E-02	2.59E-02	9.10E-02	3.10E-02	1.2837E+00	3.6799E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9112620	0.9567510	0.9609950	0.9877200	0.9511450	6.7718E+01	3.0611E+00
α_2	8.26E-03	3.53E-02	3.10E-02	7.71E-02	4.15E-02	2.5002E+00	6.8279E+01
α_3	5.57E-05	7.92E-03	4.00E-03	2.91E-02	7.32E-03	5.6092E-01	7.0218E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9223160	0.9590080	0.9620120	0.9854180	0.9568800	9.6601E+01	4.1292E+00
α_2	5.11E-03	2.34E-02	2.03E-02	5.22E-02	2.14E-02	2.3561E+00	9.8374E+01
α_3	1.39E-03	1.36E-02	1.06E-02	3.64E-02	1.84E-02	1.3742E+00	9.9356E+01
α_4	4.06E-06	3.96E-03	1.44E-03	1.64E-02	3.34E-03	3.9887E-01	1.0033E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9366010	0.9633550	0.9652170	0.9837580	0.9615910	1.5895E+02	6.0463E+00
α_2	4.93E-03	1.80E-02	1.61E-02	3.77E-02	1.32E-02	2.9770E+00	1.6202E+02
α_3	1.89E-03	1.14E-02	9.51E-03	2.75E-02	1.39E-02	1.8831E+00	1.6311E+02
α_4	3.30E-04	6.16E-03	4.31E-03	1.83E-02	9.83E-03	1.0160E+00	1.6398E+02
α_5	8.80E-11	1.03E-03	6.68E-05	5.53E-03	1.50E-03	1.7018E-01	1.6483E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9409440	0.9647240	0.9662690	0.9832240	0.9647540	1.9200E+02	7.0207E+00
α_2	4.38E-03	1.55E-02	1.39E-02	3.21E-02	1.10E-02	3.0927E+00	1.9593E+02
α_3	1.31E-03	8.77E-03	7.19E-03	2.17E-02	7.77E-03	1.7462E+00	1.9727E+02
α_4	7.50E-04	7.08E-03	5.51E-03	1.88E-02	1.05E-02	1.4087E+00	1.9761E+02
α_5	4.01E-05	3.22E-03	1.78E-03	1.13E-02	5.38E-03	6.4090E-01	1.9838E+02
α_6	4.55E-13	6.64E-04	1.66E-05	3.74E-03	6.30E-04	1.3224E-01	1.9889E+02

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO OPEN SPAR: ADV-CC

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9469870	0.9663440	0.9674440	0.9819420	0.9667170	2.7131E+02	9.4494E+00
α_2	5.09E-03	1.46E-02	1.34E-02	2.79E-02	1.11E-02	4.0923E+00	2.7667E+02
α_3	1.26E-03	7.08E-03	5.95E-03	1.68E-02	3.96E-03	1.9891E+00	2.7877E+02
α_4	8.18E-04	5.92E-03	4.79E-03	1.49E-02	7.44E-03	1.6609E+00	2.7910E+02
α_5	3.44E-04	4.32E-03	3.21E-03	1.21E-02	7.65E-03	1.2124E+00	2.7955E+02
α_6	3.22E-06	1.58E-03	6.46E-04	6.34E-03	2.86E-03	4.4458E-01	2.8031E+02
α_7	2.17E-29	1.78E-04	2.03E-09	9.50E-04	2.33E-04	5.0071E-02	2.8071E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9497200	0.9672830	0.9682280	0.9816250	0.9678740	3.1812E+02	1.0760E+01
α_2	5.23E-03	1.39E-02	1.29E-02	2.59E-02	1.20E-02	4.5772E+00	3.2430E+02
α_3	1.07E-03	6.04E-03	5.07E-03	1.43E-02	2.40E-03	1.9850E+00	3.2689E+02
α_4	5.99E-04	4.76E-03	3.80E-03	1.22E-02	4.07E-03	1.5640E+00	3.2732E+02
α_5	4.56E-04	4.30E-03	3.34E-03	1.14E-02	6.86E-03	1.4127E+00	3.2747E+02
α_6	1.13E-04	2.78E-03	1.86E-03	8.59E-03	5.34E-03	9.1486E-01	3.2797E+02
α_7	2.68E-08	8.09E-04	1.60E-04	3.84E-03	1.39E-03	2.6607E-01	3.2861E+02
α_8	6.63E-36	1.22E-04	5.55E-11	5.87E-04	6.82E-05	4.0124E-02	3.2884E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9690100	0.9511450	0.9568800	0.9615910	0.9647540	0.9667170	0.9678740
α_2	3.10E-02	4.15E-02	2.14E-02	1.32E-02	1.10E-02	1.11E-02	1.20E-02
α_3		7.32E-03	1.84E-02	1.39E-02	7.77E-03	3.96E-03	2.40E-03
α_4			3.34E-03	9.83E-03	1.05E-02	7.44E-03	4.07E-03
α_5				1.50E-03	5.38E-03	7.65E-03	6.86E-03
α_6					6.30E-04	2.86E-03	5.34E-03
α_7						2.33E-04	1.39E-03
α_8							6.82E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.69E-01	9.51E-01	9.57E-01	9.62E-01	9.65E-01	9.67E-01	9.68E-01
Beta	3.10E-02	4.89E-02	4.31E-02	3.84E-02	3.52E-02	3.33E-02	3.21E-02
Gamma		1.50E-01	5.04E-01	6.56E-01	6.89E-01	6.66E-01	6.26E-01
Delta			1.54E-01	4.49E-01	6.80E-01	8.21E-01	8.81E-01
Epsilon				1.32E-01	3.64E-01	5.91E-01	7.71E-01
Mu					1.05E-01	2.88E-01	4.98E-01
Upsilon						7.52E-02	2.15E-01
Sigma							4.66E-02

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO OPEN SPAR: ADV-CC

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	23.60	35.40	47.20	59.00	70.79	82.59	94.39
N ₁	2.9529	2.7629	3.2652	3.7892	4.2661	4.6712	5.0018
N ₂	0.8492	1.6665	1.1280	0.8628	0.8535	1.0045	1.2325
N ₃		0.2937	0.9699	0.9057	0.6044	0.3579	0.2466
N ₄			0.1762	0.6416	0.8165	0.6720	0.4175
N ₅				0.0979	0.4187	0.6906	0.7044
N ₆					0.0490	0.2583	0.5479
N ₇						0.0210	0.1431
N ₈							0.0070

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO CLOSE SPAR: ADV-OO

1.9.2.2 PWR MAIN STEAM PORV FAIL TO CLOSE SPAR: ADV-OO

System :	Main steam
Component :	Power Operated Relief Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 25.00

Total Number of Common-Cause Failure Events: 1

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9250270	0.9812610	0.9923200	0.9999620	0.9998650	2.2843E+01	4.3622E-01
α_2	3.50E-05	1.87E-02	7.68E-03	7.50E-02	1.35E-04	4.3622E-01	2.2843E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9361880	0.9776820	0.9837230	0.9985190	0.9997350	4.8445E+01	1.1059E+00
α_2	5.46E-04	1.69E-02	1.10E-02	5.35E-02	2.65E-04	8.3866E-01	4.8712E+01
α_3	1.89E-07	5.39E-03	1.09E-03	2.56E-02	0.00E+00	2.6722E-01	4.9284E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9388960	0.9745140	0.9787070	0.9957890	0.9996030	7.1316E+01	1.8651E+00
α_2	1.42E-03	1.69E-02	1.28E-02	4.66E-02	3.97E-04	1.2381E+00	7.1943E+01
α_3	6.21E-06	5.52E-03	2.05E-03	2.28E-02	0.00E+00	4.0431E-01	7.2777E+01
α_4	1.31E-08	3.04E-03	4.16E-04	1.52E-02	0.00E+00	2.2267E-01	7.2958E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9463140	0.9729060	0.9752780	0.9913960	0.9994920	1.2763E+02	3.5542E+00
α_2	3.15E-03	1.62E-02	1.38E-02	3.75E-02	4.99E-04	2.1299E+00	1.2905E+02
α_3	3.64E-04	7.45E-03	5.14E-03	2.24E-02	9.53E-06	9.7768E-01	1.3021E+02
α_4	1.87E-06	2.85E-03	9.60E-04	1.21E-02	0.00E+00	3.7439E-01	1.3081E+02
α_5	4.55E-21	5.51E-04	3.11E-07	3.19E-03	0.00E+00	7.2277E-02	1.3111E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9490140	0.9729430	0.9749060	0.9901720	0.9993860	1.5469E+02	4.3019E+00
α_2	2.95E-03	1.42E-02	1.22E-02	3.23E-02	5.93E-04	2.2616E+00	1.5673E+02
α_3	5.06E-04	7.19E-03	5.25E-03	2.05E-02	2.12E-05	1.1426E+00	1.5785E+02
α_4	3.33E-05	3.72E-03	1.95E-03	1.34E-02	0.00E+00	5.9222E-01	1.5840E+02
α_5	5.84E-09	1.40E-03	1.89E-04	7.00E-03	0.00E+00	2.2220E-01	1.5877E+02
α_6	8.86E-19	5.24E-04	9.15E-07	3.05E-03	0.00E+00	8.3237E-02	1.5891E+02

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO CLOSE SPAR: ADV-OO

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9528350	0.9723880	0.9737220	0.9873880	0.9992810	2.2808E+02	6.4767E+00
α_2	3.77E-03	1.33E-02	1.19E-02	2.75E-02	6.83E-04	3.1179E+00	2.3144E+02
α_3	9.39E-04	6.96E-03	5.62E-03	1.76E-02	3.63E-05	1.6328E+00	2.3292E+02
α_4	2.11E-04	4.22E-03	2.92E-03	1.27E-02	0.00E+00	9.8887E-01	2.3357E+02
α_5	1.09E-05	2.22E-03	1.05E-03	8.41E-03	0.00E+00	5.2177E-01	2.3403E+02
α_6	2.86E-10	7.94E-04	6.78E-05	4.17E-03	0.00E+00	1.8628E-01	2.3437E+02
α_7	0.00E+00	1.24E-04	1.08E-13	4.66E-04	0.00E+00	2.9071E-02	2.3453E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9551270	0.9728720	0.9740060	0.9867510	0.9991840	2.6904E+02	7.5021E+00
α_2	3.71E-03	1.22E-02	1.11E-02	2.47E-02	7.65E-04	3.3832E+00	2.7316E+02
α_3	9.33E-04	6.30E-03	5.15E-03	1.56E-02	4.96E-05	1.7409E+00	2.7480E+02
α_4	2.93E-04	4.15E-03	3.03E-03	1.18E-02	1.99E-06	1.1466E+00	2.7540E+02
α_5	4.66E-05	2.56E-03	1.50E-03	8.67E-03	0.00E+00	7.0833E-01	2.7583E+02
α_6	7.51E-07	1.33E-03	4.34E-04	5.68E-03	0.00E+00	3.6696E-01	2.7618E+02
α_7	5.89E-14	4.45E-04	7.99E-06	2.53E-03	0.00E+00	1.2297E-01	2.7642E+02
α_8	1.10E-42	1.20E-04	1.71E-12	5.06E-04	0.00E+00	3.3124E-02	2.7651E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9998650	0.9997350	0.9996030	0.9994920	0.9993860	0.9992810	0.9991840
α_2	1.35E-04	2.65E-04	3.97E-04	4.99E-04	5.93E-04	6.83E-04	7.65E-04
α_3		0.00E+00	0.00E+00	9.53E-06	2.12E-05	3.63E-05	4.96E-05
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.99E-06
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00	1.00E+00	1.00E+00	9.99E-01	9.99E-01	9.99E-01	9.99E-01
Beta	1.35E-04	2.65E-04	3.97E-04	5.08E-04	6.14E-04	7.19E-04	8.16E-04
Gamma		0.00E+00	0.00E+00	1.88E-02	3.45E-02	5.05E-02	6.33E-02
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.85E-02
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO CLOSE SPAR: ADV-OO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	12.50	18.75	25.00	31.25	37.50	43.75	50.00
N ₁	0.0967	0.1400	0.1800	0.2175	0.2523	0.2845	0.3143
N ₂	0.0017	0.0050	0.0100	0.0157	0.0224	0.0301	0.0385
N ₃		0.0000	0.0000	0.0003	0.0008	0.0016	0.0025
N ₄			0.0000	0.0000	0.0000	0.0000	0.0001
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

PWR Pressurizer Power Operated Relief Valves

PRESSURIZER PORVS FAIL TO OPEN SPAR: PPR-SRV-CC

1.9.3 PWR Pressurizer Power Operated Relief Valves

1.9.3.1 PRESSURIZER PORVS FAIL TO OPEN SPAR: PPR-SRV-CC

System :	Reactor coolant
Component :	Power Operated Relief Valve
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 19.10

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9404860	0.9849300	0.9936000	0.9999610	0.9989730	2.9706E+01	4.5452E-01
α_2	3.57E-05	1.51E-02	6.40E-03	5.95E-02	1.03E-03	4.5452E-01	2.9706E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9455050	0.9806700	0.9857140	0.9985830	0.9980820	5.8691E+01	1.1569E+00
α_2	5.63E-04	1.48E-02	9.88E-03	4.60E-02	1.85E-03	8.8766E-01	5.8960E+01
α_3	1.70E-07	4.50E-03	9.17E-04	2.13E-02	6.85E-05	2.6922E-01	5.9579E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9466870	0.9774440	0.9810010	0.9960380	0.9973100	8.4919E+01	1.9597E+00
α_2	1.46E-03	1.53E-02	1.17E-02	4.11E-02	2.50E-03	1.3253E+00	8.5553E+01
α_3	5.97E-06	4.74E-03	1.79E-03	1.95E-02	1.85E-04	4.1151E-01	8.6467E+01
α_4	1.12E-08	2.57E-03	3.51E-04	1.28E-02	5.14E-06	2.2287E-01	8.6656E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	0.9989730	0.9980820	0.9973100
α_2	1.03E-03	1.85E-03	2.50E-03
α_3		6.85E-05	1.85E-04
α_4			5.14E-06

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.99E-01	9.98E-01	9.97E-01
Beta	1.03E-03	1.92E-03	2.69E-03
Gamma		3.57E-02	7.07E-02
Delta			2.70E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	19.10	28.65	38.20
N ₁	0.3600	0.4860	0.5832
N ₂	0.0200	0.0540	0.0972
N ₃		0.0020	0.0072
N ₄			0.0002

PWR Pressurizer Power Operated Relief Valves

PWR PRESSURIZER PORVS FAIL TO CLOSE

1.9.3.2 PWR PRESSURIZER PORVS FAIL TO CLOSE

System :	Reactor coolant
Component :	Power Operated Relief Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 5.10

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8901120	0.9724650	0.9886040	0.9999450	1.0000000	1.5346E+01	4.3452E-01
α_2	5.09E-05	2.75E-02	1.14E-02	1.10E-01	0.00E+00	4.3452E-01	1.5346E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9122210	0.9692110	0.9774640	0.9979560	1.0000000	3.4655E+01	1.1009E+00
α_2	7.44E-04	2.33E-02	1.52E-02	7.36E-02	0.00E+00	8.3366E-01	3.4922E+01
α_3	2.63E-07	7.47E-03	1.51E-03	3.54E-02	0.00E+00	2.6722E-01	3.5489E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9164510	0.9650590	0.9707310	0.9942350	1.0000000	5.1236E+01	1.8551E+00
α_2	1.92E-03	2.31E-02	1.75E-02	6.38E-02	0.00E+00	1.2281E+00	5.1863E+01
α_3	8.59E-06	7.62E-03	2.83E-03	3.14E-02	0.00E+00	4.0431E-01	5.2687E+01
α_4	1.81E-08	4.19E-03	5.75E-04	2.10E-02	0.00E+00	2.2267E-01	5.2868E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
α_1	1.000000	1.000000	1.000000
α_2	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00
α_4			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

PWR Pressurizer Power Operated Relief Valves

PWR PRESSURIZER PORVS FAIL TO CLOSE

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	5.10	5.10	5.10
N ₁	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000
N ₄			0.0000

1.10 Main Steam Isolation Valves

1.10.1 PWR Main Steam Isolation Valves

1.10.1.1 PWR MSIV FAIL TO OPEN

System :	Main steam
Component :	Main Steam Stop Valve
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 19.30

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9244300	0.9777250	0.9869320	0.9996320	0.9875310	3.0046E+01	6.8452E-01
α_2	3.66E-04	2.23E-02	1.31E-02	7.56E-02	1.25E-02	6.8452E-01	3.0046E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9333660	0.9735300	0.9785610	0.9964880	0.9832360	5.8880E+01	1.6009E+00
α_2	1.60E-03	2.00E-02	1.50E-02	5.55E-02	1.26E-02	1.2087E+00	5.9272E+01
α_3	5.95E-06	6.49E-03	2.32E-03	2.71E-02	4.19E-03	3.9222E-01	6.0089E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9367670	0.9709510	0.9744670	0.9931150	0.9826110	8.4986E+01	2.5426E+00
α_2	2.42E-03	1.83E-02	1.48E-02	4.63E-02	9.48E-03	1.6031E+00	8.5925E+01
α_3	1.02E-04	7.48E-03	4.20E-03	2.60E-02	6.32E-03	6.5431E-01	8.6874E+01
α_4	2.18E-07	3.26E-03	7.34E-04	1.51E-02	1.58E-03	2.8517E-01	8.7243E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9451450	0.9707840	0.9728700	0.9893000	0.9834900	1.4457E+02	4.3509E+00
α_2	3.65E-03	1.63E-02	1.42E-02	3.62E-02	6.35E-03	2.4267E+00	1.4649E+02
α_3	7.82E-04	8.66E-03	6.58E-03	2.36E-02	6.35E-03	1.2899E+00	1.4763E+02
α_4	1.91E-05	3.56E-03	1.71E-03	1.34E-02	3.18E-03	5.3069E-01	1.4839E+02
α_5	1.13E-15	6.96E-04	5.10E-06	4.03E-03	6.36E-04	1.0358E-01	1.4882E+02

Main Steam Isolation Valves
 PWR Main Steam Isolation Valves
 PWR MSIV FAIL TO OPEN
CCCG = 6

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9483500	0.9712970	0.9730280	0.9883350	0.9848740	1.7493E+02	5.1694E+00
α_2	3.14E-03	1.37E-02	1.20E-02	3.03E-02	3.98E-03	2.4736E+00	1.7763E+02
α_3	9.05E-04	8.07E-03	6.34E-03	2.12E-02	5.31E-03	1.4543E+00	1.7865E+02
α_4	1.40E-04	4.59E-03	2.93E-03	1.47E-02	3.98E-03	8.2662E-01	1.7927E+02
α_5	3.00E-07	1.75E-03	4.66E-04	7.89E-03	1.59E-03	3.1600E-01	1.7978E+02
α_6	2.32E-16	5.49E-04	3.04E-06	3.19E-03	2.65E-04	9.8837E-02	1.8000E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9527130	0.9715000	0.9727030	0.9861680	0.9863220	2.5165E+02	7.3825E+00
α_2	3.69E-03	1.26E-02	1.13E-02	2.56E-02	2.39E-03	3.2519E+00	2.5578E+02
α_3	1.23E-03	7.35E-03	6.13E-03	1.77E-02	3.99E-03	1.9046E+00	2.5713E+02
α_4	4.21E-04	4.87E-03	3.67E-03	1.34E-02	3.99E-03	1.2623E+00	2.5777E+02
α_5	4.28E-05	2.65E-03	1.53E-03	9.07E-03	2.39E-03	6.8587E-01	2.5835E+02
α_6	1.04E-08	9.30E-04	1.51E-04	4.55E-03	7.98E-04	2.4098E-01	2.5879E+02
α_7	1.16E-38	1.42E-04	1.53E-11	6.50E-04	1.14E-04	3.6871E-02	2.5900E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9553120	0.9723180	0.9733440	0.9858070	0.9876590	2.9596E+02	8.4260E+00
α_2	3.50E-03	1.13E-02	1.03E-02	2.28E-02	1.40E-03	3.4541E+00	3.0093E+02
α_3	1.12E-03	6.43E-03	5.39E-03	1.53E-02	2.80E-03	1.9572E+00	3.0243E+02
α_4	5.00E-04	4.66E-03	3.63E-03	1.24E-02	3.50E-03	1.4199E+00	3.0297E+02
α_5	1.29E-04	3.05E-03	2.05E-03	9.36E-03	2.80E-03	9.2713E-01	3.0346E+02
α_6	4.74E-06	1.56E-03	6.83E-04	6.11E-03	1.40E-03	4.7636E-01	3.0391E+02
α_7	7.67E-12	5.07E-04	2.34E-05	2.78E-03	4.00E-04	1.5427E-01	3.0423E+02
α_8	1.38E-38	1.22E-04	1.41E-11	5.57E-04	4.99E-05	3.7024E-02	3.0435E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9875310	0.9832360	0.9826110	0.9834900	0.9848740	0.9863220	0.9876590
α_2	1.25E-02	1.26E-02	9.48E-03	6.35E-03	3.98E-03	2.39E-03	1.40E-03
α_3		4.19E-03	6.32E-03	6.35E-03	5.31E-03	3.99E-03	2.80E-03
α_4			1.58E-03	3.18E-03	3.98E-03	3.99E-03	3.50E-03
α_5				6.36E-04	1.59E-03	2.39E-03	2.80E-03
α_6					2.65E-04	7.98E-04	1.40E-03
α_7						1.14E-04	4.00E-04
α_8							4.99E-05

Main Steam Isolation Valves
 PWR Main Steam Isolation Valves
 PWR MSIV FAIL TO OPEN

2010

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.88E-01	9.83E-01	9.83E-01	9.83E-01	9.85E-01	9.86E-01	9.88E-01
Beta	1.25E-02	1.68E-02	1.74E-02	1.65E-02	1.51E-02	1.37E-02	1.23E-02
Gamma		2.50E-01	4.55E-01	6.15E-01	7.37E-01	8.25E-01	8.87E-01
Delta			2.00E-01	3.75E-01	5.24E-01	6.46E-01	7.44E-01
Epsilon				1.67E-01	3.18E-01	4.53E-01	5.71E-01
Mu					1.43E-01	2.76E-01	3.98E-01
Upsilon						1.25E-01	2.43E-01
Sigma							1.11E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	19.30	28.95	38.60	48.25	57.90	67.55	77.20
N ₁	0.5000	0.3750	0.2500	0.1563	0.0938	0.0547	0.0313
N ₂	0.2500	0.3750	0.3750	0.3125	0.2344	0.1641	0.1094
N ₃		0.1250	0.2500	0.3125	0.3125	0.2734	0.2188
N ₄			0.0625	0.1563	0.2344	0.2734	0.2734
N ₅				0.0313	0.0938	0.1641	0.2188
N ₆					0.0156	0.0547	0.1094
N ₇						0.0078	0.0313
N ₈							0.0039

1.10.1.2 PWR MSIV FAIL TO CLOSE

System :	Main steam
Component :	Main Steam Stop Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 28.30

Total Number of Common-Cause Failure Events: 4

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8762750	0.9567710	0.9684440	0.9972900	0.9548290	2.3633E+01	1.0678E+00
α_2	2.71E-03	4.32E-02	3.16E-02	1.24E-01	4.52E-02	1.0678E+00	2.3633E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8891090	0.9479300	0.9537080	0.9869590	0.9234760	4.8260E+01	2.6509E+00
α_2	8.93E-03	4.34E-02	3.75E-02	9.79E-02	6.79E-02	2.2087E+00	4.8702E+01
α_3	1.73E-05	8.69E-03	3.56E-03	3.47E-02	8.64E-03	4.4222E-01	5.0469E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8892480	0.9400750	0.9440080	0.9774600	0.9010300	6.9693E+01	4.4426E+00
α_2	1.35E-02	4.46E-02	4.05E-02	8.95E-02	7.94E-02	3.3031E+00	7.0832E+01
α_3	3.90E-04	1.15E-02	7.53E-03	3.63E-02	1.72E-02	8.5431E-01	7.3281E+01
α_4	2.57E-07	3.85E-03	8.68E-04	1.79E-02	2.39E-03	2.8517E-01	7.3850E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9160930	0.9504890	0.9527610	0.9771360	0.9067120	1.2512E+02	6.5175E+00
α_2	9.46E-03	2.86E-02	2.62E-02	5.57E-02	5.15E-02	3.7600E+00	1.2788E+02
α_3	3.12E-03	1.61E-02	1.37E-02	3.73E-02	3.59E-02	2.1232E+00	1.2951E+02
α_4	2.16E-05	4.03E-03	1.94E-03	1.51E-02	4.89E-03	5.3069E-01	1.3111E+02
α_5	1.28E-15	7.87E-04	5.77E-06	4.57E-03	9.80E-04	1.0358E-01	1.3153E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9230000	0.9533110	0.9552020	0.9771540	0.9166830	1.5149E+02	7.4193E+00
α_2	5.75E-03	1.99E-02	1.80E-02	4.09E-02	2.46E-02	3.1680E+00	1.5574E+02
α_3	4.87E-03	1.82E-02	1.63E-02	3.84E-02	4.66E-02	2.8987E+00	1.5601E+02
α_4	2.58E-04	5.90E-03	4.00E-03	1.80E-02	9.17E-03	9.3772E-01	1.5797E+02
α_5	3.40E-07	1.99E-03	5.28E-04	8.94E-03	2.49E-03	3.1600E-01	1.5859E+02
α_6	2.63E-16	6.22E-04	3.45E-06	3.62E-03	4.14E-04	9.8837E-02	1.5881E+02

Main Steam Isolation Valves
 PWR Main Steam Isolation Valves
 PWR MSIV FAIL TO CLOSE
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9352350	0.9586090	0.9599140	0.9775420	0.9254650	2.2425E+02	9.6826E+00
α_2	5.45E-03	1.63E-02	1.50E-02	3.19E-02	1.69E-02	3.8232E+00	2.3011E+02
α_3	3.46E-03	1.27E-02	1.14E-02	2.66E-02	3.09E-02	2.9741E+00	2.3096E+02
α_4	1.33E-03	8.06E-03	6.70E-03	1.94E-02	2.06E-02	1.8846E+00	2.3205E+02
α_5	6.05E-05	3.09E-03	1.84E-03	1.04E-02	4.63E-03	7.2287E-01	2.3321E+02
α_6	1.15E-08	1.03E-03	1.67E-04	5.04E-03	1.26E-03	2.4098E-01	2.3369E+02
α_7	1.28E-38	1.58E-04	1.70E-11	7.20E-04	1.80E-04	3.6871E-02	2.3390E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9399540	0.9608570	0.9619710	0.9779650	0.9325320	2.6458E+02	1.0778E+01
α_2	4.89E-03	1.44E-02	1.32E-02	2.78E-02	1.23E-02	3.9516E+00	2.7141E+02
α_3	2.55E-03	1.00E-02	8.87E-03	2.15E-02	2.08E-02	2.7622E+00	2.7260E+02
α_4	1.60E-03	7.98E-03	6.83E-03	1.83E-02	2.14E-02	2.1987E+00	2.7316E+02
α_5	3.27E-04	4.31E-03	3.18E-03	1.21E-02	9.71E-03	1.1858E+00	2.7417E+02
α_6	6.19E-06	1.77E-03	7.93E-04	6.87E-03	2.48E-03	4.8866E-01	2.7487E+02
α_7	8.48E-12	5.60E-04	2.59E-05	3.07E-03	6.37E-04	1.5427E-01	2.7520E+02
α_8	1.52E-38	1.34E-04	1.56E-11	6.16E-04	7.93E-05	3.7024E-02	2.7532E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9548290	0.9234760	0.9010300	0.9067120	0.9166830	0.9254650	0.9325320
α_2	4.52E-02	6.79E-02	7.94E-02	5.15E-02	2.46E-02	1.69E-02	1.23E-02
α_3		8.64E-03	1.72E-02	3.59E-02	4.66E-02	3.09E-02	2.08E-02
α_4			2.39E-03	4.89E-03	9.17E-03	2.06E-02	2.14E-02
α_5				9.80E-04	2.49E-03	4.63E-03	9.71E-03
α_6					4.14E-04	1.26E-03	2.48E-03
α_7						1.80E-04	6.37E-04
α_8							7.93E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.55E-01	9.23E-01	9.01E-01	9.07E-01	9.17E-01	9.25E-01	9.33E-01
Beta	4.52E-02	7.65E-02	9.90E-02	9.33E-02	8.33E-02	7.45E-02	6.75E-02
Gamma		1.13E-01	1.98E-01	4.48E-01	7.04E-01	7.73E-01	8.17E-01
Delta			1.22E-01	1.41E-01	2.06E-01	4.63E-01	6.22E-01
Epsilon				1.67E-01	2.40E-01	2.27E-01	3.76E-01
Mu					1.43E-01	2.37E-01	2.47E-01
Upsilon						1.25E-01	2.24E-01
Sigma							1.11E-01

Main Steam Isolation Valves
 PWR Main Steam Isolation Valves
 PWR MSIV FAIL TO CLOSE

2010

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	11.32	16.98	22.64	28.30	33.96	39.62	45.28
N₁	2.0667	1.7250	0.9167	0.6563	0.5938	0.5797	0.5713
N₂	0.6333	1.3750	2.0750	1.6458	0.9288	0.7354	0.6069
N₃		0.1750	0.4500	1.1458	1.7569	1.3429	1.0238
N₄			0.0625	0.1563	0.3455	0.8957	1.0522
N₅				0.0313	0.0938	0.2011	0.4775
N₆					0.0156	0.0547	0.1217
N₇						0.0078	0.0313
N₈							0.0039

1.10.2 BWR Main Steam Isolation Valves

1.10.2.1 BWR MSIV FAIL TO OPEN

Component :	Main Steam Stop Valve
Failure Mode :	Fail to open on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 3.50

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8513580	0.9625750	0.9842830	0.9999310	1.0000000	1.1176E+01	4.3452E-01
α_2	7.04E-05	3.74E-02	1.57E-02	1.49E-01	0.00E+00	4.3452E-01	1.1176E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9022300	0.9656380	0.9747930	0.9977110	0.9999280	3.0940E+01	1.1010E+00
α_2	8.33E-04	2.60E-02	1.70E-02	8.21E-02	7.22E-05	8.3376E-01	3.1207E+01
α_3	2.94E-07	8.34E-03	1.69E-03	3.96E-02	0.00E+00	2.6722E-01	3.1774E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9110910	0.9627760	0.9687980	0.9938470	0.9998920	4.7986E+01	1.8553E+00
α_2	2.05E-03	2.46E-02	1.86E-02	6.79E-02	1.08E-04	1.2283E+00	4.8613E+01
α_3	9.16E-06	8.11E-03	3.02E-03	3.35E-02	0.00E+00	4.0431E-01	4.9437E+01
α_4	1.93E-08	4.47E-03	6.13E-04	2.24E-02	0.00E+00	2.2267E-01	4.9619E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9313770	0.9653120	0.9683150	0.9889800	0.9998270	9.8475E+01	3.5386E+00
α_2	4.00E-03	2.07E-02	1.77E-02	4.79E-02	1.73E-04	2.1146E+00	9.9899E+01
α_3	4.68E-04	9.58E-03	6.62E-03	2.88E-02	0.00E+00	9.7738E-01	1.0104E+02
α_4	2.41E-06	3.67E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0164E+02
α_5	5.85E-21	7.09E-04	4.01E-07	4.10E-03	0.00E+00	7.2277E-02	1.0194E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9350450	0.9654900	0.9679680	0.9874670	0.9998200	1.1972E+02	4.2792E+00
α_2	3.72E-03	1.81E-02	1.55E-02	4.10E-02	1.80E-04	2.2397E+00	1.2176E+02
α_3	6.49E-04	9.21E-03	6.74E-03	2.62E-02	0.00E+00	1.1418E+00	1.2286E+02
α_4	4.27E-05	4.78E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2341E+02
α_5	7.49E-09	1.79E-03	2.43E-04	8.98E-03	0.00E+00	2.2220E-01	1.2378E+02
α_6	1.14E-18	6.71E-04	1.17E-06	3.92E-03	0.00E+00	8.3237E-02	1.2392E+02

Main Steam Isolation Valves
 BWR Main Steam Isolation Valves
 BWR MSIV FAIL TO OPEN
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9432010	0.9667270	0.9683250	0.9848010	0.9997530	1.8728E+02	6.4458E+00
α_2	4.49E-03	1.59E-02	1.43E-02	3.30E-02	2.47E-04	3.0886E+00	1.9064E+02
α_3	1.14E-03	8.42E-03	6.80E-03	2.12E-02	0.00E+00	1.6312E+00	1.9209E+02
α_4	2.56E-04	5.10E-03	3.53E-03	1.53E-02	0.00E+00	9.8887E-01	1.9274E+02
α_5	1.32E-05	2.69E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9320E+02
α_6	3.47E-10	9.62E-04	8.21E-05	5.05E-03	0.00E+00	1.8628E-01	1.9354E+02
α_7	0.00E+00	1.50E-04	1.31E-13	5.65E-04	0.00E+00	2.9071E-02	1.9370E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9463270	0.9675410	0.9688920	0.9841570	0.9997300	2.2243E+02	7.4620E+00
α_2	4.38E-03	1.46E-02	1.32E-02	2.95E-02	2.70E-04	3.3457E+00	2.2655E+02
α_3	1.12E-03	7.56E-03	6.19E-03	1.87E-02	0.00E+00	1.7384E+00	2.2815E+02
α_4	3.53E-04	4.99E-03	3.65E-03	1.42E-02	0.00E+00	1.1465E+00	2.2875E+02
α_5	5.61E-05	3.08E-03	1.81E-03	1.04E-02	0.00E+00	7.0833E-01	2.2918E+02
α_6	9.03E-07	1.60E-03	5.23E-04	6.83E-03	0.00E+00	3.6696E-01	2.2953E+02
α_7	7.08E-14	5.35E-04	9.62E-06	3.05E-03	0.00E+00	1.2297E-01	2.2977E+02
α_8	1.33E-42	1.44E-04	2.05E-12	6.09E-04	0.00E+00	3.3124E-02	2.2986E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	0.9999280	0.9998920	0.9998270	0.9998200	0.9997530	0.9997300
α_2	0.00E+00	7.22E-05	1.08E-04	1.73E-04	1.80E-04	2.47E-04	2.70E-04
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00	7.22E-05	1.08E-04	1.73E-04	1.80E-04	2.47E-04	2.70E-04
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Main Steam Isolation Valves
 BWR Main Steam Isolation Valves
 BWR MSIV FAIL TO OPEN

2010

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.88	1.31	1.75	2.19	2.63	3.06	3.50
N₁	0.0499	0.0748	0.0996	0.1243	0.1489	0.1735	0.1980
N₂	0.0000	0.0001	0.0002	0.0004	0.0005	0.0008	0.0010
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.10.2.2 BWR MSIV FAIL TO CLOSE

Component : Main Steam Stop Valve
Failure Mode : Fail to close (reset) on demand
Plant Type : BWR
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 9.00

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8651700	0.9648640	0.9838790	0.9998860	0.9849080	1.3157E+01	4.7912E-01
α_2	1.16E-04	3.51E-02	1.61E-02	1.35E-01	1.51E-02	4.7912E-01	1.3157E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9036240	0.9647480	0.9731720	0.9970110	0.9693660	3.3792E+01	1.2348E+00
α_2	1.34E-03	2.76E-02	1.93E-02	8.25E-02	3.06E-02	9.6756E-01	3.4059E+01
α_3	2.69E-07	7.63E-03	1.54E-03	3.62E-02	0.00E+00	2.6722E-01	3.4760E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9095910	0.9604830	0.9660640	0.9922520	0.9532640	5.1600E+01	2.1230E+00
α_2	3.32E-03	2.78E-02	2.22E-02	7.16E-02	4.67E-02	1.4960E+00	5.2227E+01
α_3	8.49E-06	7.53E-03	2.80E-03	3.11E-02	0.00E+00	4.0431E-01	5.3319E+01
α_4	1.79E-08	4.14E-03	5.69E-04	2.08E-02	0.00E+00	2.2267E-01	5.3500E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9285140	0.9626750	0.9655350	0.9870620	0.9367570	1.0277E+02	3.9846E+00
α_2	5.71E-03	2.40E-02	2.11E-02	5.22E-02	6.32E-02	2.5606E+00	1.0419E+02
α_3	4.47E-04	9.16E-03	6.33E-03	2.75E-02	0.00E+00	9.7738E-01	1.0578E+02
α_4	2.31E-06	3.51E-03	1.18E-03	1.49E-02	0.00E+00	3.7439E-01	1.0638E+02
α_5	5.59E-21	6.77E-04	3.83E-07	3.92E-03	0.00E+00	7.2277E-02	1.0668E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9307480	0.9618040	0.9641580	0.9848090	0.9196190	1.2460E+02	4.9483E+00
α_2	6.03E-03	2.25E-02	2.00E-02	4.71E-02	8.04E-02	2.9088E+00	1.2664E+02
α_3	6.21E-04	8.81E-03	6.45E-03	2.51E-02	0.00E+00	1.1418E+00	1.2841E+02
α_4	4.09E-05	4.57E-03	2.39E-03	1.65E-02	0.00E+00	5.9222E-01	1.2896E+02
α_5	7.17E-09	1.72E-03	2.33E-04	8.59E-03	0.00E+00	2.2220E-01	1.2933E+02
α_6	1.09E-18	6.43E-04	1.12E-06	3.75E-03	0.00E+00	8.3237E-02	1.2947E+02

Main Steam Isolation Valves
 BWR Main Steam Isolation Valves
 BWR MSIV FAIL TO CLOSE
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9389120	0.9630990	0.9646360	0.9820470	0.9020120	1.9268E+02	7.3825E+00
α_2	6.97E-03	2.01E-02	1.85E-02	3.87E-02	9.80E-02	4.0253E+00	1.9604E+02
α_3	1.10E-03	8.15E-03	6.58E-03	2.06E-02	0.00E+00	1.6312E+00	1.9843E+02
α_4	2.48E-04	4.94E-03	3.42E-03	1.48E-02	0.00E+00	9.8887E-01	1.9907E+02
α_5	1.28E-05	2.61E-03	1.23E-03	9.86E-03	0.00E+00	5.2177E-01	1.9954E+02
α_6	3.36E-10	9.31E-04	7.95E-05	4.89E-03	0.00E+00	1.8628E-01	1.9988E+02
α_7	0.00E+00	1.45E-04	1.27E-13	5.47E-04	0.00E+00	2.9071E-02	2.0003E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9411920	0.9632360	0.9645350	0.9808530	0.8837210	2.2823E+02	8.7110E+00
α_2	7.32E-03	1.94E-02	1.81E-02	3.60E-02	1.16E-01	4.5947E+00	2.3235E+02
α_3	1.09E-03	7.34E-03	6.00E-03	1.81E-02	0.00E+00	1.7384E+00	2.3520E+02
α_4	3.43E-04	4.84E-03	3.54E-03	1.38E-02	0.00E+00	1.1465E+00	2.3579E+02
α_5	5.44E-05	2.99E-03	1.76E-03	1.01E-02	0.00E+00	7.0833E-01	2.3623E+02
α_6	8.77E-07	1.55E-03	5.07E-04	6.62E-03	0.00E+00	3.6696E-01	2.3657E+02
α_7	6.87E-14	5.19E-04	9.33E-06	2.95E-03	0.00E+00	1.2297E-01	2.3682E+02
α_8	1.29E-42	1.40E-04	1.99E-12	5.91E-04	0.00E+00	3.3124E-02	2.3691E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9849080	0.9693660	0.9532640	0.9367570	0.9196190	0.9020120	0.8837210
α_2	1.51E-02	3.06E-02	4.67E-02	6.32E-02	8.04E-02	9.80E-02	1.16E-01
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.85E-01	9.69E-01	9.53E-01	9.37E-01	9.20E-01	9.02E-01	8.84E-01
Beta	1.51E-02	3.06E-02	4.67E-02	6.32E-02	8.04E-02	9.80E-02	1.16E-01
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Main Steam Isolation Valves
 BWR Main Steam Isolation Valves
 BWR MSIV FAIL TO CLOSE

2010

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.25	3.38	4.50	5.63	6.75	7.88	9.00
N₁	0.6607	0.8571	0.9643	0.9821	0.9107	0.7500	0.5000
N₂	0.0446	0.1339	0.2679	0.4464	0.6696	0.9375	1.2500
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.11 Generators

1.11.1 Emergency Diesel Generators

1.11.1.1 EMERGENCY DIESEL GENERATOR SPAR:DGN-FS

System :	Emergency power supply
Component :	Generator
Failure Mode :	Fail to start
Component Group :	Emergency Diesel Generator
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 197.90

Total Number of Common-Cause Failure Events: 4

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9733480	0.9877110	0.9891910	0.9970130	0.9892000	2.1175E+02	2.6345E+00
α_2	2.99E-03	1.23E-02	1.08E-02	2.67E-02	1.08E-02	2.6345E+00	2.1175E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9783850	0.9890700	0.9900250	0.9964770	0.9915860	3.3127E+02	3.6609E+00
α_2	1.54E-03	7.09E-03	6.13E-03	1.59E-02	5.06E-03	2.3737E+00	3.3256E+02
α_3	3.44E-04	3.84E-03	2.91E-03	1.05E-02	3.35E-03	1.2872E+00	3.3364E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9801470	0.9891730	0.9898880	0.9957630	0.9924730	4.4777E+02	4.9011E+00
α_2	1.48E-03	5.96E-03	5.25E-03	1.29E-02	3.64E-03	2.7001E+00	4.4997E+02
α_3	3.73E-04	3.26E-03	2.57E-03	8.53E-03	2.65E-03	1.4763E+00	4.5119E+02
α_4	3.16E-05	1.60E-03	9.52E-04	5.38E-03	1.24E-03	7.2467E-01	4.5195E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9801170	0.9881460	0.9886820	0.9943520	0.9928130	5.9747E+02	7.1675E+00
α_2	2.10E-03	6.32E-03	5.79E-03	1.24E-02	3.38E-03	3.8222E+00	6.0082E+02
α_3	5.17E-04	3.12E-03	2.60E-03	7.54E-03	1.81E-03	1.8894E+00	6.0275E+02
α_4	1.29E-04	1.87E-03	1.36E-03	5.37E-03	1.50E-03	1.1334E+00	6.0350E+02
α_5	1.08E-07	5.33E-04	1.46E-04	2.38E-03	4.96E-04	3.2248E-01	6.0432E+02

Emergency Diesel Generators

EMERGENCY DIESEL GENERATOR SPAR:DGN-FS

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9809500	0.9882090	0.9886560	0.9939430	0.9929180	7.1773E+02	8.5639E+00
α_2	2.16E-03	5.97E-03	5.52E-03	1.13E-02	3.46E-03	4.3325E+00	7.2196E+02
α_3	4.54E-04	2.66E-03	2.22E-03	6.37E-03	1.31E-03	1.9334E+00	7.2436E+02
α_4	1.88E-04	1.88E-03	1.45E-03	5.05E-03	1.28E-03	1.3665E+00	7.2493E+02
α_5	1.95E-05	9.96E-04	5.91E-04	3.35E-03	8.28E-04	7.2330E-01	7.2557E+02
α_6	5.11E-10	2.87E-04	3.31E-05	1.46E-03	2.07E-04	2.0824E-01	7.2609E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9892000	0.9915860	0.9924730	0.9928130	0.9929180
α_2	1.08E-02	5.06E-03	3.64E-03	3.38E-03	3.46E-03
α_3		3.35E-03	2.65E-03	1.81E-03	1.31E-03
α_4			1.24E-03	1.50E-03	1.28E-03
α_5				4.96E-04	8.28E-04
α_6					2.07E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.89E-01	9.92E-01	9.92E-01	9.93E-01	9.93E-01
Beta	1.08E-02	8.41E-03	7.53E-03	7.19E-03	7.08E-03
Gamma		3.98E-01	5.17E-01	5.29E-01	5.12E-01
Delta			3.19E-01	5.25E-01	6.39E-01
Epsilon				2.48E-01	4.47E-01
Mu					2.00E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	197.90	296.85	395.80	494.75	593.70
N₁	3.6000	4.8600	5.8320	6.5610	7.0859
N₂	2.2000	1.5400	1.4720	1.7080	2.0933
N₃		1.0200	1.0720	0.9120	0.7916
N₄			0.5020	0.7590	0.7743
N₅				0.2502	0.5011
N₆					0.1250

1.11.1.2 EMERGENCY DIESEL GENERATOR SPAR:DGN-LR

System :	Emergency power supply
Component :	Generator
Failure Mode :	Fail to Load/Run
Component Group :	Emergency Diesel Generator
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 209.70

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9791800	0.9940090	0.9966350	0.9999200	0.9977620	1.0877E+02	6.5552E-01
α_2	8.18E-05	5.99E-03	3.37E-03	2.08E-02	2.24E-03	6.5552E-01	1.0877E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9758210	0.9901870	0.9919470	0.9985320	0.9956010	1.7670E+02	1.7511E+00
α_2	9.53E-04	8.28E-03	6.53E-03	2.16E-02	4.36E-03	1.4775E+00	1.7697E+02
α_3	6.78E-08	1.53E-03	3.20E-04	7.22E-03	4.33E-05	2.7362E-01	1.7818E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9735840	0.9871960	0.9885000	0.9963500	0.9935050	2.4150E+02	3.1323E+00
α_2	2.32E-03	1.01E-02	8.85E-03	2.24E-02	6.38E-03	2.4822E+00	2.4215E+02
α_3	2.76E-06	1.74E-03	6.81E-04	7.08E-03	1.13E-04	4.2661E-01	2.4421E+02
α_4	4.09E-09	9.13E-04	1.25E-04	4.57E-03	4.07E-06	2.2347E-01	2.4441E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9737510	0.9856220	0.9865480	0.9943250	0.9941970	3.4018E+02	4.9625E+00
α_2	2.61E-03	9.13E-03	8.20E-03	1.88E-02	4.23E-03	3.1513E+00	3.4199E+02
α_3	3.92E-04	3.94E-03	3.04E-03	1.06E-02	1.56E-03	1.3608E+00	3.4378E+02
α_4	7.68E-07	1.10E-03	3.72E-04	4.64E-03	1.47E-05	3.7799E-01	3.4476E+02
α_5	1.82E-21	2.10E-04	1.20E-07	1.21E-03	4.07E-07	7.2377E-02	3.4507E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9752900	0.9859250	0.9866950	0.9939170	0.9946680	4.0959E+02	5.8475E+00
α_2	2.16E-03	7.58E-03	6.80E-03	1.56E-02	3.09E-03	3.1483E+00	4.1229E+02
α_3	5.67E-04	4.04E-03	3.28E-03	1.01E-02	1.82E-03	1.6786E+00	4.1376E+02
α_4	3.22E-05	1.72E-03	1.01E-03	5.81E-03	4.15E-04	7.1442E-01	4.1472E+02
α_5	2.33E-09	5.37E-04	7.31E-05	2.69E-03	2.38E-06	2.2290E-01	4.1521E+02
α_6	3.38E-19	2.00E-04	3.50E-07	1.17E-03	0.00E+00	8.3237E-02	4.1535E+02

Emergency Diesel Generators

EMERGENCY DIESEL GENERATOR SPAR:DGN-LR

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9977620	0.9956010	0.9935050	0.9941970	0.9946680
α_2	2.24E-03	4.36E-03	6.38E-03	4.23E-03	3.09E-03
α_3		4.33E-05	1.13E-04	1.56E-03	1.82E-03
α_4			4.07E-06	1.47E-05	4.15E-04
α_5				4.07E-07	2.38E-06
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.98E-01	9.96E-01	9.94E-01	9.94E-01	9.95E-01
Beta	2.24E-03	4.40E-03	6.50E-03	5.80E-03	5.33E-03
Gamma		9.84E-03	1.81E-02	2.72E-01	4.21E-01
Delta			3.46E-02	9.56E-03	1.86E-01
Epsilon				2.70E-02	5.70E-03
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	96.86	145.29	193.72	242.15	290.58
N ₁	1.6680	1.8582	1.6415	1.8682	2.0684
N ₂	0.2210	0.6438	1.2541	1.0371	0.9091
N ₃		0.0064	0.0223	0.3834	0.5368
N ₄			0.0008	0.0036	0.1222
N ₅				0.0001	0.0007
N ₆					0.0000

1.11.1.3 EMERGENCY DIESEL GENERATOR SPAR:DGN-FR

System :	Emergency power supply
Component :	Generator
Failure Mode :	Fail to Run (Normally running equipment)
Component Group :	Emergency Diesel Generator
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 140.20

Total Number of Common-Cause Failure Events: 4

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9660900	0.9868990	0.9896050	0.9984490	0.9897360	1.1303E+02	1.5005E+00
α_2	1.55E-03	1.31E-02	1.04E-02	3.39E-02	1.03E-02	1.5005E+00	1.1303E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9721900	0.9877210	0.9894200	0.9974310	0.9923890	1.8357E+02	2.2821E+00
α_2	9.64E-04	8.11E-03	6.42E-03	2.10E-02	4.34E-03	1.5065E+00	1.8435E+02
α_3	1.04E-04	4.17E-03	2.58E-03	1.37E-02	3.28E-03	7.7562E-01	1.8508E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9742860	0.9874770	0.9887270	0.9963790	0.9935500	2.5129E+02	3.1869E+00
α_2	1.07E-03	6.99E-03	5.75E-03	1.72E-02	2.67E-03	1.7794E+00	2.5270E+02
α_3	1.58E-04	3.67E-03	2.48E-03	1.12E-02	2.56E-03	9.3381E-01	2.5354E+02
α_4	5.47E-06	1.86E-03	8.08E-04	7.28E-03	1.22E-03	4.7367E-01	2.5400E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9743300	0.9858850	0.9867800	0.9943750	0.9941540	3.5238E+02	5.0451E+00
α_2	1.84E-03	7.49E-03	6.59E-03	1.62E-02	2.18E-03	2.6766E+00	3.5475E+02
α_3	4.24E-04	3.97E-03	3.09E-03	1.05E-02	1.71E-03	1.4172E+00	3.5601E+02
α_4	4.77E-05	2.11E-03	1.28E-03	6.98E-03	1.47E-03	7.5389E-01	3.5667E+02
α_5	4.68E-10	5.52E-04	5.54E-05	2.86E-03	4.85E-04	1.9738E-01	3.5723E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9757860	0.9861470	0.9868920	0.9939550	0.9945610	4.2420E+02	5.9589E+00
α_2	1.73E-03	6.63E-03	5.88E-03	1.41E-02	1.98E-03	2.8500E+00	4.2731E+02
α_3	4.17E-04	3.51E-03	2.78E-03	9.11E-03	1.19E-03	1.5095E+00	4.2865E+02
α_4	1.12E-04	2.28E-03	1.57E-03	6.87E-03	1.26E-03	9.8062E-01	4.2918E+02
α_5	3.20E-06	1.10E-03	4.76E-04	4.31E-03	8.12E-04	4.7300E-01	4.2969E+02
α_6	1.73E-12	3.39E-04	1.26E-05	1.88E-03	2.02E-04	1.4574E-01	4.3001E+02

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9897360	0.9923890	0.9935500	0.9941540	0.9945610
α_2	1.03E-02	4.34E-03	2.67E-03	2.18E-03	1.98E-03
α_3		3.28E-03	2.56E-03	1.71E-03	1.19E-03
α_4			1.22E-03	1.47E-03	1.26E-03
α_5				4.85E-04	8.12E-04
α_6					2.02E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.90E-01	9.92E-01	9.94E-01	9.94E-01	9.95E-01
Beta	1.03E-02	7.61E-03	6.45E-03	5.85E-03	5.44E-03
Gamma		4.30E-01	5.86E-01	6.27E-01	6.36E-01
Delta			3.22E-01	5.34E-01	6.56E-01
Epsilon				2.48E-01	4.46E-01
Mu					1.99E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	101.96	152.95	203.93	254.91	305.89
N ₁	0.8280	1.0692	1.2247	1.3122	1.3666
N ₂	1.0660	0.6728	0.5513	0.5624	0.6108
N ₃		0.5084	0.5295	0.4398	0.3677
N ₄			0.2510	0.3795	0.3884
N ₅				0.1251	0.2508
N ₆					0.0625

1.12 Vacuum Breakers

1.12.1 BWR Pressure Suppression Vacuum Breakers

1.12.1.1 CONTAINMENT VACUUM RELIEF CHECK FAIL TO OPEN

System : Vapor suppression
Component : Vacuum Breaker
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 7.50

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8612040	0.9606120	0.9783400	0.9996040	0.9636300	1.4663E+01	6.0122E-01
α_2	3.94E-04	3.94E-02	2.17E-02	1.39E-01	3.64E-02	6.0122E-01	1.4663E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8927750	0.9570640	0.9649780	0.9942240	0.9245850	3.5685E+01	1.6009E+00
α_2	3.52E-03	3.58E-02	2.78E-02	9.52E-02	7.54E-02	1.3337E+00	3.5952E+01
α_3	2.52E-07	7.17E-03	1.45E-03	3.40E-02	0.00E+00	2.6722E-01	3.7019E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8945600	0.9494600	0.9546940	0.9864480	0.8823530	5.3636E+01	2.8551E+00
α_2	8.18E-03	3.94E-02	3.41E-02	8.89E-02	1.18E-01	2.2281E+00	5.4263E+01
α_3	8.07E-06	7.16E-03	2.66E-03	2.96E-02	0.00E+00	4.0431E-01	5.6087E+01
α_4	1.70E-08	3.94E-03	5.40E-04	1.97E-02	0.00E+00	2.2267E-01	5.6268E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9237230	0.9587720	0.9615280	0.9844100	0.9036610	1.0554E+02	4.5383E+00
α_2	6.52E-03	2.53E-02	2.24E-02	5.37E-02	6.42E-02	2.7809E+00	1.0730E+02
α_3	1.11E-03	1.19E-02	9.11E-03	3.23E-02	3.21E-02	1.3107E+00	1.0877E+02
α_4	2.24E-06	3.40E-03	1.15E-03	1.44E-02	0.00E+00	3.7439E-01	1.0970E+02
α_5	5.42E-21	6.57E-04	3.71E-07	3.80E-03	0.00E+00	7.2277E-02	1.1001E+02

BWR Pressure Suppression Vacuum Breakers

CONTAINMENT VACUUM RELIEF CHECK FAIL TO OPEN

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9294330	0.9604510	0.9627350	0.9836660	0.9183750	1.2819E+02	5.2786E+00
α_2	5.00E-03	2.01E-02	1.78E-02	4.32E-02	3.63E-02	2.6836E+00	1.3078E+02
α_3	1.54E-03	1.19E-02	9.55E-03	3.02E-02	3.63E-02	1.5862E+00	1.3188E+02
α_4	9.38E-05	5.27E-03	3.09E-03	1.79E-02	9.07E-03	7.0332E-01	1.3277E+02
α_5	6.96E-09	1.66E-03	2.26E-04	8.34E-03	0.00E+00	2.2220E-01	1.3325E+02
α_6	1.06E-18	6.24E-04	1.09E-06	3.64E-03	0.00E+00	8.3237E-02	1.3339E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9636300	0.9245850	0.8823530	0.9036610	0.9183750
α_2	3.64E-02	7.54E-02	1.18E-01	6.42E-02	3.63E-02
α_3		0.00E+00	0.00E+00	3.21E-02	3.63E-02
α_4			0.00E+00	0.00E+00	9.07E-03
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.64E-01	9.25E-01	8.82E-01	9.04E-01	9.18E-01
Beta	3.64E-02	7.54E-02	1.18E-01	9.63E-02	8.16E-02
Gamma		0.00E+00	0.00E+00	3.33E-01	5.56E-01
Delta			0.00E+00	0.00E+00	2.00E-01
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	3.75	5.63	7.50	9.38	11.25
N₁	0.6667	0.5000	0.0000	0.0000	0.0000
N₂	0.1667	0.5000	1.0000	0.6667	0.4444
N₃		0.0000	0.0000	0.3333	0.4444
N₄			0.0000	0.0000	0.1111
N₅				0.0000	0.0000
N₆					0.0000

1.13 AC Power Distribution Breakers

1.13.1 480 Vac Circuit Breakers

1.13.1.1 480 V CIRCUIT BREAKERS FAIL TO OPEN

System :	Plant ac power
Component :	Circuit Breaker
Failure Mode :	Fail to open on demand
Component Group :	480 Volt
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 12.20

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8574060	0.9632090	0.9835270	0.9998990	0.9844030	1.2177E+01	4.6512E-01
α_2	1.03E-04	3.68E-02	1.65E-02	1.43E-01	1.56E-02	4.6512E-01	1.2177E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9021370	0.9647150	0.9734900	0.9972530	0.9713440	3.2368E+01	1.1839E+00
α_2	1.13E-03	2.72E-02	1.85E-02	8.30E-02	2.71E-02	9.1226E-01	3.2640E+01
α_3	3.37E-07	8.10E-03	1.69E-03	3.82E-02	1.52E-03	2.7162E-01	3.3280E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9098200	0.9612840	0.9670770	0.9929170	0.9605090	4.9794E+01	2.0055E+00
α_2	2.67E-03	2.63E-02	2.05E-02	6.99E-02	3.54E-02	1.3628E+00	5.0437E+01
α_3	1.16E-05	8.10E-03	3.14E-03	3.30E-02	3.96E-03	4.1941E-01	5.1380E+01
α_4	1.93E-08	4.31E-03	5.95E-04	2.16E-02	1.58E-04	2.2327E-01	5.1576E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9298630	0.9639350	0.9668600	0.9879950	0.9516930	1.0064E+02	3.7654E+00
α_2	4.71E-03	2.21E-02	1.91E-02	4.97E-02	4.08E-02	2.3062E+00	1.0210E+02
α_3	5.13E-04	9.67E-03	6.77E-03	2.87E-02	6.89E-03	1.0098E+00	1.0340E+02
α_4	2.50E-06	3.61E-03	1.23E-03	1.53E-02	5.53E-04	3.7699E-01	1.0403E+02
α_5	6.05E-21	6.93E-04	3.97E-07	4.01E-03	2.13E-05	7.2377E-02	1.0433E+02

AC Power Distribution Breakers
 480 Vac Circuit Breakers
 480 V CIRCUIT BREAKERS FAIL TO OPEN
CCCG = 6

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9331270	0.9638210	0.9662340	0.9862570	0.9446800	1.2222E+02	4.5878E+00
α_2	4.52E-03	1.96E-02	1.71E-02	4.31E-02	4.41E-02	2.4854E+00	1.2432E+02
α_3	7.36E-04	9.44E-03	7.02E-03	2.64E-02	9.97E-03	1.1975E+00	1.2561E+02
α_4	4.44E-05	4.72E-03	2.50E-03	1.70E-02	1.22E-03	5.9902E-01	1.2621E+02
α_5	7.51E-09	1.76E-03	2.39E-04	8.79E-03	7.16E-05	2.2260E-01	1.2659E+02
α_6	1.11E-18	6.56E-04	1.15E-06	3.83E-03	0.00E+00	8.3237E-02	1.2672E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9415240	0.9652780	0.9668410	0.9836880	0.9390090	1.9011E+02	6.8384E+00
α_2	5.22E-03	1.72E-02	1.56E-02	3.46E-02	4.56E-02	3.3822E+00	1.9357E+02
α_3	1.26E-03	8.71E-03	7.11E-03	2.16E-02	1.30E-02	1.7150E+00	1.9523E+02
α_4	2.64E-04	5.09E-03	3.54E-03	1.52E-02	2.14E-03	1.0027E+00	1.9595E+02
α_5	1.32E-05	2.66E-03	1.26E-03	1.00E-02	2.02E-04	5.2307E-01	1.9643E+02
α_6	3.44E-10	9.46E-04	8.09E-05	4.97E-03	1.55E-05	1.8638E-01	1.9676E+02
α_7	0.00E+00	1.48E-04	1.29E-13	5.56E-04	0.00E+00	2.9071E-02	1.9692E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9445330	0.9660020	0.9673240	0.9829570	0.9346470	2.2555E+02	7.9381E+00
α_2	5.11E-03	1.58E-02	1.44E-02	3.11E-02	4.59E-02	3.6798E+00	2.2981E+02
α_3	1.28E-03	7.94E-03	6.58E-03	1.92E-02	1.58E-02	1.8534E+00	2.3163E+02
α_4	3.71E-04	5.01E-03	3.69E-03	1.42E-02	3.26E-03	1.1703E+00	2.3232E+02
α_5	5.63E-05	3.05E-03	1.80E-03	1.03E-02	4.11E-04	7.1133E-01	2.3278E+02
α_6	8.94E-07	1.57E-03	5.15E-04	6.73E-03	2.74E-05	3.6716E-01	2.3312E+02
α_7	6.97E-14	5.27E-04	9.47E-06	3.00E-03	0.00E+00	1.2297E-01	2.3337E+02
α_8	1.31E-42	1.42E-04	2.02E-12	6.00E-04	0.00E+00	3.3124E-02	2.3345E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9844030	0.9713440	0.9605090	0.9516930	0.9446800	0.9390090	0.9346470
α_2	1.56E-02	2.71E-02	3.54E-02	4.08E-02	4.41E-02	4.56E-02	4.59E-02
α_3		1.52E-03	3.96E-03	6.89E-03	9.97E-03	1.30E-02	1.58E-02
α_4			1.58E-04	5.53E-04	1.22E-03	2.14E-03	3.26E-03
α_5				2.13E-05	7.16E-05	2.02E-04	4.11E-04
α_6					0.00E+00	1.55E-05	2.74E-05
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

AC Power Distribution Breakers
 480 Vac Circuit Breakers
 480 V CIRCUIT BREAKERS FAIL TO OPEN

2010

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.84E-01	9.71E-01	9.61E-01	9.52E-01	9.45E-01	9.39E-01	9.35E-01
Beta	1.56E-02	2.87E-02	3.95E-02	4.83E-02	5.53E-02	6.10E-02	6.54E-02
Gamma		5.30E-02	1.04E-01	1.55E-01	2.03E-01	2.52E-01	2.98E-01
Delta			3.82E-02	7.69E-02	1.14E-01	1.54E-01	1.90E-01
Epsilon				3.70E-02	5.56E-02	9.21E-02	1.19E-01
Mu					0.00E+00	7.14E-02	6.25E-02
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	1.53	2.29	3.05	3.81	4.58	5.34	6.10
N ₁	0.4013	0.5234	0.6081	0.6641	0.6984	0.7167	0.7233
N ₂	0.0306	0.0786	0.1347	0.1920	0.2462	0.2944	0.3351
N ₃		0.0044	0.0151	0.0324	0.0557	0.0838	0.1150
N ₄			0.0006	0.0026	0.0068	0.0138	0.0238
N ₅				0.0001	0.0004	0.0013	0.0030
N ₆					0.0000	0.0001	0.0002
N ₇						0.0000	0.0000
N ₈							0.0000

AC Power Distribution Breakers
 480 Vac Circuit Breakers
 480 V CIRCUIT BREAKERS FAIL TO CLOSE

2010

1.13.1.2 480 V CIRCUIT BREAKERS FAIL TO CLOSE

System : Plant ac power
Component : Circuit Breaker
Failure Mode : Fail to close (reset) on demand
Component Group : 480 Volt
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 48.20

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8946290	0.9730650	0.9882370	0.9999270	0.9960820	1.6601E+01	4.5952E-01
α_2	6.94E-05	2.69E-02	1.18E-02	1.05E-01	3.92E-03	4.5952E-01	1.6601E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9185560	0.9708280	0.9782260	0.9977840	0.9925070	3.9013E+01	1.1723E+00
α_2	9.03E-04	2.25E-02	1.52E-02	6.90E-02	7.30E-03	9.0326E-01	3.9282E+01
α_3	2.52E-07	6.69E-03	1.37E-03	3.17E-02	1.89E-04	2.6902E-01	3.9916E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9231590	0.9671750	0.9721710	0.9940750	0.9892790	5.8657E+01	1.9908E+00
α_2	2.24E-03	2.24E-02	1.74E-02	5.96E-02	1.02E-02	1.3567E+00	5.9291E+01
α_3	8.57E-06	6.78E-03	2.57E-03	2.78E-02	5.61E-04	4.1141E-01	6.0236E+01
α_4	1.59E-08	3.67E-03	5.03E-04	1.84E-02	0.00E+00	2.2267E-01	6.0425E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9366560	0.9675000	0.9701630	0.9892270	0.9864070	1.1171E+02	3.7525E+00
α_2	4.27E-03	2.00E-02	1.73E-02	4.50E-02	1.25E-02	2.3106E+00	1.1315E+02
α_3	4.41E-04	8.62E-03	6.00E-03	2.58E-02	1.14E-03	9.9528E-01	1.1447E+02
α_4	2.13E-06	3.24E-03	1.09E-03	1.38E-02	0.00E+00	3.7439E-01	1.1509E+02
α_5	5.17E-21	6.26E-04	3.54E-07	3.62E-03	0.00E+00	7.2277E-02	1.1539E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9394480	0.9672890	0.9694890	0.9876020	0.9839070	1.3550E+02	4.5823E+00
α_2	4.16E-03	1.79E-02	1.57E-02	3.93E-02	1.42E-02	2.5071E+00	1.3758E+02
α_3	6.32E-04	8.41E-03	6.21E-03	2.37E-02	1.89E-03	1.1775E+00	1.3890E+02
α_4	3.78E-05	4.23E-03	2.21E-03	1.53E-02	0.00E+00	5.9222E-01	1.3949E+02
α_5	6.63E-09	1.59E-03	2.15E-04	7.95E-03	0.00E+00	2.2220E-01	1.3986E+02
α_6	1.01E-18	5.94E-04	1.04E-06	3.47E-03	0.00E+00	8.3237E-02	1.4000E+02

AC Power Distribution Breakers
 480 Vac Circuit Breakers
 480 V CIRCUIT BREAKERS FAIL TO CLOSE
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9457110	0.9677780	0.9692400	0.9848640	0.9817680	2.0559E+02	6.8450E+00
α_2	4.95E-03	1.61E-02	1.46E-02	3.24E-02	1.54E-02	3.4253E+00	2.0901E+02
α_3	1.14E-03	7.97E-03	6.49E-03	1.99E-02	2.85E-03	1.6937E+00	2.1074E+02
α_4	2.33E-04	4.65E-03	3.22E-03	1.40E-02	0.00E+00	9.8887E-01	2.1145E+02
α_5	1.21E-05	2.46E-03	1.16E-03	9.28E-03	0.00E+00	5.2177E-01	2.1191E+02
α_6	3.16E-10	8.77E-04	7.49E-05	4.60E-03	0.00E+00	1.8628E-01	2.1225E+02
α_7	0.00E+00	1.37E-04	1.20E-13	5.15E-04	0.00E+00	2.9071E-02	2.1241E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9482890	0.9683070	0.9695460	0.9841050	0.9800000	2.4323E+02	7.9610E+00
α_2	4.89E-03	1.49E-02	1.36E-02	2.93E-02	1.60E-02	3.7447E+00	2.4745E+02
α_3	1.17E-03	7.32E-03	6.06E-03	1.78E-02	4.00E-03	1.8384E+00	2.4935E+02
α_4	3.23E-04	4.56E-03	3.34E-03	1.30E-02	0.00E+00	1.1465E+00	2.5004E+02
α_5	5.13E-05	2.82E-03	1.66E-03	9.54E-03	0.00E+00	7.0833E-01	2.5048E+02
α_6	8.27E-07	1.46E-03	4.78E-04	6.25E-03	0.00E+00	3.6696E-01	2.5082E+02
α_7	6.48E-14	4.90E-04	8.80E-06	2.79E-03	0.00E+00	1.2297E-01	2.5107E+02
α_8	1.21E-42	1.32E-04	1.88E-12	5.57E-04	0.00E+00	3.3124E-02	2.5116E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9960820	0.9925070	0.9892790	0.9864070	0.9839070	0.9817680	0.9800000
α_2	3.92E-03	7.30E-03	1.02E-02	1.25E-02	1.42E-02	1.54E-02	1.60E-02
α_3		1.89E-04	5.61E-04	1.14E-03	1.89E-03	2.85E-03	4.00E-03
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.96E-01	9.93E-01	9.89E-01	9.86E-01	9.84E-01	9.82E-01	9.80E-01
Beta	3.92E-03	7.49E-03	1.07E-02	1.36E-02	1.61E-02	1.82E-02	2.00E-02
Gamma		2.52E-02	5.23E-02	8.35E-02	1.18E-01	1.56E-01	2.00E-01
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

480 V CIRCUIT BREAKERS FAIL TO CLOSE

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	6.03	9.04	12.05	15.06	18.08	21.09	24.10
N₁	0.3250	0.4179	0.4714	0.4911	0.4821	0.4500	0.4000
N₂	0.0250	0.0696	0.1286	0.1964	0.2679	0.3375	0.4000
N₃		0.0018	0.0071	0.0179	0.0357	0.0625	0.1000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

AC Power Distribution Breakers
 480 Vac Circuit Breakers
 480 V CIRCUIT BREAKERS SPURIOUS ACTUATION

2010

1.13.1.3 480 V CIRCUIT BREAKERS SPURIOUS ACTUATION

System :	Plant ac power
Component :	Circuit Breaker
Failure Mode :	Spurious operation open or close
Component Group :	480 Volt
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 42.20

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9669310	0.9917830	0.9966990	0.9999840	1.0000000	5.2446E+01	4.3452E-01
α_2	1.47E-05	8.22E-03	3.30E-03	3.31E-02	0.00E+00	4.3452E-01	5.2446E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9565670	0.9848900	0.9890400	0.9990100	1.0000000	7.1755E+01	1.1009E+00
α_2	3.60E-04	1.14E-02	7.39E-03	3.64E-02	0.00E+00	8.3366E-01	7.2022E+01
α_3	1.28E-07	3.67E-03	7.36E-04	1.74E-02	0.00E+00	2.6722E-01	7.2589E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9504890	0.9794320	0.9828630	0.9966420	1.0000000	8.8336E+01	1.8551E+00
α_2	1.12E-03	1.36E-02	1.02E-02	3.77E-02	0.00E+00	1.2281E+00	8.8963E+01
α_3	5.03E-06	4.48E-03	1.66E-03	1.85E-02	0.00E+00	4.0431E-01	8.9787E+01
α_4	1.06E-08	2.47E-03	3.37E-04	1.24E-02	0.00E+00	2.2267E-01	8.9968E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9504910	0.9750650	0.9772670	0.9921220	1.0000000	1.3836E+02	3.5382E+00
α_2	2.86E-03	1.49E-02	1.27E-02	3.45E-02	0.00E+00	2.1142E+00	1.3978E+02
α_3	3.36E-04	6.89E-03	4.75E-03	2.07E-02	0.00E+00	9.7738E-01	1.4092E+02
α_4	1.73E-06	2.64E-03	8.88E-04	1.12E-02	0.00E+00	3.7439E-01	1.4152E+02
α_5	4.20E-21	5.09E-04	2.88E-07	2.95E-03	0.00E+00	7.2277E-02	1.4183E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9505740	0.9738180	0.9757310	0.9905280	1.0000000	1.5914E+02	4.2787E+00
α_2	2.81E-03	1.37E-02	1.18E-02	3.12E-02	0.00E+00	2.2392E+00	1.6118E+02
α_3	4.91E-04	6.99E-03	5.11E-03	1.99E-02	0.00E+00	1.1418E+00	1.6228E+02
α_4	3.24E-05	3.62E-03	1.90E-03	1.31E-02	0.00E+00	5.9222E-01	1.6283E+02
α_5	5.68E-09	1.36E-03	1.84E-04	6.81E-03	0.00E+00	2.2220E-01	1.6320E+02
α_6	8.62E-19	5.09E-04	8.90E-07	2.97E-03	0.00E+00	8.3237E-02	1.6334E+02

AC Power Distribution Breakers
 480 Vac Circuit Breakers
 480 V CIRCUIT BREAKERS SPURIOUS ACTUATION
CCCG = 7

2010

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9526440	0.9723030	0.9736480	0.9873780	1.0000000	2.2625E+02	6.4450E+00
α_2	3.73E-03	1.33E-02	1.19E-02	2.75E-02	0.00E+00	3.0878E+00	2.2961E+02
α_3	9.44E-04	7.01E-03	5.66E-03	1.77E-02	0.00E+00	1.6312E+00	2.3106E+02
α_4	2.13E-04	4.25E-03	2.94E-03	1.28E-02	0.00E+00	9.8887E-01	2.3171E+02
α_5	1.10E-05	2.24E-03	1.06E-03	8.48E-03	0.00E+00	5.2177E-01	2.3217E+02
α_6	2.89E-10	8.01E-04	6.83E-05	4.20E-03	0.00E+00	1.8628E-01	2.3251E+02
α_7	0.00E+00	1.25E-04	1.09E-13	4.70E-04	0.00E+00	2.9071E-02	2.3267E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9539690	0.9722010	0.9733640	0.9864490	1.0000000	2.6093E+02	7.4610E+00
α_2	3.75E-03	1.25E-02	1.13E-02	2.52E-02	0.00E+00	3.3447E+00	2.6505E+02
α_3	9.58E-04	6.48E-03	5.30E-03	1.60E-02	0.00E+00	1.7384E+00	2.6665E+02
α_4	3.02E-04	4.27E-03	3.12E-03	1.22E-02	0.00E+00	1.1465E+00	2.6724E+02
α_5	4.80E-05	2.64E-03	1.55E-03	8.93E-03	0.00E+00	7.0833E-01	2.6768E+02
α_6	7.74E-07	1.37E-03	4.47E-04	5.85E-03	0.00E+00	3.6696E-01	2.6802E+02
α_7	6.07E-14	4.58E-04	8.24E-06	2.61E-03	0.00E+00	1.2297E-01	2.6827E+02
α_8	1.14E-42	1.23E-04	1.76E-12	5.21E-04	0.00E+00	3.3124E-02	2.6836E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

480 V CIRCUIT BREAKERS SPURIOUS ACTUATION

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	42.20	42.20	42.20	42.20	42.20	42.20	42.20
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.13.2 4160 vac and 6.9Kva Distribution Circuit Breakers

1.13.2.1 ACP 4160 AND 6.9 CIRCUIT BREAKERS FAIL TO OPEN SPAR: CRB-CC

System : Plant ac power
Component : Circuit Breaker
Failure Mode : Fail to open on demand
Component Group : 4160 - 6900 Volt
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 16.10

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8699270	0.9661810	0.9845710	0.9998930	0.9875910	1.3628E+01	4.7702E-01
α_2	1.09E-04	3.38E-02	1.54E-02	1.30E-01	1.24E-02	4.7702E-01	1.3628E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9058520	0.9656470	0.9739180	0.9971220	0.9750400	3.4512E+01	1.2278E+00
α_2	1.28E-03	2.69E-02	1.87E-02	8.05E-02	2.49E-02	9.6026E-01	3.4780E+01
α_3	2.66E-07	7.49E-03	1.52E-03	3.55E-02	5.90E-05	2.6752E-01	3.5472E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9115860	0.9614580	0.9669550	0.9925130	0.9622640	5.2575E+01	2.1076E+00
α_2	3.17E-03	2.71E-02	2.15E-02	6.99E-02	3.75E-02	1.4793E+00	5.3203E+01
α_3	8.55E-06	7.42E-03	2.77E-03	3.06E-02	1.94E-04	4.0561E-01	5.4277E+01
α_4	1.76E-08	4.07E-03	5.58E-04	2.04E-02	0.00E+00	2.2267E-01	5.4460E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9296570	0.9633470	0.9661740	0.9873600	0.9492900	1.0400E+02	3.9569E+00
α_2	5.51E-03	2.34E-02	2.06E-02	5.12E-02	5.03E-02	2.5299E+00	1.0543E+02
α_3	4.47E-04	9.08E-03	6.28E-03	2.73E-02	3.63E-04	9.8038E-01	1.0698E+02
α_4	2.28E-06	3.47E-03	1.17E-03	1.47E-02	0.00E+00	3.7439E-01	1.0758E+02
α_5	5.53E-21	6.69E-04	3.79E-07	3.88E-03	0.00E+00	7.2277E-02	1.0788E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9319670	0.9625690	0.9649000	0.9851910	0.9361010	1.2610E+02	4.9037E+00
α_2	5.76E-03	2.18E-02	1.94E-02	4.60E-02	6.33E-02	2.8582E+00	1.2815E+02
α_3	6.24E-04	8.76E-03	6.42E-03	2.49E-02	6.03E-04	1.1477E+00	1.2986E+02
α_4	4.05E-05	4.52E-03	2.37E-03	1.63E-02	1.02E-05	5.9232E-01	1.3041E+02
α_5	7.09E-09	1.70E-03	2.30E-04	8.50E-03	0.00E+00	2.2220E-01	1.3078E+02
α_6	1.08E-18	6.35E-04	1.11E-06	3.71E-03	0.00E+00	8.3237E-02	1.3092E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9398470	0.9637380	0.9652650	0.9824310	0.9226780	1.9444E+02	7.3160E+00
α_2	6.68E-03	1.96E-02	1.80E-02	3.78E-02	7.64E-02	3.9484E+00	1.9781E+02
α_3	1.11E-03	8.14E-03	6.58E-03	2.05E-02	8.97E-04	1.6413E+00	2.0011E+02
α_4	2.46E-04	4.90E-03	3.39E-03	1.47E-02	2.66E-05	9.8917E-01	2.0077E+02
α_5	1.27E-05	2.59E-03	1.22E-03	9.77E-03	0.00E+00	5.2177E-01	2.0123E+02
α_6	3.33E-10	9.23E-04	7.88E-05	4.85E-03	0.00E+00	1.8628E-01	2.0157E+02
α_7	0.00E+00	1.44E-04	1.26E-13	5.42E-04	0.00E+00	2.9071E-02	2.0173E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9421670	0.9639310	0.9652210	0.9812980	0.9090370	2.3028E+02	8.6169E+00
α_2	6.98E-03	1.88E-02	1.74E-02	3.51E-02	8.97E-02	4.4843E+00	2.3441E+02
α_3	1.10E-03	7.34E-03	6.02E-03	1.81E-02	1.24E-03	1.7541E+00	2.3714E+02
α_4	3.40E-04	4.80E-03	3.51E-03	1.37E-02	4.72E-05	1.1471E+00	2.3775E+02
α_5	5.40E-05	2.97E-03	1.74E-03	1.00E-02	0.00E+00	7.0833E-01	2.3819E+02
α_6	8.69E-07	1.54E-03	5.03E-04	6.57E-03	0.00E+00	3.6696E-01	2.3853E+02
α_7	6.82E-14	5.15E-04	9.26E-06	2.93E-03	0.00E+00	1.2297E-01	2.3877E+02
α_8	1.28E-42	1.39E-04	1.98E-12	5.86E-04	0.00E+00	3.3124E-02	2.3886E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9875910	0.9750400	0.9622640	0.9492900	0.9361010	0.9226780	0.9090370
α_2	1.24E-02	2.49E-02	3.75E-02	5.03E-02	6.33E-02	7.64E-02	8.97E-02
α_3		5.90E-05	1.94E-04	3.63E-04	6.03E-04	8.97E-04	1.24E-03
α_4			0.00E+00	0.00E+00	1.02E-05	2.66E-05	4.72E-05
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.88E-01	9.75E-01	9.62E-01	9.49E-01	9.36E-01	9.23E-01	9.09E-01
Beta	1.24E-02	2.50E-02	3.77E-02	5.07E-02	6.39E-02	7.73E-02	9.10E-02
Gamma		2.36E-03	5.15E-03	7.17E-03	9.60E-03	1.19E-02	1.41E-02
Delta			0.00E+00	0.00E+00	1.67E-02	2.88E-02	3.68E-02
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

AC Power Distribution Breakers

2010

4160 vac and 6.9Kva Distribution Circuit Breakers

ACP 4160 AND 6.9 CIRCUIT BREAKERS FAIL TO OPEN SPAR: CRB-CC

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.68	4.03	5.37	6.71	8.05	9.39	10.73
N₁	0.7025	0.9272	1.0688	1.1281	1.1061	1.0036	0.8214
N₂	0.0425	0.1266	0.2512	0.4157	0.6190	0.8606	1.1396
N₃		0.0003	0.0013	0.0030	0.0059	0.0101	0.0157
N₄			0.0000	0.0000	0.0001	0.0003	0.0006
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.13.2.2 ACP 4160 AND 6.9 CIRCUIT BREAKERS FAIL TO CLOSE SPAR: CRB-OO

System : Plant ac power
Component : Circuit Breaker
Failure Mode : Fail to close (reseat) on demand
Component Group : 4160 - 6900 Volt
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 59.80

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9751720	0.9938350	0.9975270	0.9999880	1.0000000	7.0046E+01	4.3452E-01
α_2	1.10E-05	6.17E-03	2.47E-03	2.48E-02	0.00E+00	4.3452E-01	7.0046E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9649640	0.9878300	0.9911930	0.9992040	1.0000000	8.9355E+01	1.1009E+00
α_2	2.89E-04	9.22E-03	5.94E-03	2.93E-02	0.00E+00	8.3366E-01	8.9622E+01
α_3	1.03E-07	2.95E-03	5.92E-04	1.40E-02	0.00E+00	2.6722E-01	9.0189E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9585110	0.9827910	0.9856790	0.9971970	1.0000000	1.0594E+02	1.8551E+00
α_2	9.36E-04	1.14E-02	8.54E-03	3.16E-02	0.00E+00	1.2281E+00	1.0657E+02
α_3	4.20E-06	3.75E-03	1.39E-03	1.55E-02	0.00E+00	4.0431E-01	1.0739E+02
α_4	8.88E-09	2.07E-03	2.82E-04	1.03E-02	0.00E+00	2.2267E-01	1.0757E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9559140	0.9778160	0.9797820	0.9930000	1.0000000	1.5596E+02	3.5382E+00
α_2	2.54E-03	1.33E-02	1.13E-02	3.07E-02	0.00E+00	2.1142E+00	1.5738E+02
α_3	2.98E-04	6.13E-03	4.23E-03	1.84E-02	0.00E+00	9.7738E-01	1.5852E+02
α_4	1.54E-06	2.35E-03	7.89E-04	9.97E-03	0.00E+00	3.7439E-01	1.5912E+02
α_5	3.74E-21	4.53E-04	2.56E-07	2.62E-03	0.00E+00	7.2277E-02	1.5943E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9553410	0.9763630	0.9781000	0.9914630	1.0000000	1.7674E+02	4.2787E+00
α_2	2.54E-03	1.24E-02	1.06E-02	2.82E-02	0.00E+00	2.2392E+00	1.7878E+02
α_3	4.43E-04	6.31E-03	4.61E-03	1.80E-02	0.00E+00	1.1418E+00	1.7988E+02
α_4	2.92E-05	3.27E-03	1.71E-03	1.18E-02	0.00E+00	5.9222E-01	1.8043E+02
α_5	5.13E-09	1.23E-03	1.66E-04	6.15E-03	0.00E+00	2.2220E-01	1.8080E+02
α_6	7.78E-19	4.60E-04	8.04E-07	2.68E-03	0.00E+00	8.3237E-02	1.8094E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9559450	0.9742500	0.9755060	0.9882740	1.0000000	2.4385E+02	6.4450E+00
α_2	3.47E-03	1.23E-02	1.11E-02	2.56E-02	0.00E+00	3.0878E+00	2.4721E+02
α_3	8.77E-04	6.52E-03	5.26E-03	1.65E-02	0.00E+00	1.6312E+00	2.4866E+02
α_4	1.98E-04	3.95E-03	2.73E-03	1.19E-02	0.00E+00	9.8887E-01	2.4931E+02
α_5	1.02E-05	2.08E-03	9.86E-04	7.88E-03	0.00E+00	5.2177E-01	2.4977E+02
α_6	2.68E-10	7.44E-04	6.35E-05	3.91E-03	0.00E+00	1.8628E-01	2.5011E+02
α_7	0.00E+00	1.16E-04	1.02E-13	4.37E-04	0.00E+00	2.9071E-02	2.5027E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9567850	0.9739120	0.9750110	0.9872950	1.0000000	2.7853E+02	7.4610E+00
α_2	3.51E-03	1.17E-02	1.06E-02	2.37E-02	0.00E+00	3.3447E+00	2.8265E+02
α_3	8.99E-04	6.08E-03	4.97E-03	1.50E-02	0.00E+00	1.7384E+00	2.8425E+02
α_4	2.84E-04	4.01E-03	2.93E-03	1.14E-02	0.00E+00	1.1465E+00	2.8484E+02
α_5	4.51E-05	2.48E-03	1.46E-03	8.38E-03	0.00E+00	7.0833E-01	2.8528E+02
α_6	7.26E-07	1.28E-03	4.20E-04	5.49E-03	0.00E+00	3.6696E-01	2.8562E+02
α_7	5.69E-14	4.30E-04	7.73E-06	2.45E-03	0.00E+00	1.2297E-01	2.8587E+02
α_8	1.07E-42	1.16E-04	1.65E-12	4.89E-04	0.00E+00	3.3124E-02	2.8596E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	59.80	59.80	59.80	59.80	59.80	59.80	59.80
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

**1.13.2.3 ACP 4160 AND 6.9 CIRCUIT BREAKERS SPURIOUS OP SPAR:
CRB-CO**

System : Plant ac power
Component : Circuit Breaker
Failure Mode : Spurious operation open or close
Component Group : 4160 - 6900 Volt
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 34.50

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8873580	0.9699960	0.9855150	0.9998620	0.9878150	1.6569E+01	5.1252E-01
α_2	1.40E-04	3.00E-02	1.45E-02	1.13E-01	1.22E-02	5.1252E-01	1.6569E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9113590	0.9667450	0.9741620	0.9967340	0.9753380	3.8801E+01	1.3347E+00
α_2	1.64E-03	2.66E-02	1.92E-02	7.68E-02	2.46E-02	1.0673E+00	3.9068E+01
α_3	2.36E-07	6.66E-03	1.35E-03	3.16E-02	2.11E-05	2.6742E-01	3.9868E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9144750	0.9616040	0.9665900	0.9916710	0.9625990	5.8150E+01	2.3219E+00
α_2	4.06E-03	2.80E-02	2.30E-02	6.92E-02	3.74E-02	1.6943E+00	5.8778E+01
α_3	7.62E-06	6.70E-03	2.49E-03	2.76E-02	4.81E-05	4.0491E-01	6.0067E+01
α_4	1.59E-08	3.68E-03	5.04E-04	1.84E-02	0.00E+00	2.2267E-01	6.0249E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9296580	0.9625100	0.9651600	0.9862920	0.9495530	1.1079E+02	4.3153E+00
α_2	6.71E-03	2.51E-02	2.24E-02	5.27E-02	5.04E-02	2.8899E+00	1.1222E+02
α_3	4.17E-04	8.50E-03	5.88E-03	2.56E-02	9.09E-05	9.7878E-01	1.1413E+02
α_4	2.14E-06	3.25E-03	1.10E-03	1.38E-02	0.00E+00	3.7439E-01	1.1473E+02
α_5	5.18E-21	6.28E-04	3.55E-07	3.63E-03	0.00E+00	7.2277E-02	1.1503E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9308660	0.9609780	0.9631660	0.9836140	0.9362390	1.3404E+02	5.4430E+00
α_2	7.47E-03	2.44E-02	2.21E-02	4.89E-02	6.36E-02	3.4008E+00	1.3608E+02
α_3	5.80E-04	8.20E-03	6.00E-03	2.33E-02	1.42E-04	1.1444E+00	1.3834E+02
α_4	3.80E-05	4.25E-03	2.22E-03	1.53E-02	5.48E-06	5.9232E-01	1.3889E+02
α_5	6.66E-09	1.59E-03	2.16E-04	7.98E-03	0.00E+00	2.2220E-01	1.3926E+02
α_6	1.01E-18	5.97E-04	1.04E-06	3.48E-03	0.00E+00	8.3237E-02	1.3940E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9404460	0.9637370	0.9651920	0.9820650	0.9417840	2.0392E+02	7.6731E+00
α_2	6.82E-03	1.94E-02	1.79E-02	3.71E-02	4.85E-02	4.1114E+00	2.0748E+02
α_3	1.39E-03	8.67E-03	7.18E-03	2.11E-02	9.68E-03	1.8355E+00	2.0976E+02
α_4	2.34E-04	4.67E-03	3.24E-03	1.40E-02	9.48E-06	9.8907E-01	2.1060E+02
α_5	1.21E-05	2.47E-03	1.17E-03	9.32E-03	0.00E+00	5.2177E-01	2.1107E+02
α_6	3.18E-10	8.80E-04	7.52E-05	4.62E-03	0.00E+00	1.8628E-01	2.1141E+02
α_7	0.00E+00	1.37E-04	1.20E-13	5.17E-04	0.00E+00	2.9071E-02	2.1156E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9440000	0.9649640	0.9661950	0.9817210	0.9455740	2.4135E+02	8.7629E+00
α_2	6.17E-03	1.71E-02	1.58E-02	3.24E-02	3.91E-02	4.2796E+00	2.4583E+02
α_3	1.53E-03	8.26E-03	6.99E-03	1.93E-02	1.37E-02	2.0650E+00	2.4805E+02
α_4	3.62E-04	4.75E-03	3.51E-03	1.34E-02	1.69E-03	1.1869E+00	2.4893E+02
α_5	5.15E-05	2.83E-03	1.66E-03	9.59E-03	0.00E+00	7.0833E-01	2.4940E+02
α_6	8.30E-07	1.47E-03	4.80E-04	6.28E-03	0.00E+00	3.6696E-01	2.4975E+02
α_7	6.51E-14	4.92E-04	8.84E-06	2.80E-03	0.00E+00	1.2297E-01	2.4999E+02
α_8	1.22E-42	1.32E-04	1.89E-12	5.60E-04	0.00E+00	3.3124E-02	2.5008E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.9878150	0.9753380	0.9625990	0.9495530	0.9362390	0.9417840	0.9455740
α_2	1.22E-02	2.46E-02	3.74E-02	5.04E-02	6.36E-02	4.85E-02	3.91E-02
α_3		2.11E-05	4.81E-05	9.09E-05	1.42E-04	9.68E-03	1.37E-02
α_4			0.00E+00	0.00E+00	5.48E-06	9.48E-06	1.69E-03
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.88E-01	9.75E-01	9.63E-01	9.50E-01	9.36E-01	9.42E-01	9.46E-01
Beta	1.22E-02	2.47E-02	3.74E-02	5.04E-02	6.38E-02	5.82E-02	5.44E-02
Gamma		8.55E-04	1.29E-03	1.80E-03	2.32E-03	1.67E-01	2.82E-01
Delta			0.00E+00	0.00E+00	3.70E-02	9.78E-04	1.10E-01
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

AC Power Distribution Breakers

2010

4160 vac and 6.9Kva Distribution Circuit Breakers

ACP 4160 AND 6.9 CIRCUIT BREAKERS SPURIOUS OP SPAR: CRB-CO

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	5.45	8.17	10.89	13.61	16.34	19.06	21.78
N₁	0.8732	1.0762	1.1241	1.0173	0.7561	0.8076	0.8387
N₂	0.0780	0.2336	0.4662	0.7757	1.1616	1.0236	0.9349
N₃		0.0002	0.0006	0.0014	0.0026	0.2043	0.3266
N₄			0.0000	0.0000	0.0001	0.0002	0.0404
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.14DC Power System - Batteries, Chargers, and Breakers

1.14.1 Batteries

1.14.1.1 DC POWER BATTERY NO OUTPUT SPAR:BAT-LP

System :	dc power
Component :	Battery
Failure Mode :	
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 50.60

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9714550	0.9929090	0.9971570	0.9999860	1.0000000	6.0846E+01	4.3452E-01
α_2	1.27E-05	7.09E-03	2.85E-03	2.85E-02	0.00E+00	4.3452E-01	6.0846E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9610260	0.9864520	0.9901830	0.9991130	1.0000000	8.0155E+01	1.1009E+00
α_2	3.23E-04	1.03E-02	6.62E-03	3.26E-02	0.00E+00	8.3366E-01	8.0422E+01
α_3	1.15E-07	3.29E-03	6.59E-04	1.56E-02	0.00E+00	2.6722E-01	8.0989E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9546710	0.9811840	0.9843330	0.9969320	1.0000000	9.6736E+01	1.8551E+00
α_2	1.02E-03	1.25E-02	9.35E-03	3.45E-02	0.00E+00	1.2281E+00	9.7363E+01
α_3	4.60E-06	4.10E-03	1.52E-03	1.70E-02	0.00E+00	4.0431E-01	9.8187E+01
α_4	9.71E-09	2.26E-03	3.08E-04	1.13E-02	0.00E+00	2.2267E-01	9.8368E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9532340	0.9764580	0.9785440	0.9925670	1.0000000	1.4676E+02	3.5382E+00
α_2	2.70E-03	1.41E-02	1.20E-02	3.26E-02	0.00E+00	2.1142E+00	1.4818E+02
α_3	3.17E-04	6.50E-03	4.49E-03	1.96E-02	0.00E+00	9.7738E-01	1.4932E+02
α_4	1.63E-06	2.49E-03	8.38E-04	1.06E-02	0.00E+00	3.7439E-01	1.4992E+02
α_5	3.97E-21	4.81E-04	2.72E-07	2.78E-03	0.00E+00	7.2277E-02	1.5023E+02

Batteries

DC POWER BATTERY NO OUTPUT SPAR:BAT-LP

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9529700	0.9750980	0.9769220	0.9910010	1.0000000	1.6754E+02	4.2787E+00
α_2	2.67E-03	1.30E-02	1.12E-02	2.97E-02	0.00E+00	2.2392E+00	1.6958E+02
α_3	4.67E-04	6.65E-03	4.86E-03	1.89E-02	0.00E+00	1.1418E+00	1.7068E+02
α_4	3.08E-05	3.45E-03	1.80E-03	1.24E-02	0.00E+00	5.9222E-01	1.7123E+02
α_5	5.40E-09	1.29E-03	1.75E-04	6.48E-03	0.00E+00	2.2220E-01	1.7160E+02
α_6	8.20E-19	4.84E-04	8.47E-07	2.83E-03	0.00E+00	8.3237E-02	1.7174E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	50.60	50.60	50.60	50.60	50.60
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.14.2 Battery Chargers

1.14.2.1 DC POWER BATTERY CHARGER LOSS OF FUNCTION SPAR: BCH-FC

System :

dc power

Component :

Battery Charger

Failure Mode :

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
α_2	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
α_2	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
α_3	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
α_2	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
α_3	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
α_4	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
α_2	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
α_3	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
α_4	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
α_5	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
α_2	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
α_3	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
α_4	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
α_5	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
α_6	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000
N ₅				0.0000	0.0000
N ₆					0.0000

1.14.2.2 DC POWER BATTERY CHARGER NO OUTPUT SPAR:BCH-LP

System : dc power
Component : Battery Charger
Failure Mode :
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 253.50

Total Number of Common-Cause Failure Events: 0

*ALPHA FACTOR DISTRIBUTIONS***CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9933610	0.9983550	0.9993480	0.9999940	1.0000000	2.6375E+02	4.3452E-01
α_2	2.91E-06	1.64E-03	6.55E-04	6.64E-03	0.00E+00	4.3452E-01	2.6375E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9887990	0.9961260	0.9972130	0.9997480	1.0000000	2.8305E+02	1.1009E+00
α_2	9.15E-05	2.93E-03	1.88E-03	9.36E-03	0.00E+00	8.3366E-01	2.8332E+02
α_3	3.26E-08	9.40E-04	1.88E-04	4.46E-03	0.00E+00	2.6722E-01	2.8388E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9850910	0.9938470	0.9949020	0.9990030	1.0000000	2.9964E+02	1.8551E+00
α_2	3.33E-04	4.07E-03	3.04E-03	1.13E-02	0.00E+00	1.2281E+00	3.0027E+02
α_3	1.50E-06	1.34E-03	4.93E-04	5.55E-03	0.00E+00	4.0431E-01	3.0109E+02
α_4	3.16E-09	7.39E-04	1.00E-04	3.70E-03	0.00E+00	2.2267E-01	3.0127E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9799990	0.9899820	0.9908880	0.9968540	1.0000000	3.4966E+02	3.5382E+00
α_2	1.14E-03	5.99E-03	5.08E-03	1.39E-02	0.00E+00	2.1142E+00	3.5108E+02
α_3	1.34E-04	2.77E-03	1.90E-03	8.35E-03	0.00E+00	9.7738E-01	3.5222E+02
α_4	6.94E-07	1.06E-03	3.56E-04	4.50E-03	0.00E+00	3.7439E-01	3.5282E+02
α_5	1.68E-21	2.05E-04	1.15E-07	1.18E-03	0.00E+00	7.2277E-02	3.5313E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9783400	0.9885820	0.9894370	0.9958990	1.0000000	3.7044E+02	4.2787E+00
α_2	1.22E-03	5.98E-03	5.12E-03	1.36E-02	0.00E+00	2.2392E+00	3.7248E+02
α_3	2.13E-04	3.05E-03	2.22E-03	8.70E-03	0.00E+00	1.1418E+00	3.7358E+02
α_4	1.41E-05	1.58E-03	8.25E-04	5.71E-03	0.00E+00	5.9222E-01	3.7413E+02
α_5	2.47E-09	5.93E-04	8.02E-05	2.97E-03	0.00E+00	2.2220E-01	3.7450E+02
α_6	3.75E-19	2.22E-04	3.88E-07	1.29E-03	0.00E+00	8.3237E-02	3.7464E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	253.50	253.50	253.50	253.50	253.50
N₁	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000
N₅				0.0000	0.0000
N₆					0.0000

1.14.3 DC Power Distribution Circuit Breakers

1.14.3.1 DC POWER BREAKER FAIL TO OPEN

System : dc power
Component : Circuit Breaker
Failure Mode : Fail to open on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 1.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8581890	0.9643270	0.9850590	0.9999350	1.0000000	1.1746E+01	4.3452E-01
α_2	6.69E-05	3.57E-02	1.49E-02	1.42E-01	0.00E+00	4.3452E-01	1.1746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9025780	0.9657640	0.9748880	0.9977200	1.0000000	3.1055E+01	1.1009E+00
α_2	8.29E-04	2.59E-02	1.69E-02	8.18E-02	0.00E+00	8.3366E-01	3.1322E+01
α_3	2.93E-07	8.31E-03	1.69E-03	3.94E-02	0.00E+00	2.6722E-01	3.1889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9104790	0.9625170	0.9685780	0.9938040	1.0000000	4.7636E+01	1.8551E+00
α_2	2.06E-03	2.48E-02	1.87E-02	6.83E-02	0.00E+00	1.2281E+00	4.8263E+01
α_3	9.23E-06	8.17E-03	3.04E-03	3.37E-02	0.00E+00	4.0431E-01	4.9087E+01
α_4	1.95E-08	4.50E-03	6.18E-04	2.25E-02	0.00E+00	2.2267E-01	4.9268E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9308380	0.9650370	0.9680620	0.9888920	1.0000000	9.7661E+01	3.5382E+00
α_2	4.03E-03	2.09E-02	1.78E-02	4.83E-02	0.00E+00	2.1142E+00	9.9085E+01
α_3	4.72E-04	9.66E-03	6.68E-03	2.90E-02	0.00E+00	9.7738E-01	1.0022E+02
α_4	2.43E-06	3.70E-03	1.25E-03	1.57E-02	0.00E+00	3.7439E-01	1.0082E+02
α_5	5.90E-21	7.14E-04	4.04E-07	4.14E-03	0.00E+00	7.2277E-02	1.0113E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9343810	0.9651340	0.9676320	0.9873370	1.0000000	1.1844E+02	4.2787E+00
α_2	3.75E-03	1.82E-02	1.57E-02	4.15E-02	0.00E+00	2.2392E+00	1.2048E+02
α_3	6.56E-04	9.30E-03	6.81E-03	2.65E-02	0.00E+00	1.1418E+00	1.2158E+02
α_4	4.32E-05	4.83E-03	2.53E-03	1.74E-02	0.00E+00	5.9222E-01	1.2213E+02
α_5	7.57E-09	1.81E-03	2.46E-04	9.07E-03	0.00E+00	2.2220E-01	1.2250E+02
α_6	1.15E-18	6.78E-04	1.19E-06	3.96E-03	0.00E+00	8.3237E-02	1.2264E+02

DC Power Distribution Circuit Breakers

DC POWER BREAKER FAIL TO OPEN

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9426990	0.9664310	0.9680420	0.9846650	1.0000000	1.8555E+02	6.4450E+00
α_2	4.53E-03	1.61E-02	1.44E-02	3.33E-02	0.00E+00	3.0878E+00	1.8891E+02
α_3	1.15E-03	8.50E-03	6.86E-03	2.14E-02	0.00E+00	1.6312E+00	1.9036E+02
α_4	2.58E-04	5.15E-03	3.57E-03	1.55E-02	0.00E+00	9.8887E-01	1.9101E+02
α_5	1.34E-05	2.72E-03	1.29E-03	1.03E-02	0.00E+00	5.2177E-01	1.9147E+02
α_6	3.50E-10	9.70E-04	8.29E-05	5.09E-03	0.00E+00	1.8628E-01	1.9181E+02
α_7	0.00E+00	1.51E-04	1.33E-13	5.70E-04	0.00E+00	2.9071E-02	1.9197E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9458180	0.9672320	0.9685940	0.9840060	1.0000000	2.2023E+02	7.4610E+00
α_2	4.42E-03	1.47E-02	1.33E-02	2.97E-02	0.00E+00	3.3447E+00	2.2435E+02
α_3	1.13E-03	7.63E-03	6.25E-03	1.89E-02	0.00E+00	1.7384E+00	2.2595E+02
α_4	3.57E-04	5.04E-03	3.68E-03	1.43E-02	0.00E+00	1.1465E+00	2.2654E+02
α_5	5.66E-05	3.11E-03	1.83E-03	1.05E-02	0.00E+00	7.0833E-01	2.2698E+02
α_6	9.12E-07	1.61E-03	5.28E-04	6.89E-03	0.00E+00	3.6696E-01	2.2732E+02
α_7	7.15E-14	5.40E-04	9.71E-06	3.07E-03	0.00E+00	1.2297E-01	2.2757E+02
α_8	1.34E-42	1.45E-04	2.07E-12	6.15E-04	0.00E+00	3.3124E-02	2.2766E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	1.50	1.50	1.50	1.50	1.50	1.50	1.50
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.14.3.2 DC POWER BREAKER FAIL TO CLOSE

System : dc power
Component : Circuit Breaker
Failure Mode : Fail to close (reset) on demand
Start Date : 1997/01/01
Data Version : 2010/12/31

Total Number of Independent Failure Events: 9.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9116630	0.9779210	0.9909360	0.9999560	1.0000000	1.9246E+01	4.3452E-01
α_2	4.05E-05	2.21E-02	9.06E-03	8.83E-02	0.00E+00	4.3452E-01	1.9246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9207320	0.9722390	0.9797180	0.9981670	1.0000000	3.8555E+01	1.1009E+00
α_2	6.69E-04	2.10E-02	1.37E-02	6.65E-02	0.00E+00	8.3366E-01	3.8822E+01
α_3	2.37E-07	6.74E-03	1.36E-03	3.20E-02	0.00E+00	2.6722E-01	3.9389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9220800	0.9674500	0.9727570	0.9946390	1.0000000	5.5136E+01	1.8551E+00
α_2	1.79E-03	2.15E-02	1.63E-02	5.94E-02	0.00E+00	1.2281E+00	5.5763E+01
α_3	8.00E-06	7.09E-03	2.63E-03	2.93E-02	0.00E+00	4.0431E-01	5.6587E+01
α_4	1.69E-08	3.91E-03	5.36E-04	1.96E-02	0.00E+00	2.2267E-01	5.6768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9355510	0.9674490	0.9702750	0.9896710	1.0000000	1.0516E+02	3.5382E+00
α_2	3.75E-03	1.95E-02	1.66E-02	4.50E-02	0.00E+00	2.1142E+00	1.0658E+02
α_3	4.39E-04	8.99E-03	6.21E-03	2.70E-02	0.00E+00	9.7738E-01	1.0772E+02
α_4	2.26E-06	3.44E-03	1.16E-03	1.46E-02	0.00E+00	3.7439E-01	1.0832E+02
α_5	5.49E-21	6.65E-04	3.76E-07	3.85E-03	0.00E+00	7.2277E-02	1.0863E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9381170	0.9671430	0.9695070	0.9880770	1.0000000	1.2594E+02	4.2787E+00
α_2	3.53E-03	1.72E-02	1.48E-02	3.91E-02	0.00E+00	2.2392E+00	1.2798E+02
α_3	6.17E-04	8.77E-03	6.41E-03	2.50E-02	0.00E+00	1.1418E+00	1.2908E+02
α_4	4.07E-05	4.55E-03	2.38E-03	1.64E-02	0.00E+00	5.9222E-01	1.2963E+02
α_5	7.13E-09	1.71E-03	2.31E-04	8.55E-03	0.00E+00	2.2220E-01	1.3000E+02
α_6	1.08E-18	6.39E-04	1.12E-06	3.73E-03	0.00E+00	8.3237E-02	1.3014E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9448370	0.9676930	0.9692440	0.9852520	1.0000000	1.9305E+02	6.4450E+00
α_2	4.36E-03	1.55E-02	1.39E-02	3.20E-02	0.00E+00	3.0878E+00	1.9641E+02
α_3	1.10E-03	8.18E-03	6.60E-03	2.06E-02	0.00E+00	1.6312E+00	1.9786E+02
α_4	2.48E-04	4.96E-03	3.43E-03	1.49E-02	0.00E+00	9.8887E-01	1.9851E+02
α_5	1.29E-05	2.62E-03	1.24E-03	9.88E-03	0.00E+00	5.2177E-01	1.9897E+02
α_6	3.37E-10	9.34E-04	7.97E-05	4.90E-03	0.00E+00	1.8628E-01	1.9931E+02
α_7	0.00E+00	1.46E-04	1.28E-13	5.49E-04	0.00E+00	2.9071E-02	1.9947E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9475310	0.9682770	0.9695950	0.9845210	1.0000000	2.2773E+02	7.4610E+00
α_2	4.28E-03	1.42E-02	1.29E-02	2.88E-02	0.00E+00	3.3447E+00	2.3185E+02
α_3	1.09E-03	7.39E-03	6.05E-03	1.83E-02	0.00E+00	1.7384E+00	2.3345E+02
α_4	3.45E-04	4.87E-03	3.56E-03	1.39E-02	0.00E+00	1.1465E+00	2.3404E+02
α_5	5.48E-05	3.01E-03	1.77E-03	1.02E-02	0.00E+00	7.0833E-01	2.3448E+02
α_6	8.83E-07	1.56E-03	5.11E-04	6.67E-03	0.00E+00	3.6696E-01	2.3482E+02
α_7	6.92E-14	5.23E-04	9.40E-06	2.98E-03	0.00E+00	1.2297E-01	2.3507E+02
α_8	1.30E-42	1.41E-04	2.01E-12	5.95E-04	0.00E+00	3.3124E-02	2.3516E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	9.00	9.00	9.00	9.00	9.00	9.00	9.00
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.14.3.3 DC POWER BREAKER SPURIOUS ACTUATION**System :**

dc power

Component :

Circuit Breaker

Failure Mode :

Spurious operation open or close

Start Date :

1997/01/01

Data Version :

2010/12/31

Total Number of Independent Failure Events: 14.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9294220	0.9823940	0.9928250	0.9999650	1.0000000	2.4246E+01	4.3452E-01
α_2	3.20E-05	1.76E-02	7.18E-03	7.06E-02	0.00E+00	4.3452E-01	2.4246E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9294880	0.9753470	0.9820230	0.9983720	1.0000000	4.3555E+01	1.1009E+00
α_2	5.92E-04	1.87E-02	1.21E-02	5.91E-02	0.00E+00	8.3366E-01	4.3822E+01
α_3	2.10E-07	5.98E-03	1.21E-03	2.84E-02	0.00E+00	2.6722E-01	4.4389E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9282810	0.9700750	0.9749830	0.9950760	1.0000000	6.0136E+01	1.8551E+00
α_2	1.64E-03	1.98E-02	1.49E-02	5.47E-02	0.00E+00	1.2281E+00	6.0763E+01
α_3	7.35E-06	6.52E-03	2.42E-03	2.69E-02	0.00E+00	4.0431E-01	6.1587E+01
α_4	1.55E-08	3.59E-03	4.92E-04	1.80E-02	0.00E+00	2.2267E-01	6.1768E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9383530	0.9688800	0.9715890	0.9901320	1.0000000	1.1016E+02	3.5382E+00
α_2	3.58E-03	1.86E-02	1.59E-02	4.30E-02	0.00E+00	2.1142E+00	1.1158E+02
α_3	4.20E-04	8.60E-03	5.94E-03	2.58E-02	0.00E+00	9.7738E-01	1.1272E+02
α_4	2.16E-06	3.29E-03	1.11E-03	1.40E-02	0.00E+00	3.7439E-01	1.1332E+02
α_5	5.25E-21	6.36E-04	3.59E-07	3.68E-03	0.00E+00	7.2277E-02	1.1363E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9403810	0.9683580	0.9706390	0.9885240	1.0000000	1.3094E+02	4.2787E+00
α_2	3.40E-03	1.66E-02	1.42E-02	3.77E-02	0.00E+00	2.2392E+00	1.3298E+02
α_3	5.94E-04	8.44E-03	6.18E-03	2.40E-02	0.00E+00	1.1418E+00	1.3408E+02
α_4	3.92E-05	4.38E-03	2.29E-03	1.58E-02	0.00E+00	5.9222E-01	1.3463E+02
α_5	6.87E-09	1.64E-03	2.23E-04	8.23E-03	0.00E+00	2.2220E-01	1.3500E+02
α_6	1.04E-18	6.16E-04	1.08E-06	3.59E-03	0.00E+00	8.3237E-02	1.3514E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9461730	0.9684830	0.9699980	0.9856130	1.0000000	1.9805E+02	6.4450E+00
α_2	4.25E-03	1.51E-02	1.35E-02	3.12E-02	0.00E+00	3.0878E+00	2.0141E+02
α_3	1.07E-03	7.98E-03	6.44E-03	2.01E-02	0.00E+00	1.6312E+00	2.0286E+02
α_4	2.42E-04	4.84E-03	3.35E-03	1.45E-02	0.00E+00	9.8887E-01	2.0351E+02
α_5	1.25E-05	2.55E-03	1.21E-03	9.64E-03	0.00E+00	5.2177E-01	2.0397E+02
α_6	3.29E-10	9.11E-04	7.78E-05	4.78E-03	0.00E+00	1.8628E-01	2.0431E+02
α_7	0.00E+00	1.42E-04	1.24E-13	5.35E-04	0.00E+00	2.9071E-02	2.0447E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9486090	0.9689370	0.9702290	0.9848460	1.0000000	2.3273E+02	7.4610E+00
α_2	4.19E-03	1.39E-02	1.26E-02	2.82E-02	0.00E+00	3.3447E+00	2.3685E+02
α_3	1.07E-03	7.24E-03	5.92E-03	1.79E-02	0.00E+00	1.7384E+00	2.3845E+02
α_4	3.38E-04	4.77E-03	3.49E-03	1.36E-02	0.00E+00	1.1465E+00	2.3904E+02
α_5	5.37E-05	2.95E-03	1.73E-03	9.98E-03	0.00E+00	7.0833E-01	2.3948E+02
α_6	8.65E-07	1.53E-03	5.00E-04	6.54E-03	0.00E+00	3.6696E-01	2.3982E+02
α_7	6.78E-14	5.12E-04	9.21E-06	2.91E-03	0.00E+00	1.2297E-01	2.4007E+02
α_8	1.27E-42	1.38E-04	1.97E-12	5.83E-04	0.00E+00	3.3124E-02	2.4016E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

DC POWER BREAKER SPURIOUS ACTUATION

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	14.00	14.00	14.00	14.00	14.00	14.00	14.00
N₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N₄			0.0000	0.0000	0.0000	0.0000	0.0000
N₅				0.0000	0.0000	0.0000	0.0000
N₆					0.0000	0.0000	0.0000
N₇						0.0000	0.0000
N₈							0.0000

1.15 Reactor Protection System, Reactor Trip Breakers

1.15.1 Reactor Trip Breakers

1.15.1.1 REACTOR TRIP BREAKERS FAIL TO OPEN

System :	Reactor protection
Component :	Circuit Breaker
Failure Mode :	Fail to open on demand
Component Group :	Reactor Trip Breaker
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 4.50

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8858260	0.9713760	0.9881340	0.9999430	1.0000000	1.4746E+01	4.3452E-01
α_2	5.30E-05	2.86E-02	1.19E-02	1.14E-01	0.00E+00	4.3452E-01	1.4746E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9107480	0.9686860	0.9770720	0.9979200	1.0000000	3.4055E+01	1.1009E+00
α_2	7.57E-04	2.37E-02	1.55E-02	7.49E-02	0.00E+00	8.3366E-01	3.4322E+01
α_3	2.68E-07	7.60E-03	1.54E-03	3.61E-02	0.00E+00	2.6722E-01	3.4889E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9155110	0.9646590	0.9703930	0.9941670	1.0000000	5.0636E+01	1.8551E+00
α_2	1.94E-03	2.34E-02	1.77E-02	6.45E-02	0.00E+00	1.2281E+00	5.1263E+01
α_3	8.69E-06	7.70E-03	2.86E-03	3.18E-02	0.00E+00	4.0431E-01	5.2087E+01
α_4	1.83E-08	4.24E-03	5.82E-04	2.13E-02	0.00E+00	2.2267E-01	5.2268E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9328030	0.9660430	0.9689890	0.9892170	1.0000000	1.0066E+02	3.5382E+00
α_2	3.91E-03	2.03E-02	1.73E-02	4.69E-02	0.00E+00	2.1142E+00	1.0208E+02
α_3	4.58E-04	9.38E-03	6.48E-03	2.82E-02	0.00E+00	9.7738E-01	1.0322E+02
α_4	2.36E-06	3.59E-03	1.21E-03	1.53E-02	0.00E+00	3.7439E-01	1.0382E+02
α_5	5.73E-21	6.94E-04	3.92E-07	4.02E-03	0.00E+00	7.2277E-02	1.0413E+02

Reactor Trip Breakers

REACTOR TRIP BREAKERS FAIL TO OPEN

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9359280	0.9659660	0.9684130	0.9876440	1.0000000	1.2144E+02	4.2787E+00
α_2	3.66E-03	1.78E-02	1.53E-02	4.05E-02	0.00E+00	2.2392E+00	1.2348E+02
α_3	6.40E-04	9.08E-03	6.64E-03	2.59E-02	0.00E+00	1.1418E+00	1.2458E+02
α_4	4.21E-05	4.71E-03	2.47E-03	1.70E-02	0.00E+00	5.9222E-01	1.2513E+02
α_5	7.39E-09	1.77E-03	2.40E-04	8.86E-03	0.00E+00	2.2220E-01	1.2550E+02
α_6	1.12E-18	6.62E-04	1.16E-06	3.86E-03	0.00E+00	8.3237E-02	1.2564E+02

CCCG = 7

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9435720	0.9669480	0.9685360	0.9849040	1.0000000	1.8855E+02	6.4450E+00
α_2	4.46E-03	1.58E-02	1.42E-02	3.28E-02	0.00E+00	3.0878E+00	1.9191E+02
α_3	1.13E-03	8.37E-03	6.75E-03	2.11E-02	0.00E+00	1.6312E+00	1.9336E+02
α_4	2.54E-04	5.07E-03	3.51E-03	1.52E-02	0.00E+00	9.8887E-01	1.9401E+02
α_5	1.32E-05	2.68E-03	1.27E-03	1.01E-02	0.00E+00	5.2177E-01	1.9447E+02
α_6	3.45E-10	9.55E-04	8.16E-05	5.01E-03	0.00E+00	1.8628E-01	1.9481E+02
α_7	0.00E+00	1.49E-04	1.31E-13	5.61E-04	0.00E+00	2.9071E-02	1.9497E+02

CCCG = 8

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9465160	0.9676580	0.9690050	0.9842160	1.0000000	2.2323E+02	7.4610E+00
α_2	4.36E-03	1.45E-02	1.31E-02	2.93E-02	0.00E+00	3.3447E+00	2.2735E+02
α_3	1.12E-03	7.54E-03	6.17E-03	1.86E-02	0.00E+00	1.7384E+00	2.2895E+02
α_4	3.52E-04	4.97E-03	3.63E-03	1.42E-02	0.00E+00	1.1465E+00	2.2954E+02
α_5	5.59E-05	3.07E-03	1.80E-03	1.04E-02	0.00E+00	7.0833E-01	2.2998E+02
α_6	9.00E-07	1.59E-03	5.21E-04	6.80E-03	0.00E+00	3.6696E-01	2.3032E+02
α_7	7.06E-14	5.33E-04	9.59E-06	3.03E-03	0.00E+00	1.2297E-01	2.3057E+02
α_8	1.32E-42	1.44E-04	2.05E-12	6.07E-04	0.00E+00	3.3124E-02	2.3066E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

Reactor Trip Breakers

REACTOR TRIP BREAKERS FAIL TO OPEN

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	4.50	4.50	4.50	4.50	4.50	4.50	4.50
N ₁	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₂	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₃		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N ₄			0.0000	0.0000	0.0000	0.0000	0.0000
N ₅				0.0000	0.0000	0.0000	0.0000
N ₆					0.0000	0.0000	0.0000
N ₇						0.0000	0.0000
N ₈							0.0000

1.16 Air Compressors

1.16.1 Motor-Driven Air Compressors

1.16.1.1 MOTOR DRIVEN AIR COMPRESSOR FAIL TO START

Component :	Compressor
Failure Mode :	Fail to start
Component Group :	Motor Driven
Start Date :	1998/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 217.60

Total Number of Common-Cause Failure Events: 2

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9791990	0.9936620	0.9960890	0.9998490	0.9969830	1.2038E+02	7.6782E-01
α_2	1.53E-04	6.34E-03	3.91E-03	2.08E-02	3.02E-03	7.6782E-01	1.2038E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9750620	0.9892730	0.9908910	0.9979580	0.9939470	1.9376E+02	2.1009E+00
α_2	1.49E-03	9.36E-03	7.75E-03	2.27E-02	6.05E-03	1.8337E+00	1.9403E+02
α_3	4.73E-08	1.36E-03	2.72E-04	6.47E-03	0.00E+00	2.6722E-01	1.9559E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9719390	0.9855940	0.9867890	0.9951750	0.9908930	2.6374E+02	3.8551E+00
α_2	3.52E-03	1.21E-02	1.09E-02	2.47E-02	9.11E-03	3.2281E+00	2.6437E+02
α_3	1.69E-06	1.51E-03	5.56E-04	6.25E-03	0.00E+00	4.0431E-01	2.6719E+02
α_4	3.56E-09	8.32E-04	1.13E-04	4.17E-03	0.00E+00	2.2267E-01	2.6737E+02

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9736570	0.9851800	0.9860350	0.9937800	0.9927010	3.6816E+02	5.5383E+00
α_2	2.84E-03	9.23E-03	8.37E-03	1.86E-02	4.87E-03	3.4475E+00	3.7025E+02
α_3	5.98E-04	4.40E-03	3.55E-03	1.11E-02	2.43E-03	1.6441E+00	3.7205E+02
α_4	6.56E-07	1.00E-03	3.36E-04	4.26E-03	0.00E+00	3.7439E-01	3.7332E+02
α_5	1.59E-21	1.93E-04	1.09E-07	1.12E-03	0.00E+00	7.2277E-02	3.7363E+02

Motor-Driven Air Compressors

MOTOR DRIVEN AIR COMPRESSOR FAIL TO START

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9758880	0.9860360	0.9867480	0.9937490	0.9939100	4.4334E+02	6.2787E+00
α_2	1.97E-03	6.96E-03	6.24E-03	1.44E-02	2.71E-03	3.1281E+00	4.4649E+02
α_3	8.20E-04	4.52E-03	3.81E-03	1.06E-02	2.71E-03	2.0307E+00	4.4759E+02
α_4	5.25E-05	1.81E-03	1.15E-03	5.83E-03	6.77E-04	8.1442E-01	4.4880E+02
α_5	2.06E-09	4.94E-04	6.68E-05	2.48E-03	0.00E+00	2.2220E-01	4.4940E+02
α_6	3.13E-19	1.85E-04	3.23E-07	1.08E-03	0.00E+00	8.3237E-02	4.4954E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9969830	0.9939470	0.9908930	0.9927010	0.9939100
α_2	3.02E-03	6.05E-03	9.11E-03	4.87E-03	2.71E-03
α_3		0.00E+00	0.00E+00	2.43E-03	2.71E-03
α_4			0.00E+00	0.00E+00	6.77E-04
α_5				0.00E+00	0.00E+00
α_6					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.97E-01	9.94E-01	9.91E-01	9.93E-01	9.94E-01
Beta	3.02E-03	6.05E-03	9.11E-03	7.30E-03	6.09E-03
Gamma		0.00E+00	0.00E+00	3.33E-01	5.56E-01
Delta			0.00E+00	0.00E+00	2.00E-01
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	108.80	163.20	217.60	272.00	326.40
N₁	1.3333	1.0000	0.0000	0.0000	0.0000
N₂	0.3333	1.0000	2.0000	1.3333	0.8889
N₃		0.0000	0.0000	0.6667	0.8889
N₄			0.0000	0.0000	0.2222
N₅				0.0000	0.0000
N₆					0.0000

1.16.1.2 MOTOR DRIVEN AIR COMPRESSOR FAIL TO RUN

Component : Compressor
 Failure Mode : Fail to Run (Normally running equipment)
 Component Group : Motor Driven
 Start Date : 1998/01/01
 Data Version : 2010/12/31

Total Number of Independent Failure Events: 580.00

Total Number of Common-Cause Failure Events: 3

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9883980	0.9945890	0.9952160	0.9986240	0.9953410	5.0876E+02	2.7678E+00
α_2	1.37E-03	5.41E-03	4.78E-03	1.16E-02	4.66E-03	2.7678E+00	5.0876E+02

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9899010	0.9947450	0.9951640	0.9981680	0.9959990	7.7634E+02	4.1009E+00
α_2	9.42E-04	3.63E-03	3.22E-03	7.74E-03	2.67E-03	2.8337E+00	7.7761E+02
α_3	1.41E-04	1.62E-03	1.22E-03	4.48E-03	1.33E-03	1.2672E+00	7.7917E+02

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9914600	0.9953610	0.9956700	0.9981970	0.9969960	1.0418E+03	4.8551E+00
α_2	4.31E-04	2.13E-03	1.82E-03	4.88E-03	1.00E-03	2.2281E+00	1.0444E+03
α_3	3.04E-04	1.82E-03	1.51E-03	4.38E-03	1.50E-03	1.9043E+00	1.0448E+03
α_4	1.35E-05	6.90E-04	4.10E-04	2.32E-03	5.01E-04	7.2267E-01	1.0459E+03

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9916730	0.9951470	0.9953930	0.9977880	0.9975950	1.3408E+03	6.5383E+00
α_2	4.66E-04	1.94E-03	1.70E-03	4.24E-03	4.01E-04	2.6142E+00	1.3447E+03
α_3	3.35E-04	1.65E-03	1.41E-03	3.79E-03	1.00E-03	2.2274E+00	1.3451E+03
α_4	1.03E-04	1.02E-03	7.87E-04	2.74E-03	8.02E-04	1.3744E+00	1.3460E+03
α_5	4.82E-08	2.39E-04	6.53E-05	1.07E-03	2.00E-04	3.2228E-01	1.3470E+03

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9924610	0.9955010	0.9957000	0.9978450	0.9979950	1.6105E+03	7.2786E+00
α_2	3.51E-04	1.54E-03	1.34E-03	3.41E-03	1.67E-04	2.4892E+00	1.6153E+03
α_3	2.24E-04	1.25E-03	1.05E-03	2.95E-03	5.85E-04	2.0168E+00	1.6158E+03
α_4	1.54E-04	1.06E-03	8.64E-04	2.64E-03	7.52E-04	1.7172E+00	1.6161E+03
α_5	1.71E-05	5.24E-04	3.38E-04	1.66E-03	4.18E-04	8.4720E-01	1.6169E+03
α_6	2.29E-10	1.29E-04	1.48E-05	6.56E-04	8.35E-05	2.0824E-01	1.6176E+03

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9953410	0.9959990	0.9969960	0.9975950	0.9979950
α_2	4.66E-03	2.67E-03	1.00E-03	4.01E-04	1.67E-04
α_3		1.33E-03	1.50E-03	1.00E-03	5.85E-04
α_4			5.01E-04	8.02E-04	7.52E-04
α_5				2.00E-04	4.18E-04
α_6					8.35E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.95E-01	9.96E-01	9.97E-01	9.98E-01	9.98E-01
Beta	4.66E-03	4.00E-03	3.00E-03	2.40E-03	2.00E-03
Gamma		3.33E-01	6.67E-01	8.33E-01	9.17E-01
Delta			2.50E-01	5.00E-01	6.82E-01
Epsilon				2.00E-01	4.00E-01
Mu					1.67E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	497.85	746.78	995.71	1244.64	1493.56
N ₁	0.6667	0.0000	0.0000	0.0000	0.0000
N ₂	2.3333	2.0000	1.0000	0.5000	0.2500
N ₃		1.0000	1.5000	1.2500	0.8750
N ₄			0.5000	1.0000	1.1250
N ₅				0.2500	0.6250
N ₆					0.1250

2 No Data (Prior Only)

2.1.1.1 No Data

The section labeled No Data (Prior Only) shows the prior used in the CCF database. This is the result of calculating an application without any data, which is the same as calculating an application with all the events in the CCF database. These CCF parameters may be used for those cases where there is no reasonable set of data to approximate the intended event.

2.2 Generic Distributions

2.2.1 Generic Demand CCF Distribution

2.2.1.1 ALL CCF DEMAND BASED EVENTS 1997 TO CURRENT SPAR: CCF-DEM

Failure Mode :	Fail to close (reseat) on demand Fail to Open/Close Mode Unspecified (demand based) Fail to open on demand Fail to start Fail to Load/Run Fail to stop
Start Date :	1997/01/01
Data Version :	2010/12/31

Total Number of Independent Failure Events: 2821.80

Total Number of Common-Cause Failure Events: 95

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9679280	0.9760020	0.9762900	0.9830830	0.9761660	1.0674E+03	2.6245E+01
α_2	1.69E-02	2.40E-02	2.37E-02	3.21E-02	2.38E-02	2.6245E+01	1.0674E+03

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9689110	0.9755070	0.9756980	0.9814460	0.9757250	1.5955E+03	4.0060E+01
α_2	1.15E-02	1.62E-02	1.60E-02	2.17E-02	1.60E-02	2.6557E+01	1.6090E+03
α_3	4.95E-03	8.26E-03	8.06E-03	1.22E-02	8.25E-03	1.3503E+01	1.6221E+03

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9689330	0.9747150	0.9748630	0.9799950	0.9750170	2.1153E+03	5.4874E+01
α_2	1.13E-02	1.54E-02	1.53E-02	2.00E-02	1.52E-02	3.3455E+01	2.1367E+03
α_3	3.95E-03	6.50E-03	6.35E-03	9.57E-03	6.46E-03	1.4109E+01	2.1561E+03
α_4	1.61E-03	3.37E-03	3.22E-03	5.64E-03	3.34E-03	7.3097E+00	2.1629E+03

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9721560	0.9770540	0.9771730	0.9815520	0.9775280	2.6748E+03	6.2818E+01
α_2	8.03E-03	1.11E-02	1.10E-02	1.46E-02	1.07E-02	3.0426E+01	2.7072E+03
α_3	4.24E-03	6.55E-03	6.43E-03	9.28E-03	6.43E-03	1.7939E+01	2.7197E+03
α_4	2.18E-03	3.91E-03	3.79E-03	6.06E-03	3.92E-03	1.0711E+01	2.7269E+03
α_5	4.45E-04	1.37E-03	1.25E-03	2.70E-03	1.39E-03	3.7417E+00	2.7339E+03

Generic Demand CCF Distribution

ALL CCF DEMAND BASED EVENTS 1997 TO CURRENT SPAR: CCF-DEM

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9745600	0.9788530	0.9789530	0.9828180	0.9793970	3.2045E+03	6.9231E+01
α_2	6.15E-03	8.63E-03	8.53E-03	1.14E-02	8.25E-03	2.8242E+01	3.2455E+03
α_3	3.83E-03	5.84E-03	5.74E-03	8.19E-03	5.70E-03	1.9120E+01	3.2546E+03
α_4	2.22E-03	3.80E-03	3.70E-03	5.72E-03	3.76E-03	1.2439E+01	3.2613E+03
α_5	1.09E-03	2.27E-03	2.16E-03	3.78E-03	2.28E-03	7.4165E+00	3.2663E+03
α_6	1.10E-04	6.15E-04	5.17E-04	1.46E-03	6.12E-04	2.0134E+00	3.2717E+03

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9761660	0.9757250	0.9750170	0.9775280	0.9793970
α_2	2.38E-02	1.60E-02	1.52E-02	1.07E-02	8.25E-03
α_3		8.25E-03	6.46E-03	6.43E-03	5.70E-03
α_4			3.34E-03	3.92E-03	3.76E-03
α_5				1.39E-03	2.28E-03
α_6					6.12E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.76E-01	9.76E-01	9.75E-01	9.78E-01	9.79E-01
Beta	2.38E-02	2.43E-02	2.50E-02	2.25E-02	2.06E-02
Gamma		3.40E-01	3.92E-01	5.22E-01	6.00E-01
Delta			3.41E-01	4.52E-01	5.38E-01
Epsilon				2.62E-01	4.35E-01
Mu					2.12E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	1015.04	1522.55	2030.07	2537.59	3045.11
N₁	42.0650	43.3744	39.0866	41.0323	42.4318
N₂	25.8106	25.7231	32.2268	28.3118	26.0027
N₃		13.2362	13.7050	16.9613	17.9781
N₄			7.0870	10.3371	11.8469
N₅				3.6694	7.1943
N₆					1.9302

2.2.2 Generic Rate CCF Distribution

2.2.2.1 ALL CCF RATE BASED EVENTS 1997 TO CURRENT SPAR: CCF-RATE

Failure Mode :

Spurious operation open or close
 Fail to Run (Normally running equipment)
 Filter media allows the pass through of debris
 Failure of Control Function Only
 High dP across filter
 Fail to Run >1 Hour (Standby equipment)
 Fail to control flow
 Fail to Run less than 1 Hour
 Fail to Operate (General operation failure, rate based)

Loss of heat transfer capabilities in heat exchangers

Start Date :

No flow/plugged

Data Version :

1997/01/01

2010/12/31

Total Number of Independent Failure Events: 2433.50

Total Number of Common-Cause Failure Events: 99

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9546190	0.9640470	0.9643150	0.9725600	0.9640900	1.1169E+03	4.1654E+01
α_2	2.74E-02	3.60E-02	3.57E-02	4.54E-02	3.59E-02	4.1654E+01	1.1169E+03

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9582460	0.9657470	0.9659280	0.9726330	0.9657760	1.6645E+03	5.9037E+01
α_2	1.45E-02	1.97E-02	1.95E-02	2.55E-02	1.95E-02	3.3908E+01	1.6896E+03
α_3	1.02E-02	1.46E-02	1.44E-02	1.96E-02	1.47E-02	2.5129E+01	1.6984E+03

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9618670	0.9681350	0.9682740	0.9739420	0.9682810	2.2088E+03	7.2699E+01
α_2	1.10E-02	1.50E-02	1.48E-02	1.94E-02	1.47E-02	3.4148E+01	2.2474E+03
α_3	6.89E-03	1.01E-02	9.92E-03	1.37E-02	1.01E-02	2.2953E+01	2.2585E+03
α_4	4.27E-03	6.84E-03	6.69E-03	9.90E-03	6.88E-03	1.5598E+01	2.2659E+03

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9665110	0.9717760	0.9718820	0.9766630	0.9720370	2.7911E+03	8.1064E+01
α_2	7.42E-03	1.03E-02	1.02E-02	1.36E-02	9.92E-03	2.9626E+01	2.8425E+03
α_3	5.93E-03	8.55E-03	8.44E-03	1.16E-02	8.51E-03	2.4566E+01	2.8476E+03
α_4	3.54E-03	5.62E-03	5.50E-03	8.09E-03	5.69E-03	1.6139E+01	2.8560E+03
α_5	2.08E-03	3.74E-03	3.62E-03	5.78E-03	3.85E-03	1.0733E+01	2.8614E+03

Generic Rate CCF Distribution

ALL CCF RATE BASED EVENTS 1997 TO CURRENT SPAR: CCF-RATE

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9701220	0.9746820	0.9747770	0.9789330	0.9750480	3.3448E+03	8.6882E+01
α_2	5.07E-03	7.29E-03	7.19E-03	9.83E-03	6.88E-03	2.5014E+01	3.4067E+03
α_3	4.91E-03	7.10E-03	7.00E-03	9.60E-03	7.01E-03	2.4348E+01	3.4073E+03
α_4	3.55E-03	5.44E-03	5.34E-03	7.65E-03	5.46E-03	1.8666E+01	3.4130E+03
α_5	1.67E-03	3.03E-03	2.94E-03	4.72E-03	3.08E-03	1.0408E+01	3.4213E+03
α_6	1.25E-03	2.46E-03	2.37E-03	4.00E-03	2.53E-03	8.4458E+00	3.4232E+03

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
α_1	0.9640900	0.9657760	0.9682810	0.9720370	0.9750480
α_2	3.59E-02	1.95E-02	1.47E-02	9.92E-03	6.88E-03
α_3		1.47E-02	1.01E-02	8.51E-03	7.01E-03
α_4			6.88E-03	5.69E-03	5.46E-03
α_5				3.85E-03	3.08E-03
α_6					2.53E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.64E-01	9.66E-01	9.68E-01	9.72E-01	9.75E-01
Beta	3.59E-02	3.42E-02	3.17E-02	2.80E-02	2.50E-02
Gamma		4.29E-01	5.35E-01	6.45E-01	7.24E-01
Delta			4.05E-01	5.28E-01	6.12E-01
Epsilon				4.03E-01	5.06E-01
Mu					4.51E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	1064.99	1597.48	2129.98	2662.47	3194.97
N₁	41.6641	37.4219	32.6854	32.5040	32.9120
N₂	41.2199	33.0742	32.9199	27.5114	22.7750
N₃		24.8618	22.5482	23.5890	23.2064
N₄			15.3758	15.7646	18.0733
N₅				10.6611	10.1861
N₆					8.3626

2.2.3 CCF Prior Distribution

2.2.3.1 No Data (Prior Only)

Data Version :

2007/12/31

Total Number of Independent Failure Events: 0
 Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS

CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.8993200	0.9742690	0.9887700	0.9999290	----	1.7418E+01	4.6002E-01
α_2	6.65E-05	2.57E-02	1.12E-02	1.00E-01	----	4.6002E-01	1.7418E+01

CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9306240	0.9755060	0.9819700	0.9982830	----	4.5105E+01	1.1325E+00
α_2	6.61E-04	1.87E-02	1.23E-02	5.84E-02	----	8.6476E-01	4.5372E+01
α_3	2.07E-07	5.79E-03	1.17E-03	2.74E-02	----	2.6776E-01	4.5969E+01

CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9380870	0.9740820	0.9782970	0.9956540	----	7.0868E+01	1.8856E+00
α_2	1.43E-03	1.70E-02	1.28E-02	4.69E-02	----	1.2400E+00	7.1513E+01
α_3	9.66E-06	5.89E-03	2.32E-03	2.38E-02	----	4.2870E-01	7.2324E+01
α_4	9.21E-09	2.98E-03	3.83E-04	1.50E-02	----	2.1695E-01	7.2536E+01

CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9521790	0.9760740	0.9782400	0.9925770	----	1.4106E+02	3.4576E+00
α_2	2.59E-03	1.41E-02	1.19E-02	3.30E-02	----	2.0400E+00	1.4247E+02
α_3	3.01E-04	6.59E-03	4.50E-03	2.00E-02	----	9.5369E-01	1.4356E+02
α_4	2.21E-06	2.67E-03	9.37E-04	1.12E-02	----	3.8684E-01	1.4413E+02
α_5	5.61E-20	5.33E-04	5.18E-07	3.10E-03	----	7.7129E-02	1.4444E+02

CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9553700	0.9762820	0.9779970	0.9913440	----	1.7893E+02	4.3470E+00
α_2	2.60E-03	1.24E-02	1.07E-02	2.81E-02	----	2.2804E+00	1.8099E+02
α_3	4.16E-04	6.13E-03	4.45E-03	1.75E-02	----	1.1245E+00	1.8215E+02
α_4	3.82E-05	3.40E-03	1.85E-03	1.20E-02	----	6.2471E-01	1.8265E+02
α_5	1.60E-08	1.32E-03	2.18E-04	6.46E-03	----	2.4272E-01	1.8303E+02
α_6	1.26E-20	4.07E-04	3.05E-07	2.36E-03	----	7.4722E-02	1.8320E+02

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9603690	0.9769760	0.9781320	0.9896440	----	2.6720E+02	6.2971E+00
α_2	3.14E-03	1.12E-02	1.00E-02	2.33E-02	----	3.0721E+00	2.7042E+02
α_3	6.66E-04	5.55E-03	4.40E-03	1.43E-02	----	1.5182E+00	2.7197E+02
α_4	1.58E-04	3.48E-03	2.37E-03	1.06E-02	----	9.5310E-01	2.7254E+02
α_5	1.00E-05	1.93E-03	9.22E-04	7.26E-03	----	5.2795E-01	2.7296E+02
α_6	4.58E-10	7.08E-04	6.75E-05	3.68E-03	----	1.9373E-01	2.7330E+02
α_7	5.03E-44	1.17E-04	8.41E-13	4.81E-04	----	3.2027E-02	2.7346E+02

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
α_1	0.9622170	0.9773660	0.9783580	0.9891370	----	3.1221E+02	7.2302E+00
α_2	3.13E-03	1.04E-02	9.45E-03	2.12E-02	----	3.3414E+00	3.1609E+02
α_3	6.67E-04	5.04E-03	4.06E-03	1.28E-02	----	1.6130E+00	3.1782E+02
α_4	1.86E-04	3.26E-03	2.30E-03	9.62E-03	----	1.0438E+00	3.1839E+02
α_5	3.88E-05	2.20E-03	1.28E-03	7.47E-03	----	7.0280E-01	3.1873E+02
α_6	5.77E-07	1.13E-03	3.63E-04	4.86E-03	----	3.6184E-01	3.1907E+02
α_7	1.19E-13	3.98E-04	8.44E-06	2.25E-03	----	1.2739E-01	3.1931E+02
α_8	5.47E-36	1.25E-04	5.43E-11	6.01E-04	----	4.0005E-02	3.1940E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
α_1	0.0000000	0.0000000	0.0000000	0.0000000	0.0000000	0.0000000	0.0000000
α_2	0.00E+00						
α_3		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_4			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_5				0.00E+00	0.00E+00	0.00E+00	0.00E+00
α_6					0.00E+00	0.00E+00	0.00E+00
α_7						0.00E+00	0.00E+00
α_8							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

3 Glossary

Application

A particular set of CCF events selected from the CCF database for use in a specific study.

Average Impact Vector

An average over the impact vectors for different hypotheses regarding the number of components failed in an event.

Available

The component is available if it is capable of performing its function according to a specified success criterion.

Basic Event

An event in a reliability logic model that represents the state in which a component or group of components is unavailable and does not require further development in terms of contributing causes.

Common Cause Event

A dependent failure in which two or more component fault states exist simultaneously, or within a short time interval, and are a direct result of a shared cause.

Common Cause Basic Event

In system modeling, a basic event that represents the unavailability of a specific set of components because of shared causes that are not explicitly represented in the system logic model as other basic events.

Common Cause Component Group

A group of (usually similar [in mission, manufacturer, maintenance, environment, etc.]) components that are considered to have a high potential for failure due to the same cause or causes.

Common Cause Failure Model

The basis for quantifying the frequency of common cause events. Examples include the beta factor, alpha factor, and basic parameter, and the binomial failure rate models.

Complete Common Cause Failure

A CCF in which all redundant components are failed simultaneously as a direct result of a shared cause; i.e., the component degradation value equals 1.0 for all components, and both the timing factor and the shared cause factor are equal to 1.0.

Component

An element of plant hardware designed to provide a particular function.

Component Boundary

The component boundary encompasses the set of piece parts that are considered to form the component.

Component Degradation Value (p)

The assessed probability ($0.0 = p = 1.0$) that a functionally or physically degraded component would fail to complete the mission.

Component State

Component state defines the component status in regard to its intended function. Two general categories of component states are defined as available and unavailable.

Timing Factor (q)

The probability ($0.0 = q = 1.0$) that two or more component failures (or degraded states) separated in time represent a CCF. This can be viewed as an indication of the strength-of-coupling in synchronizing failure times.

Unavailable

The component is unavailable if the component is unable to perform its intended function according to a stated success criterion. Two subsets of unavailable states are failure and functionally unavailable.

Exposed Population

The set of components within the plant that are potentially affected by the CCF under consideration.

Failure

The component is not capable of performing its specified operation according to a success criterion.

Functionally Unavailable

The component is capable of operation, but the function normally provided by the component is unavailable due to lack of proper input, lack of support function from a source outside the component (i.e., motive power, actuation signal), maintenance, testing, the improper interference of a person, etc.

Potentially Unavailable

The component is capable of performing its function according to a success criterion, but an incipient or degraded condition exists. (N.B., potentially unavailable is not synonymous with hypothetical.)

Defense

Any operational, maintenance, and design measures taken to diminish the frequency and/or consequences of CCFs.

Degraded

The component is in such a state that it exhibits reduced performance but insufficient degradation to declare the component unavailable according to the specified success criterion.

Impact Vector

An assessment of the impact an event would have on a common cause component group. The impact is usually measured as the number of failed components out of a set of similar components in the common cause component group.

Incipient

The component is in a condition that, if left unremedied, could ultimately lead to a degraded or unavailable state.

Reliability Logic Model

A logical representation of the combinations of component states that could lead to

system failure. A fault tree is an example of a system logic model.

Root Cause

The most basic reason for a component failure, which, if corrected, could prevent recurrence. The identified root cause may vary depending on the particular defensive strategy adopted against the failure mechanism.

Shared Cause Factor/Mechanism

A set of causes and factors characterizing why and how a failure is systematically induced in several components.

Failure Mechanism

The history describing the events and influences leading to a given failure.

Failure Mode

A description of component failure in terms of the component function that was actually or potentially unavailable.

Failure Mode Applicability

The analyst's probability that the specified component failure mode for a given event is appropriate to the particular application.

Mapping

The impact vector of an event must be "mapped up" or "mapped down" when the exposed population of the target plant is higher or lower than that of the original plant that experienced the CCF. The end result of mapping an impact vector is an adjusted impact vector applicable to the target plant.

Mapping up Factor

A factor used to adjust the impact vector of an event when the exposed population of the target plan is higher than that of the original plant that experienced the CCF.

Potential Common Cause Failure

Any common cause event in which at least one component degradation value is less than 1.0.

Proximate Cause

A characterization of the condition that is readily identified as leading to failure of the component. It might alternatively be characterized as a symptom.

Shared-Cause Factor (c)

A number that reflects the analyst's uncertainty ($0.0 = c = 1.0$) about the existence of coupling among the failures of two or more components, i.e., whether a shared cause of failure can be clearly identified.

Shock

A shock is an event that occurs at a random point in time and acts on the system; i.e., all the components in the system simultaneously. There are two kinds of shocks distinguished by the potential impact of the shock event, i.e., lethal and non-lethal.

System

The entity that encompasses an interacting collection of components to provide a particular function or functions.