

Component Performance Study

Air-Operated Valves

1998–2007

1 INTRODUCTION

This report presents a performance evaluation of air-operated valves (AOVs) at U.S. commercial nuclear power plants. This report does not estimate values for use in probabilistic risk assessments (PRAs), but does evaluate component performance over time. Reference 1 ([NUREG/CR-6928](#)) reports AOV unreliability estimates using Equipment Performance and Information Exchange (EPIX) data from 1998–2002 for use in PRAs.

The trend evaluations in this study are based on the operating experience failure reports from fiscal year (FY) 1998 through FY 2007 for the component reliability as reported in EPIX. The AOV failure modes considered are failure-to-open/close (failure to operate) (FTOC) and spurious operation (SO).

Previously, the study relied on operating experience obtained from licensee event reports, Nuclear Plant Reliability Data System (NPRDS), and EPIX. The EPIX database (which includes as a subset the Mitigating Systems Performance Index (MSPI) designated devices) has matured to the point where component availability and reliability can be estimated with a higher degree of assurance of accuracy. In addition, the population of data is much larger than the population used in the previous study.

The objective of the effort for the updated component performance studies is to obtain annual performance trends of failure rates and probabilities. An overview of the trending methods, glossary of terms, and abbreviations can be found in the [Overview and Reference](#) document on the Reactor Operational Experience Results and Databases web page.

2 SUMMARY OF FINDINGS

The results of this study are summarized in this section. Of particular interest is the existence of any statistically significant¹ increasing trends. In this update, no statistically significant increasing trends were identified in the AOV results. Statistically significant decreasing trends were identified in the AOV results for the following:

- Frequency (demands per reactor year) of AOV operation demands. (see Figure 3)
- Frequency (failures per reactor year) of AOV FTOC events. (see Figure 4)

Table 3 shows that 88% of the AOV FTOC failures occurred in 6 systems. Similarly, Table 4 shows that 83% of the AOV SO failures occurred in 5 systems.

¹ Statistical significance is defined in terms of the 'p-value.' A p-value is a probability indicating whether to accept or reject the null hypothesis that there is no trend in the data. P-values of less than or equal to 0.05 indicate that we are 95% confident that there is a trend in the data (reject the null hypothesis of no trend.) By convention, we use the "Michelin Guide" scale: p-value < 0.05 (statistically significant), p-value < 0.01 (highly statistically significant); p-value < 0.001 (extremely statistically significant).

3 FAILURE PROBABILITIES AND FAILURE RATES

3.1 Overview

The industry-wide failure probabilities and failure rates of AOVs have been calculated from the operating experience for the FTOC and SO failure modes. The AOV data set obtained from EPIX was reduced to include only those AOVs with ≤ 20 demands/year (to match the standby data collection criteria in [NUREG/CR-6928](#)) and includes AOVs in the systems listed in Table 1. Table 2 shows industry-wide failure probability and failure rate results for the AOV from Reference 1.

The AOVs are assumed to operate both when the reactor is critical and during shutdown periods. The number of valves in operation is assumed to be constant throughout the study period. All demand types are considered—testing, non-testing, and, as applicable, emergency safeguard feature (ESF) demands.

Table 1. AOV systems.

System	Description	Valve Count	System	Description	Valve Count
AFW	Auxiliary feedwater	264	LPCI	Low pressure coolant injection	36
CCW	Component cooling water	361	LPCS	Low pressure core spray	10
CDS	Condensate system	23	LPI	Low pressure injection	199
CRD	Control rod drive	101	MFW	Main feedwater	320
CSR	Containment spray recirculation	32	MSS	Main steam	104
CVC	Chemical and volume control	442	SLC	Standby liquid control	1
EPS	Emergency power supply	29	SWN	Normal service water	377
FWS	Firewater	1	SWS	Emergency service water (Standby)	22
HPCI	High pressure coolant injection	8			
HPSI	High pressure injection	87			
ISO	Isolation condenser	5			
			Total		2422

Table 2. Industry-wide distributions of p (failure probability) and λ (hourly rate) for AOVs.

Failure Mode	5%	Median	Mean	95%	Distribution		
					Type	α	β
FTOC	6.0E-05	8.0E-04	1.2E-03	4.0E-03	Beta	1.00	8.33E+02
SO	2.0E-11	5.0E-08	2.0E-07	9.0E-07	Gamma	0.30	1.50E+06

3.2 AOV Failure Probability and Failure Rate Trends

Trends in failure probabilities and failure rates are shown in Figure 1 and Figure 2. The data for the trend plots are contained in Table 5 and Table 6, respectively.




Figure 1. All systems, industry-wide AOV FTOC trend.




Figure 2. All systems, industry-wide AOV SO trend.

In the plots, the means of the posterior distributions from the Bayesian update process were trended across the years. The posterior distributions were also used for the vertical bounds for each year. The 5th and 95th percentiles of these distributions give an indication of the relative variation from year to year in the data. When there are no failures, the interval is larger than the interval for years when there are one or more failures. The larger interval reflects the uncertainty that comes from having little information in that year's data. Such uncertainty intervals are determined by the prior distribution. In each plot, a relatively "flat" constrained noninformative prior distribution (CNID) is used, which has large bounds.

The horizontal curves plotted around the regression lines in the graphs form 90 percent simultaneous confidence bands for the fitted lines. The bounds are larger than ordinary confidence intervals for the trended values because they form a band that has a 90% probability of containing the entire line. In the lower left hand corner of the trend figures, the regression p-values are reported. They come from a statistical test on whether the slope of the regression line might be zero. Low p-values indicate that the slopes are not likely to be zero, and that trends exist. Further information on the trending methods is provided in Section 2 of the [Overview and Reference](#) document. A final feature of the trend graphs is that the baseline industry values from Table 2 are shown for comparison.

4 ENGINEERING TRENDS

This section presents frequency trends for AOV failures and demands. The data are normalized by reactor year for plants that have the equipment being trended. Figure 3 shows the trend for AOV demands. Figure 4 shows the trend in failure events for FTOC mode, and Figure 5 shows the trend for the SO failure events. Table 3 summarizes the failures by system, year, and the FTOC failure mode. The major contributing systems for the FTOC failure mode are AFW, CVC, ESW, and MFW. Table 4 summarizes the failures by system, year, and the SO failure mode. The major contributing systems for the SO failure mode are AFW, CCW, CVC, and MFW. Table 7, Table 8, and Table 9 provide the frequency (per reactor year) of AOV demands, FTOC events, and SO events, respectively. The systems from Table 2 are trended together for each figure. The rate methods described in Section 2 of the [Overview and Reference](#) document are used.




Figure 3. Frequency (demands per reactor year) of AOV operation demands.




Figure 4. Frequency (failures per reactor year) of AOV FTOC events.




Figure 5. Frequency (failures per reactor year) of AOV SO events.

Table 3. Summary of AOV failure counts for the FTOC failure mode over time by system.

System Code	Valve Count	Valve Percent	FY 98	FY 99	FY 00	FY 01	FY 02	FY 03	FY 04	FY 05	FY 06	FY 07	Total	Percent of Failures
AFW	264	10.9%	4	0	1	3	0	0	0	4	2	3	17	13.0%
CCW	361	14.9%	2	0	2	1	3	1	0	0	2	2	13	9.9%
CDS	23	0.9%	0	0	0	0	0	0	0	0	0	0	0	0.0%
CRD	101	4.2%	0	1	1	0	0	0	0	0	0	0	2	1.5%
CSR	32	1.3%	1	0	0	0	0	0	0	2	0	0	3	2.3%
CVC	442	18.2%	2	3	1	1	5	2	0	0	1	2	17	13.0%
EPS	29	1.2%	0	0	0	0	0	0	0	0	0	0	0	0.0%
FWS	1	0.0%	0	0	0	0	0	0	0	0	0	0	0	0.0%
HPCI	8	0.3%	0	0	0	0	0	0	0	0	0	0	0	0.0%
HPSI	87	3.6%	0	0	0	0	0	2	0	0	1	0	3	2.3%
ISO	5	0.2%	0	0	0	0	0	0	0	0	0	0	0	0.0%
LPCI	36	1.5%	0	0	0	0	0	0	0	0	1	1	2	1.5%
LPCS	10	0.4%	0	1	0	0	0	0	0	0	0	0	1	0.8%
LPI	199	8.2%	0	3	2	0	1	2	0	0	2	1	11	8.4%
MFW	320	13.2%	6	6	5	4	2	1	4	3	1	1	33	25.2%
MSS	104	4.3%	1	0	3	0	0	0	0	0	1	0	5	3.8%
SLC	1	0.0%	0	0	0	0	0	0	0	0	0	0	0	0.0%
SWN	377	15.6%	5	5	2	3	0	1	3	1	3	1	24	18.3%
SWS	22	0.9%	0	0	0	0	0	0	0	0	0	0	0	0.0%
Total	2422	100.0%	21	19	17	12	11	9	7	10	14	11	131	100.0%

Table 4. Summary of AOV failure counts for the SO failure mode over time by system.

System Code	Valve Count	Valve Percent	FY 98	FY 99	FY 00	FY 01	FY 02	FY 03	FY 04	FY 05	FY 06	FY 07	Total	Percent of Failures
AFW	264	10.9%	0	0	0	2	1	1	1	0	0	1	6	13.0%
CCW	361	14.9%	0	2	1	0	7	0	0	0	0	1	11	23.9%
CDS	23	0.9%	0	0	0	0	0	0	0	0	0	0	0	0.0%
CRD	101	4.2%	0	4	0	0	0	0	0	0	0	0	4	8.7%
CSR	32	1.3%	0	0	0	0	0	0	0	0	0	0	0	0.0%
CVC	442	18.2%	0	0	0	0	5	0	0	1	0	0	6	13.0%
EPS	29	1.2%	0	0	0	0	0	0	0	0	0	0	0	0.0%
FWS	1	0.0%	0	0	0	0	0	0	0	0	0	0	0	0.0%
HPCI	8	0.3%	0	0	0	0	0	0	0	0	0	0	0	0.0%
HPSI	87	3.6%	0	0	0	0	0	1	0	0	0	0	1	2.2%
ISO	5	0.2%	0	0	0	0	0	0	0	0	0	0	0	0.0%
LPCI	36	1.5%	0	0	0	0	0	0	0	0	0	0	0	0.0%
LPCS	10	0.4%	0	0	0	0	0	0	0	0	0	0	0	0.0%
LPI	199	8.2%	2	0	0	0	0	0	0	0	0	0	2	4.3%
MFW	320	13.2%	3	0	0	1	2	0	0	2	3	0	11	23.9%
MSS	104	4.3%	0	2	0	0	0	0	0	0	0	0	2	4.3%
SLC	1	0.0%	0	0	0	0	0	0	0	0	0	0	0	0.0%
SWN	377	15.6%	0	0	0	2	0	0	0	0	1	0	3	6.5%
SWS	22	0.9%	0	0	0	0	0	0	0	0	0	0	0	0.0%
Total	2422	100.0%	5	8	1	5	15	2	1	3	4	2	46	100.0%

5 AOV ASSEMBLY DESCRIPTION

An AOV assembly consists of a valve body and pneumatic operator sub-components (includes the circuit breaker). The valve body is generally a globe or butterfly type. The pneumatic operator is generally a piston or diaphragm type actuator. Main steam isolation valves and power operated relief valves are excluded from the AOV study even though pneumatically operated, as these are valves with different design and operating features.

The piece-parts of the valve body are the stem, packing, and internals. The pneumatic operator piece-parts may include piston internals/seals or diaphragm, positioner, mechanical linkage, volume booster, pilot valve, bolting, air regulator, airline, and wiring/contacts. Failures associated with instrument air systems that are not integral to the AOV assembly (e.g., contamination from the instrument air system that failed the AOV) are excluded in the AOV analysis.

6 DATA TABLES

Table 5. Plot data for industry-wide AOV FTOC trend. Figure 1

FY/ Source	Failures	Demands	Regression Curve Data Points			Plot Trend Error Bar Points		
			Mean	Lower (5%)	Upper (95%)	Lower (5%)	Upper (95%)	Mean
NUREG/ CR-6928						6.16E-05	3.59E-03	1.20E-03
1998	21	10848	1.58E-03	1.10E-03	2.27E-03	1.29E-03	2.63E-03	1.91E-03
1999	19	11800	1.48E-03	1.09E-03	2.01E-03	1.05E-03	2.23E-03	1.60E-03
2000	17	11447	1.38E-03	1.07E-03	1.79E-03	9.47E-04	2.10E-03	1.48E-03
2001	12	10596	1.29E-03	1.04E-03	1.62E-03	6.64E-04	1.71E-03	1.14E-03
2002	11	10747	1.21E-03	9.80E-04	1.50E-03	5.87E-04	1.58E-03	1.03E-03
2003	9	10436	1.13E-03	9.03E-04	1.42E-03	4.66E-04	1.39E-03	8.76E-04
2004	7	11019	1.06E-03	8.14E-04	1.38E-03	3.18E-04	1.09E-03	6.57E-04
2005	10	9606	9.91E-04	7.24E-04	1.36E-03	5.79E-04	1.63E-03	1.05E-03
2006	14	9564	9.27E-04	6.39E-04	1.35E-03	8.87E-04	2.13E-03	1.45E-03
2007	11	9757	8.67E-04	5.61E-04	1.34E-03	6.44E-04	1.73E-03	1.13E-03

Table 6. Plot data for industry-wide AOV SO trend. Figure 2

FY/ Source	Failures	Hours	Regression Curve Data Points			Plot Trend Error Bar Points		
			Mean	Lower (5%)	Upper (95%)	Lower (5%)	Upper (95%)	Mean
NUREG/ CR-6928						2.14E-11	9.15E-07	2.00E-07
1998	5	21015240	2.42E-07	8.57E-08	6.80E-07	9.83E-08	4.23E-07	2.36E-07
1999	8	21015240	2.23E-07	9.32E-08	5.34E-07	1.86E-07	5.93E-07	3.65E-07
2000	1	21015240	2.06E-07	9.88E-08	4.29E-07	7.56E-09	1.68E-07	6.44E-08
2001	5	21015240	1.90E-07	1.01E-07	3.60E-07	9.83E-08	4.23E-07	2.36E-07
2002	15	21015240	1.76E-07	9.64E-08	3.20E-07	4.14E-07	9.66E-07	6.66E-07
2003	2	21015240	1.62E-07	8.60E-08	3.07E-07	2.46E-08	2.38E-07	1.07E-07
2004	1	21015240	1.50E-07	7.21E-08	3.12E-07	7.56E-09	1.68E-07	6.44E-08
2005	3	21015240	1.38E-07	5.80E-08	3.31E-07	4.66E-08	3.02E-07	1.50E-07
2006	4	21015240	1.28E-07	4.55E-08	3.59E-07	7.14E-08	3.63E-07	1.93E-07
2007	2	21015240	1.18E-07	3.52E-08	3.96E-07	2.46E-08	2.38E-07	1.07E-07

Table 7. Plot data for frequency (events per reactor year) of AOV operation demands. Figure 3

FY	Demands	Reactor Years	Regression Curve Data Points			Plot Trend Error Bar Points		
			Mean	Lower (5%)	Upper (95%)	Lower (5%)	Upper (95%)	Mean
1998	10848	94.0	1.22E+02	1.15E+02	1.30E+02	1.14E+02	1.17E+02	1.15E+02
1999	11800	94.0	1.20E+02	1.14E+02	1.27E+02	1.24E+02	1.27E+02	1.26E+02
2000	11447	94.3	1.18E+02	1.13E+02	1.23E+02	1.20E+02	1.23E+02	1.21E+02
2001	10596	94.0	1.16E+02	1.11E+02	1.20E+02	1.11E+02	1.15E+02	1.13E+02
2002	10747	94.0	1.13E+02	1.09E+02	1.17E+02	1.13E+02	1.16E+02	1.14E+02
2003	10436	94.0	1.11E+02	1.07E+02	1.15E+02	1.09E+02	1.13E+02	1.11E+02
2004	11019	94.3	1.09E+02	1.05E+02	1.13E+02	1.15E+02	1.19E+02	1.17E+02
2005	9606	94.0	1.07E+02	1.02E+02	1.12E+02	1.00E+02	1.04E+02	1.02E+02
2006	9564	94.0	1.05E+02	9.93E+01	1.11E+02	1.00E+02	1.03E+02	1.02E+02
2007	9757	94.0	1.03E+02	9.64E+01	1.10E+02	1.02E+02	1.06E+02	1.04E+02

Table 8. Plot data for frequency (events per reactor year) of AOV FTOC events. Figure 4

FY	Failures	Reactor Years	Regression Curve Data Points			Plot Trend Error Bar Points		
			Mean	Lower (5%)	Upper (95%)	Lower (5%)	Upper (95%)	Mean
1998	21	94.0	1.94E-01	1.39E-01	2.70E-01	1.48E-01	3.04E-01	2.20E-01
1999	19	94.0	1.78E-01	1.35E-01	2.35E-01	1.32E-01	2.80E-01	2.00E-01
2000	17	94.3	1.63E-01	1.29E-01	2.07E-01	1.15E-01	2.55E-01	1.79E-01
2001	12	94.0	1.50E-01	1.22E-01	1.84E-01	7.49E-02	1.93E-01	1.28E-01
2002	11	94.0	1.38E-01	1.13E-01	1.68E-01	6.71E-02	1.80E-01	1.18E-01
2003	9	94.0	1.27E-01	1.02E-01	1.56E-01	5.18E-02	1.54E-01	9.74E-02
2004	7	94.3	1.16E-01	9.09E-02	1.49E-01	3.71E-02	1.28E-01	7.67E-02
2005	10	94.0	1.07E-01	7.96E-02	1.43E-01	5.94E-02	1.67E-01	1.08E-01
2006	14	94.0	9.80E-02	6.92E-02	1.39E-01	9.07E-02	2.18E-01	1.49E-01
2007	11	94.0	9.00E-02	5.99E-02	1.35E-01	6.71E-02	1.80E-01	1.18E-01

Table 9. Plot data for frequency (events per reactor year) of AOV SO events. Figure 5

FY	Failures	Reactor Years	Regression Curve Data Points			Plot Trend Error Bar Points		
			Mean	Lower (5%)	Upper (95%)	Lower (5%)	Upper (95%)	Mean
1998	5	94.0	5.39E-02	1.91E-02	1.52E-01	2.20E-02	9.45E-02	5.28E-02
1999	8	94.0	4.98E-02	2.08E-02	1.19E-01	4.16E-02	1.32E-01	8.16E-02
2000	1	94.3	4.60E-02	2.21E-02	9.60E-02	1.69E-03	3.74E-02	1.44E-02
2001	5	94.0	4.25E-02	2.25E-02	8.04E-02	2.20E-02	9.45E-02	5.28E-02
2002	15	94.0	3.93E-02	2.15E-02	7.16E-02	9.26E-02	2.16E-01	1.49E-01
2003	2	94.0	3.63E-02	1.92E-02	6.85E-02	5.50E-03	5.32E-02	2.40E-02
2004	1	94.3	3.35E-02	1.61E-02	6.97E-02	1.69E-03	3.74E-02	1.44E-02
2005	3	94.0	3.09E-02	1.29E-02	7.39E-02	1.04E-02	6.76E-02	3.36E-02
2006	4	94.0	2.86E-02	1.02E-02	8.04E-02	1.60E-02	8.13E-02	4.32E-02
2007	2	94.0	2.64E-02	7.86E-03	8.87E-02	5.50E-03	5.32E-02	2.40E-02

7 REFERENCE

1. S.A. Eide, et al, *Industry-Average Performance for Components and Initiating Events at U.S. Commercial Nuclear Power Plants*, U.S. Nuclear Regulatory Commission, NUREG/CR-6928, February 2007.