



# System Study: High-Pressure Coolant Injection 1998–2022

December 2023

Zhegang Ma, Kellie Kvarfordt  
*Idaho National Laboratory*

Thomas Wierman  
*Schroeder Incorporated*



*INL is a U.S. Department of Energy National Laboratory  
operated by Battelle Energy Alliance, LLC*

#### **DISCLAIMER**

This information was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

**System Study:  
High-Pressure Coolant Injection  
1998–2022**

**Zhegang Ma, Kellie Kvarfordt  
Idaho National Laboratory  
Thomas Wierman  
Schroeder Incorporated**

**December 2023**

**Idaho National Laboratory  
Idaho Falls, Idaho 83415**

**<http://www.inl.gov>**

**Prepared for the  
Division of Risk Assessment  
Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
NRC Agreement Number 31310019N0006  
Task Order Number 31310019F0022**

*Page intentionally left blank*

## **ABSTRACT**

This report presents an unreliability evaluation of the high-pressure coolant injection (HPCI) system at 22 U.S. commercial operating boiling water reactors. New Standardized Plant Analysis Risk (SPAR) models with the most recent SPAR parameter update results were used in this report. Demand, run hour, and failure data from 1998–2022 for selected components were obtained from the Institute of Nuclear Power Operations Industry Reporting and Information System. The unreliability results are trended for the most recent 10-year period while yearly estimates for system unreliability are provided for the entire active period. No statistically significant increasing or decreasing trends were identified in the HPCI results.

*Page intentionally left blank*

## **CONTENTS**

ABSTRACT.....	iii
ACRONYMS.....	vii
1. INTRODUCTION.....	1
2. SUMMARY OF FINDINGS .....	3
3. INDUSTRY-WIDE UNRELIABILITY .....	4
4. INDUSTRY-WIDE TRENDS .....	5
5. BASIC EVENT GROUP IMPORTANCES .....	7
6. DATA TABLES.....	9
7. SYSTEM DESCRIPTION .....	18
8. REFERENCES.....	20

## **FIGURES**

Figure 1. Trend of HPCI system start-only unreliability. ....	5
Figure 2. Trend of HPCI system 8-hour mission unreliability.....	6
Figure 3. HPCI basic event group importances. ....	7
Figure 4. HPCI system diagram.....	19

## **TABLES**

Table 1. BWR plants with a HPCI system selected for the study.....	2
Table 2. Industry-wide unreliability values. ....	4
For more discussion on the HPCI TDPs, see the TDP component reliability study at the NRC Reactor Operational Experience Results and Databases web page ( <a href="https://nrcoe.inl.gov/">https://nrcoe.inl.gov/</a> ). Table 3 shows the SPAR model HPCI importance groups and their descriptions.....	7
Table 3. HPCI model basic event importance group descriptions. ....	8
Table 5. Plot data for Figure 2, HPCI 8-hour mission unreliability trend.....	10
Table 6. Basic event reliability trending data.....	11
Table 7. Basic event unavailability (UA) trending data.....	17
Table 8. Failure mode acronyms.....	17

*Page intentionally left blank*

## **ACRONYMS**

BWR	boiling water reactor
CCF	common-cause failure
CST	condensate storage tank
EPIX	Equipment Performance and Information Exchange
FTOC	fail to open/close
FTOP	fail to operate
FTR>1H	fail to run more than 1 hour (standby equipment)
FTR<1H	fail to run less than 1 hour (after start, standby equipment)
FTS	fail to start
HPCI	high-pressure coolant injection
ICES	INPO Consolidated Events Database
INPO	Institute of Nuclear Power Operations
IRIS	Industry Reporting and Information System
MOV	motor-operated valve
MSPI	Mitigating Systems Performance Index
NRC	Nuclear Regulatory Commission
PRA	probabilistic risk assessment
ROP	Reactor Oversight Process
RPV	reactor pressure vessel
SPAR	standardized plant analysis risk
SSU	safety system unavailability
TDP	turbine-driven pump
UA	unavailability (maintenance or state of another component)

*Page intentionally left blank*

# System Study: High-Pressure Coolant Injection

1998–2022

## 1. INTRODUCTION

This report presents an unreliability evaluation of the high-pressure coolant injection (HPCI) systems at the 22 U.S. commercial operating boiling water reactors (BWRs) listed in Table 1. For each reactor (or plant), the corresponding Standardized Plant Analysis Risk (SPAR) model was used in the yearly calculations. Demand, run hour, and failure data from calendar year 1998–2022 for selected components in the HPCI system were obtained from the Institute of Nuclear Power Operations (INPO) Industry Reporting and Information System (IRIS), formerly the INPO Consolidated Events Database (ICES) and the Equipment Performance and Information Exchange Database (EPIX). Train unavailability data (outages from test or maintenance) were obtained from the Reactor Oversight Process (ROP) Safety System Unavailability (SSU) database (1998–2001) and the Mitigating Systems Performance Index (MSPI) database (2002–2022). The system unreliability results are trended for the most recent 10-year period while yearly estimates for system unreliability are provided for the entire active period.

This report does not attempt to estimate basic event values for use in a probabilistic risk assessment (PRA). Suggested values for such use are presented in the 2020 SPAR parameter update including INL/EXT-21-65055, *Industry Average Performance for Components and Initiating Events at U.S. Commercial Nuclear Power Plants: 2020 Update* [1], which is the most recent update to NUREG/CR-6928 [2], and INL/EXT-21-62940, *CCF Parameter Estimations, 2020 Update* [3], for common-cause failure (CCF) parameters.

New SPAR models (versions of 8.80 or above, as indicated in Table 1) that utilize the 2020 SPAR parameter update results [1, 3] were used in this report. In previous system studies, which can be found at the Nuclear Regulatory Commission (NRC) Reactor Operational Experience Results and Databases web page (<https://nrcoe.inl.gov/>), older SPAR models (versions of 8.1 to 8.2) with the *2010 Component Reliability Update* [4] for basic event data were used for the 2011 through 2020 system study updates. For comparison purposes, it is necessary to use the same set of SPAR models and basic event data in the analysis while the only variables subject to change are yearly demand, run hour, failure, and unavailability data for selected components in the system. However, more recent SPAR models must be used to replace outdated models periodically so that the system study reflects the current plant and system configurations as well as the more representative baseline data for the industry performance. With the 2020 SPAR parameter and model updates concluded in 2022, it was a good time to revamp the system study with the more current models for the 2022 update.

The HPCI model is evaluated using the transient flag set in the SPAR model. The transient flag set assumes all support systems are available and that the HPCI system is required to perform to mitigate the effects of the transient initiating event. All models include failures due to unavailability while in test or maintenance. Human error and recovery events in the models are set to “Ignore” in the study for the results to represent that the mechanical part of the system has not been included in the SPAR model logic. An overview of the trending methods, glossary of terms, and abbreviations can be found in the *Overview and Reference* document [5] on the NRC web page (<https://nrcoe.inl.gov>).

Two variations of the HPCI system model are implemented and calculated. The HPCI start-only model is the HPCI SPAR model modified by setting all fail-to-run basic events to zero (“False”), all human error and recovery events to “Ignore,” the suction transfer to the torus to “False,” and all cooling basic events to “False.” The 8-hour mission model sets all human error and recovery events to “Ignore.”

Section 2 of this report summarizes the main findings from the study. Section 3 presents the baseline HPCI unreliability results using basic event values from the 2020 SPAR parameter update. Section 4 shows the trend results for HPCI unreliability using system-specific data as listed in Section 6. Section 5 provides the basic event group importance information using the baseline results from Section 3. Section 7 presents a high-level generic description of the HPCI system.

Table 1. BWR plants with a HPCI system selected for the study.

Plant	SPAR ID	SPAR Version
Browns Ferry 1	BRF1	8.80
Browns Ferry 2	BRF2	8.80
Browns Ferry 3	BRF3	8.80
Brunswick 1	BRU1	8.80
Brunswick 2	BRU2	8.80
Cooper	COOP	8.80
Dresden 2 & 3	DRES	8.81
Fermi 2	FERM	8.80
FitzPatrick	FITZ	8.80
Hatch 1 & 2	HATC	8.82
Hope Creek	HOPE	8.80
Limerick 1	LIM1	8.80
Limerick 2	LIM2	8.82
Monticello	MONT	8.81
Peach Bottom 2	PBT2	8.80
Peach Bottom 3	PBT3	8.80
Quad Cities 1 & 2	QCTY	8.80
Susquehanna 1	SUS1	8.82
Susquehanna 2	SUS2	8.80

## 2. SUMMARY OF FINDINGS

The results of this HPCI system unreliability study are summarized in this section. Of particular interest is any statistically significant<sup>a</sup> increasing trends. In this update, **no statistically significant increasing or decreasing trends** were identified in the HPCI system unreliability for the most recent 10-year period.

The industry-wide HPCI start-only and 8-hour mission basic event group importances were evaluated. For both **start-only and 8-hour mission, the leading contributor to HPCI system unreliability** is the **HPCI TDP** group of basic events followed by the **Injection** group.

---

<sup>a</sup> Statistically significant is defined in terms of the “p-value.” A p-value is a probability indicating whether to accept or reject the null hypothesis that there is no trend in the data. P-values of less than or equal to 0.05 indicate that we are 95% confident that there is a trend in the data (reject the null hypothesis of no trend.) By convention, we use the “Michelin Guide” scale: p-value < 0.05 (statistically significant); p-value < 0.01 (highly statistically significant); p-value < 0.001 (extremely statistically significant).

### 3. INDUSTRY-WIDE UNRELIABILITY

The HPCI fault trees from the SPAR models were evaluated for each of the 22 U.S. commercial operating boiling water nuclear power plants with a HPCI system.

The industry-wide unreliability of the HPCI system has been estimated for two variations. A failure-to-start (start-only) model and an 8-hour mission model were evaluated. The uncertainty distributions for HPCI show both plant design variability and parameter uncertainty from the industry-wide component failure data as in the 2020 SPAR parameter update.<sup>b</sup>

Table 2 shows the percentiles and mean of the aggregated sample data (Latin hypercube, 1,000 samples for each model) collected from the uncertainty calculations of the HPCI fault trees in the SPAR models. The lower and upper bounds are based directly on the samples (Latin hypercube) from the uncertainty calculations in the SPAR models. For the industry-level results, the SPAR samples were combined into one large sample to determine the industry-level bounds, mean, and median.

Table 2. Industry-wide unreliability values.

Model	Lower (5%)	Median	Mean	Upper (95%)
Start-only	1.19E-02	3.46E-02	4.72E-02	1.28E-01
8-hour Mission	5.55E-02	9.29E-02	1.03E-01	1.81E-01

---

<sup>b</sup> By using industry-wide component failure data, individual plant performance is not included in the distribution of results.

## 4. INDUSTRY-WIDE TRENDS

The yearly failure and demand or run-time data from 1998–2022 were obtained from IRIS for the HPCI system. HPCI train maintenance unavailability data for trending are from the same period, as reported in the ROP program and IRIS. The component basic event uncertainty was calculated for the HPCI system components using the trending methods described in Sections 1 and 2 of Reference [5]. Table 6 and Table 7 show the yearly data values for each HPCI system specific component and failure mode combination that was varied in the model. These data were loaded into the HPCI system fault tree in each SPAR model with a HPCI system (see Table 1).

The trend charts show the results of varying component reliability data over time and updating via generic, relatively flat prior distributions (or constrained noninformative distributions, refer to Section 2 of Reference [5]) using data for each year. In addition, the calculated industry-wide system reliability in Table 2 is shown as “SPAR/ ICES” in the charts for comparison. Section 4 of Reference [5] provides a more detailed discussion of the trending methods. In the lower left-hand corner of the trend figures, the regression method is reported. The regression method is indicated in the lower left-hand corner of the trend figures.

The components that were varied in the HPCI model are:

- HPCI turbine-driven pump start, run, and test and maintenance
- HPCI motor-operated valve fail to operate.

Figure 1 shows the trend in the start-only unreliability. Table 4 shows the data points for Figure 1. **No statistically significant increasing or decreasing trends** were identified within the industry-wide estimates of **HPCI system start-only unreliability** for the most recent 10-year period.

Figure 2 shows the trend in the 8-hour mission unreliability. Table 5 shows the data points for Figure 2. **No statistically significant trend** was identified within the industry-wide estimates of **HPCI system 8-hour mission unreliability** for the most recent 10-year period.




Figure 1. Trend of HPCI system start-only unreliability.




Figure 2. Trend of HPCI system 8-hour mission unreliability.

## 5. BASIC EVENT GROUP IMPORTANCES

The HPCI basic event group Fussell-Vesely importances were calculated for the start-only and 8-hour mission models for each plant using the industry-wide data from the 2020 SPAR parameter update. These basic event group importances were then averaged across all plants to represent an industry-wide basic event group importance.

The industry-wide HPCI start-only and 8-hour mission basic event group importances are shown in Figure 3. For both **start-only and 8-hour mission, the leading contributor to HPIC system unreliability** is the (HPCI) TDP group of basic events followed by the **Injection** group.

For more discussion on the HPCI TDPs, see the TDP component reliability study at the NRC Reactor Operational Experience Results and Databases web page (<https://nrccoe.inl.gov/>). Table 3 shows the SPAR model HPCI importance groups and their descriptions.




Figure 3. HPCI basic event group importances.

Table 3. HPCI model basic event importance group descriptions.

Group	Description
AC Power	The ac buses and circuit breakers that supply power to the HPCI motor-operated valves (MOVs)
Actuation	ESF actuation circuitry
Cooling	The pumps, valves, and heat exchangers that provide heat removal to the HPCI TDP
CST Suction	Suction path and condensate storage tank
DC Power	The batteries and battery chargers that supply power to the HPCI TDP control circuitry
EPS	HPCI dependency on the emergency power system
Injection	The MOVs and check valves in the HPCI injection path
Instrumentation	All basic events related to instrumentation and control
Room Cooling	All basic events associated with the pump room cooling
Steam Supply	The steam supply valves to the HPCI turbine
TDP	All basic events associated with the TDPs, including the start, run, common-cause, and test and maintenance
Torus	The suppression pool MOVs, check valves, and strainers required when a need to transfer to the suppression pool (torus) occurs

## 6. DATA TABLES

Table 4. Plot data for Figure 1, HPCI start-only unreliability trend.

Year/Source	Regression Curve Data Points			Annual Estimate Data Points		
	Lower (5%)	Mean	Upper (95%)	Lower (5%)	Mean	Upper (95%)
SPAR/ICES	--	--	--	1.19E-02	4.72E-02	1.28E-01
1998	--	--	--	1.01E-02	4.45E-02	1.25E-01
1999	--	--	--	1.44E-02	4.71E-02	1.28E-01
2000	--	--	--	1.30E-02	4.62E-02	1.28E-01
2001	--	--	--	8.67E-03	4.17E-02	1.23E-01
2002	--	--	--	1.15E-02	4.58E-02	1.27E-01
2003	--	--	--	1.03E-02	4.37E-02	1.25E-01
2004	--	--	--	9.16E-03	4.35E-02	1.25E-01
2005	--	--	--	1.19E-02	4.32E-02	1.25E-01
2006	--	--	--	1.04E-02	4.14E-02	1.23E-01
2007	--	--	--	1.37E-02	5.01E-02	1.32E-01
2008	--	--	--	1.02E-02	4.82E-02	1.33E-01
2009	--	--	--	1.68E-02	5.11E-02	1.33E-01
2010	--	--	--	1.28E-02	4.51E-02	1.26E-01
2011	--	--	--	1.71E-02	5.15E-02	1.33E-01
2012	--	--	--	1.18E-02	4.56E-02	1.27E-01
2013	3.97E-02	4.48E-02	5.05E-02	1.33E-02	4.61E-02	1.27E-01
2014	3.99E-02	4.43E-02	4.90E-02	8.63E-03	4.05E-02	1.22E-01
2015	4.01E-02	4.38E-02	4.77E-02	9.63E-03	4.09E-02	1.22E-01
2016	4.02E-02	4.33E-02	4.66E-02	1.75E-02	5.05E-02	1.32E-01
2017	4.01E-02	4.28E-02	4.57E-02	1.12E-02	4.46E-02	1.26E-01
2018	3.96E-02	4.23E-02	4.52E-02	7.93E-03	3.92E-02	1.21E-01
2019	3.89E-02	4.18E-02	4.50E-02	1.49E-02	4.67E-02	1.28E-01
2020	3.79E-02	4.14E-02	4.51E-02	7.37E-03	3.65E-02	1.18E-01
2021	3.69E-02	4.09E-02	4.53E-02	8.36E-03	4.06E-02	1.22E-01
2022	3.58E-02	4.04E-02	4.56E-02	8.60E-03	4.16E-02	1.24E-01

Table 5. Plot data for Figure 2, HPCI 8-hour mission unreliability trend.

Year/Source	Regression Curve Data Points			Plot Trend Error Bar Points		
	Lower (5%)	Mean	Upper (95%)	Lower (5%)	Mean	Upper (95%)
SPAR/ICES	--	--	--	5.55E-02	1.03E-01	1.81E-01
1998	--	--	--	1.70E-02	7.20E-02	1.87E-01
1999	--	--	--	2.08E-02	7.14E-02	1.78E-01
2000	--	--	--	4.23E-02	1.35E-01	2.86E-01
2001	--	--	--	1.51E-02	6.92E-02	1.84E-01
2002	--	--	--	1.88E-02	7.74E-02	2.00E-01
2003	--	--	--	2.21E-02	8.04E-02	2.04E-01
2004	--	--	--	3.69E-02	1.33E-01	2.86E-01
2005	--	--	--	1.84E-02	7.41E-02	1.96E-01
2006	--	--	--	1.70E-02	7.44E-02	2.02E-01
2007	--	--	--	2.86E-02	9.05E-02	2.16E-01
2008	--	--	--	4.33E-02	1.48E-01	3.11E-01
2009	--	--	--	2.50E-02	7.02E-02	1.61E-01
2010	--	--	--	3.62E-02	1.17E-01	2.50E-01
2011	--	--	--	7.63E-02	2.00E-01	3.71E-01
2012	--	--	--	1.91E-02	7.83E-02	2.04E-01
2013	7.60E-02	1.04E-01	1.41E-01	4.04E-02	1.34E-01	2.86E-01
2014	7.62E-02	9.94E-02	1.29E-01	1.54E-02	7.34E-02	2.00E-01
2015	7.60E-02	9.51E-02	1.18E-01	1.86E-02	7.54E-02	1.99E-01
2016	7.51E-02	9.09E-02	1.10E-01	5.00E-02	1.45E-01	2.98E-01
2017	7.32E-02	8.69E-02	1.03E-01	1.84E-02	7.78E-02	2.05E-01
2018	6.99E-02	8.31E-02	9.86E-02	1.44E-02	7.25E-02	2.00E-01
2019	6.55E-02	7.95E-02	9.61E-02	2.18E-02	7.85E-02	2.02E-01
2020	6.04E-02	7.59E-02	9.50E-02	1.32E-02	6.99E-02	1.97E-01
2021	5.52E-02	7.26E-02	9.48E-02	1.75E-02	7.55E-02	2.00E-01
2022	5.02E-02	6.93E-02	9.50E-02	1.80E-02	7.55E-02	1.98E-01

Table 6. Basic event reliability trending data.

Failure Mode	Component	Year	Number of Failures	Demands/Run Hours	Bayesian Update			
					Mean	Post A	Post B	Distribution
FTOC	AOV	1998	0	67	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	1999	0	67	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2000	0	67	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2001	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2002	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2003	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2004	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2005	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2006	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2007	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2008	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2009	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2010	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2011	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2012	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2013	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2014	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2015	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2016	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2017	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2018	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2019	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2020	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2021	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOC	AOV	2022	0	68	5.34E-04	0.83	1.56E+03	Beta
FTOP	AOV	1998	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	1999	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2000	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2001	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2002	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2003	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2004	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2005	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2006	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2007	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2008	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2009	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2010	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2011	0	105,120	1.73E-07	1.26	7.28E+06	Gamma

Table 6. (continued).

Failure Mode	Component	Year	Number of Failures	Demands/Run Hours	Bayesian Update			
					Mean	Post A	Post B	Distribution
FTOP	AOV	2012	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2013	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2014	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2015	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2016	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2017	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2018	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2019	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2020	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2021	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
FTOP	AOV	2022	0	105,120	1.73E-07	1.26	7.28E+06	Gamma
SO	AOV	1998	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	1999	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2000	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2001	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2002	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2003	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2004	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2005	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2006	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2007	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2008	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2009	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2010	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2011	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2012	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2013	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2014	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2015	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2016	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2017	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2018	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2019	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2020	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2021	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
SO	AOV	2022	0	105,120	5.80E-08	0.86	1.48E+07	Gamma
FTOC	MOV	1998	5	2,112	1.26E-03	7.43	5.91E+03	Beta
FTOC	MOV	1999	1	1,968	5.94E-04	3.43	5.77E+03	Beta
FTOC	MOV	2000	1	2,019	5.89E-04	3.43	5.82E+03	Beta
FTOC	MOV	2001	4	1,995	1.11E-03	6.43	5.79E+03	Beta

Table 6. (continued).

Failure Mode	Component	Year	Number of Failures	Demands/Run Hours	Bayesian Update			
					Mean	Post A	Post B	Distribution
FTOC	MOV	2002	1	1,947	5.97E-04	3.43	5.75E+03	Beta
FTOC	MOV	2003	1	2,102	5.81E-04	3.43	5.90E+03	Beta
FTOC	MOV	2004	2	1,988	7.65E-04	4.43	5.79E+03	Beta
FTOC	MOV	2005	4	2,000	1.11E-03	6.43	5.80E+03	Beta
FTOC	MOV	2006	1	2,012	5.90E-04	3.43	5.81E+03	Beta
FTOC	MOV	2007	8	2,047	1.78E-03	10.43	5.84E+03	Beta
FTOC	MOV	2008	4	2,036	1.10E-03	6.43	5.83E+03	Beta
FTOC	MOV	2009	4	2,048	1.10E-03	6.43	5.84E+03	Beta
FTOC	MOV	2010	1	2,016	5.89E-04	3.43	5.82E+03	Beta
FTOC	MOV	2011	0	1,963	4.21E-04	2.43	5.76E+03	Beta
FTOC	MOV	2012	3	1,988	9.38E-04	5.43	5.79E+03	Beta
FTOC	MOV	2013	1	1,992	5.92E-04	3.43	5.79E+03	Beta
FTOC	MOV	2014	1	1,954	5.96E-04	3.43	5.75E+03	Beta
FTOC	MOV	2015	1	1,936	5.98E-04	3.43	5.74E+03	Beta
FTOC	MOV	2016	1	1,981	5.93E-04	3.43	5.78E+03	Beta
FTOC	MOV	2017	1	1,992	5.92E-04	3.43	5.79E+03	Beta
FTOC	MOV	2018	0	1,917	4.25E-04	2.43	5.72E+03	Beta
FTOC	MOV	2019	0	1,986	4.20E-04	2.43	5.79E+03	Beta
FTOC	MOV	2020	0	1,942	4.23E-04	2.43	5.74E+03	Beta
FTOC	MOV	2021	0	2,035	4.16E-04	2.43	5.84E+03	Beta
FTOC	MOV	2022	0	1,988	4.20E-04	2.43	5.79E+03	Beta
FTOP	MOV	1998	0	2,146,200	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	1999	0	2,137,440	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2000	0	2,137,440	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2001	0	2,137,440	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2002	0	2,137,440	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2003	0	2,137,440	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2004	0	2,146,200	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2005	0	2,146,200	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2006	0	2,146,200	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2007	1	2,146,200	7.15E-08	1.8	2.51E+07	Gamma
FTOP	MOV	2008	0	2,146,200	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2009	0	2,163,720	3.17E-08	0.8	2.52E+07	Gamma
FTOP	MOV	2010	0	2,216,280	3.16E-08	0.8	2.52E+07	Gamma
FTOP	MOV	2011	0	2,154,960	3.17E-08	0.8	2.52E+07	Gamma
FTOP	MOV	2012	0	2,198,760	3.17E-08	0.8	2.52E+07	Gamma
FTOP	MOV	2013	1	2,154,960	7.15E-08	1.8	2.52E+07	Gamma
FTOP	MOV	2014	0	2,154,960	3.17E-08	0.8	2.52E+07	Gamma
FTOP	MOV	2015	1	2,172,480	7.14E-08	1.8	2.52E+07	Gamma
FTOP	MOV	2016	0	2,137,440	3.17E-08	0.8	2.51E+07	Gamma

Table 6. (continued).

Failure Mode	Component	Year	Number of Failures	Demands/Run Hours	Bayesian Update			
					Mean	Post A	Post B	Distribution
FTOP	MOV	2017	0	2,137,440	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2018	0	2,286,360	3.16E-08	0.8	2.53E+07	Gamma
FTOP	MOV	2019	0	2,137,440	3.17E-08	0.8	2.51E+07	Gamma
FTOP	MOV	2020	0	2,154,960	3.17E-08	0.8	2.52E+07	Gamma
FTOP	MOV	2021	1	2,137,440	7.15E-08	1.8	2.51E+07	Gamma
FTOP	MOV	2022	0	2,154,960	3.17E-08	0.8	2.52E+07	Gamma
SO	MOV	1998	0	2,146,200	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	1999	0	2,137,440	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2000	1	2,137,440	2.60E-08	42.5	1.63E+09	Gamma
SO	MOV	2001	0	2,137,440	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2002	0	2,137,440	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2003	1	2,137,440	2.60E-08	42.5	1.63E+09	Gamma
SO	MOV	2004	0	2,146,200	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2005	0	2,146,200	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2006	0	2,146,200	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2007	1	2,146,200	2.60E-08	42.5	1.63E+09	Gamma
SO	MOV	2008	0	2,146,200	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2009	0	2,163,720	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2010	1	2,216,280	2.60E-08	42.5	1.63E+09	Gamma
SO	MOV	2011	0	2,154,960	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2012	0	2,198,760	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2013	0	2,154,960	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2014	1	2,154,960	2.60E-08	42.5	1.63E+09	Gamma
SO	MOV	2015	0	2,172,480	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2016	0	2,137,440	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2017	0	2,137,440	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2018	0	2,286,360	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2019	0	2,137,440	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2020	0	2,154,960	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2021	0	2,137,440	2.54E-08	41.5	1.63E+09	Gamma
SO	MOV	2022	1	2,154,960	2.60E-08	42.5	1.63E+09	Gamma
FTR>1H	TDP	1998	0	37	4.13E-03	0.44	1.07E+02	Gamma
FTR>1H	TDP	1999	0	52	3.62E-03	0.44	1.22E+02	Gamma
FTR>1H	TDP	2000	1	35	1.38E-02	1.44	1.04E+02	Gamma
FTR>1H	TDP	2001	0	38	4.11E-03	0.44	1.07E+02	Gamma
FTR>1H	TDP	2002	0	23	4.78E-03	0.44	9.22E+01	Gamma
FTR>1H	TDP	2003	0	23	4.77E-03	0.44	9.24E+01	Gamma
FTR>1H	TDP	2004	1	32	1.42E-02	1.44	1.01E+02	Gamma
FTR>1H	TDP	2005	0	25	4.67E-03	0.44	9.44E+01	Gamma
FTR>1H	TDP	2006	0	18	5.03E-03	0.44	8.77E+01	Gamma

Table 6. (continued).

Failure Mode	Component	Year	Number of Failures	Demands/Run Hours	Bayesian Update			
					Mean	Post A	Post B	Distribution
FTR>1H	TDP	2007	0	18	5.02E-03	0.44	8.78E+01	Gamma
FTR>1H	TDP	2008	1	22	1.57E-02	1.44	9.17E+01	Gamma
FTR>1H	TDP	2009	0	116	2.37E-03	0.44	1.86E+02	Gamma
FTR>1H	TDP	2010	1	57	1.14E-02	1.44	1.27E+02	Gamma
FTR>1H	TDP	2011	2	28	2.49E-02	2.44	9.80E+01	Gamma
FTR>1H	TDP	2012	0	19	4.98E-03	0.44	8.86E+01	Gamma
FTR>1H	TDP	2013	1	33	1.41E-02	1.44	1.02E+02	Gamma
FTR>1H	TDP	2014	0	19	4.98E-03	0.44	8.86E+01	Gamma
FTR>1H	TDP	2015	0	22	4.80E-03	0.44	9.20E+01	Gamma
FTR>1H	TDP	2016	1	30	1.44E-02	1.44	9.98E+01	Gamma
FTR>1H	TDP	2017	0	18	5.06E-03	0.44	8.71E+01	Gamma
FTR>1H	TDP	2018	0	18	5.04E-03	0.44	8.76E+01	Gamma
FTR>1H	TDP	2019	0	22	4.83E-03	0.44	9.13E+01	Gamma
FTR>1H	TDP	2020	0	18	5.03E-03	0.44	8.76E+01	Gamma
FTR>1H	TDP	2021	0	21	4.87E-03	0.44	9.05E+01	Gamma
FTR>1H	TDP	2022	0	24	4.70E-03	0.44	9.38E+01	Gamma
FTR<1H	TDP	1998	0	219	1.13E-03	0.44	3.92E+02	Gamma
FTR<1H	TDP	1999	0	211	1.16E-03	0.44	3.84E+02	Gamma
FTR<1H	TDP	2000	1	201	3.86E-03	1.44	3.74E+02	Gamma
FTR<1H	TDP	2001	0	190	1.22E-03	0.44	3.63E+02	Gamma
FTR<1H	TDP	2002	0	187	1.23E-03	0.44	3.60E+02	Gamma
FTR<1H	TDP	2003	2	192	6.69E-03	2.44	3.65E+02	Gamma
FTR<1H	TDP	2004	0	189	1.23E-03	0.44	3.62E+02	Gamma
FTR<1H	TDP	2005	0	194	1.21E-03	0.44	3.67E+02	Gamma
FTR<1H	TDP	2006	0	205	1.18E-03	0.44	3.78E+02	Gamma
FTR<1H	TDP	2007	3	199	9.27E-03	3.44	3.72E+02	Gamma
FTR<1H	TDP	2008	1	196	3.91E-03	1.44	3.69E+02	Gamma
FTR<1H	TDP	2009	1	198	3.90E-03	1.44	3.71E+02	Gamma
FTR<1H	TDP	2010	0	195	1.21E-03	0.44	3.68E+02	Gamma
FTR<1H	TDP	2011	0	196	1.20E-03	0.44	3.69E+02	Gamma
FTR<1H	TDP	2012	0	190	1.22E-03	0.44	3.63E+02	Gamma
FTR<1H	TDP	2013	0	186	1.24E-03	0.44	3.59E+02	Gamma
FTR<1H	TDP	2014	0	175	1.27E-03	0.44	3.48E+02	Gamma
FTR<1H	TDP	2015	1	177	4.12E-03	1.44	3.50E+02	Gamma
FTR<1H	TDP	2016	2	193	6.67E-03	2.44	3.66E+02	Gamma
FTR<1H	TDP	2017	0	182	1.25E-03	0.44	3.55E+02	Gamma
FTR<1H	TDP	2018	0	176	1.27E-03	0.44	3.49E+02	Gamma
FTR<1H	TDP	2019	0	178	1.26E-03	0.44	3.51E+02	Gamma
FTR<1H	TDP	2020	0	165	1.31E-03	0.44	3.38E+02	Gamma
FTR<1H	TDP	2021	1	180	4.09E-03	1.44	3.53E+02	Gamma

Table 6. (continued).

Failure Mode	Component	Year	Number of Failures	Demands/Run Hours	Bayesian Update			
					Mean	Post A	Post B	Distribution
FTR<1H	TDP	2022	1	176	4.13E-03	1.44	3.49E+02	Gamma
FTS	TDP	1998	0	219	2.77E-03	1.26	4.54E+02	Beta
FTS	TDP	1999	3	211	9.52E-03	4.26	4.43E+02	Beta
FTS	TDP	2000	3	201	9.74E-03	4.26	4.33E+02	Beta
FTS	TDP	2001	1	190	5.31E-03	2.26	4.24E+02	Beta
FTS	TDP	2002	2	187	7.71E-03	3.26	4.20E+02	Beta
FTS	TDP	2003	1	192	5.27E-03	2.26	4.26E+02	Beta
FTS	TDP	2004	1	189	5.32E-03	2.26	4.23E+02	Beta
FTS	TDP	2005	2	194	7.58E-03	3.26	4.27E+02	Beta
FTS	TDP	2006	2	205	7.39E-03	3.26	4.38E+02	Beta
FTS	TDP	2007	2	199	7.50E-03	3.26	4.32E+02	Beta
FTS	TDP	2008	2	196	7.53E-03	3.26	4.29E+02	Beta
FTS	TDP	2009	4	198	1.21E-02	5.26	4.29E+02	Beta
FTS	TDP	2010	2	195	7.56E-03	3.26	4.28E+02	Beta
FTS	TDP	2011	4	196	1.22E-02	5.26	4.27E+02	Beta
FTS	TDP	2012	1	190	5.30E-03	2.26	4.24E+02	Beta
FTS	TDP	2013	3	186	1.01E-02	4.26	4.18E+02	Beta
FTS	TDP	2014	0	175	3.06E-03	1.26	4.10E+02	Beta
FTS	TDP	2015	0	177	3.05E-03	1.26	4.12E+02	Beta
FTS	TDP	2016	4	193	1.22E-02	5.26	4.24E+02	Beta
FTS	TDP	2017	1	182	5.40E-03	2.26	4.16E+02	Beta
FTS	TDP	2018	1	176	5.48E-03	2.26	4.10E+02	Beta
FTS	TDP	2019	4	178	1.27E-02	5.26	4.09E+02	Beta
FTS	TDP	2020	1	165	5.63E-03	2.26	3.99E+02	Beta
FTS	TDP	2021	1	180	5.42E-03	2.26	4.14E+02	Beta
FTS	TDP	2022	1	176	5.48E-03	2.26	4.10E+02	Beta

Table 7. Basic event unavailability (UA) trending data.

Failure Mode	Component	Year	UA Hours	Critical Hours	Bayesian Update			
					Mean	Post A	Post B	Distribution
UA	TDP	1998	2417.366	182,188	1.42E-02	1.72	1.20E+02	Beta
UA	TDP	1999	2263.647	195,033	1.16E-02	2.4	2.05E+02	Beta
UA	TDP	2000	2046.777	196,240	1.04E-02	1.56	1.48E+02	Beta
UA	TDP	2001	1735.021	195,742	9.03E-03	0.96	1.05E+02	Beta
UA	TDP	2002	2403.082	199,989	1.21E-02	1.39	1.13E+02	Beta
UA	TDP	2003	2378.24	194,267	1.23E-02	1.76	1.41E+02	Beta
UA	TDP	2004	2239.69	196,465	1.16E-02	1.12	9.51E+01	Beta
UA	TDP	2005	1626.882	195,610	8.34E-03	2.12	2.52E+02	Beta
UA	TDP	2006	1534.99	197,941	7.81E-03	1.91	2.43E+02	Beta
UA	TDP	2007	2758.37	196,293	1.42E-02	1.24	8.64E+01	Beta
UA	TDP	2008	2718.49	199,399	1.36E-02	0.58	4.22E+01	Beta
UA	TDP	2009	2341.58	193,544	1.20E-02	1.74	1.43E+02	Beta
UA	TDP	2010	2263.44	197,083	1.14E-02	2.5	2.16E+02	Beta
UA	TDP	2011	2681.81	192,786	1.40E-02	2.3	1.62E+02	Beta
UA	TDP	2012	2631.7	192,525	1.35E-02	2.04	1.48E+02	Beta
UA	TDP	2013	1924.92	193,672	1.00E-02	1.78	1.76E+02	Beta
UA	TDP	2014	2197.6	196,708	1.12E-02	2.12	1.87E+02	Beta
UA	TDP	2015	2234.37	189,557	1.16E-02	2.89	2.45E+02	Beta
UA	TDP	2016	2416.35	192,415	1.25E-02	2.84	2.25E+02	Beta
UA	TDP	2017	2500.21	192,345	1.31E-02	2.04	1.54E+02	Beta
UA	TDP	2018	1475.42	188,839	7.86E-03	1.36	1.71E+02	Beta
UA	TDP	2019	1561.93	186,027	8.41E-03	2.4	2.82E+02	Beta
UA	TDP	2020	888.49	178,748	4.91E-03	2.18	4.42E+02	Beta
UA	TDP	2021	1645.59	176,105	9.32E-03	1.36	1.44E+02	Beta
UA	TDP	2022	1763.31	173,355	1.03E-02	1.32	1.27E+02	Beta

Table 8. Failure mode acronyms.

Failure Mode	Failure Mode Description
FTOC	Fail to open/close
FTOP	Fail to operate
FTR>1H	Fail to run more than 1 hour (standby equipment)
FTR<1H	Fail to run less than 1 hour (after start; standby equipment)
FTS	Fail to start
SO	Spurious operation
UA	Unavailability (maintenance or state of another component)

## 7. SYSTEM DESCRIPTION

The HPCI system is a single-train system that provides a reliable source of high-pressure coolant for cases where there is a loss of normal core coolant inventory. Figure 4 provides a simplified schematic diagram of the system.

The HPCI system consists of a steam turbine-driven pump, valves, and valve operators and associated piping, including that from the normal and alternate pump suction sources and the pump discharge up to the penetration of the main feedwater line. For this study, the part of the main feedwater line from the check valve upstream of the HPCI connection to the reactor vessel, including the check valve, was considered part of the HPCI system. The steam turbine-driven pump includes all steam piping from the main steam line penetration to the turbine and turbine exhaust piping to the suppression pool, valves and valve operators, gland sealing steam, and the turbine auxiliary oil system.

The HPCI system is actuated by either a low reactor water level or a high dry-well pressure. Initially, the system operates in an open loop mode, taking suction from the condensate storage tank (CST) and injecting water into the reactor pressure vessel (RPV) via one of the main feedwater lines. When the level in the CST reaches a low-level set point, the HPCI pump suction is aligned to the suppression pool. To maintain the RPV level after the initial recovery, the HPCI system is placed in manual control, which may involve controlling turbine speed, diverting flow through minimum-flow or test lines, cycling the injection motor-operated valve (MOV), or completing stop-start cycles.

The HPCI system is also manually used to help control RPV pressure following a transient. Although this is not part of the ECCS design function, it is employed in this manner in PRAs. However, only a small percentage of PRAs that employ this function model the pressure control operation. In this mode, the turbine-driven pump is operated manually with the injection valve closed and the full-flow test-line MOV open. The turbine operation with the injection line isolated and the test-line open allows the turbine to draw steam from the RPV, thereby reducing RPV pressure. Operating the system in the pressure control mode may also occur with intermittent injection of coolant to the RPV. As steam is being drawn off the RPV, the RPV water inventory is reduced, resulting in the need for vessel water level restoration. When level restoration is required, the injection valve is opened, and the test-line MOV is closed. Upon restoration of RPV water inventory, the system is returned to the pressure control line-up. This cycling between injection and pressure control can be repeated as necessary.




Figure 4. HPCI system diagram.

## **8. REFERENCES**

1. Z. Ma, T. E. Wierman, and K. J. Kvarfordt. 2021. “Industry-Average Performance for Components and Initiating Events at U.S. Commercial Nuclear Power Plants: 2020 Update,” INL/EXT-21-65055, Idaho National Laboratory.
2. S. A. Eide, T. E. Wierman, C. D. Gentillon, D. M. Rasmuson, and C. L. Atwood. 2007. “Industry-Average Performance for Components and Initiating Events at U.S. Commercial Nuclear Power Plants,” NUREG/CR-6928, U.S. Nuclear Regulatory Commission.
3. Z. Ma and K. J. Kvarfordt. 2022. “CCF Parameter Estimations, 2020 Update,” INL/EXT-21-62940, Revision 1, Idaho National Laboratory.
4. United States Nuclear Regulatory Commission. 2010. “Component Reliability Data Sheets Update 2010,” online. Available: <https://nrcoe.inl.gov/resultsdb/publicdocs/AvgPerf/ComponentUR2010.pdf>.
5. C. D. Gentillion. 2016. “Overview and Reference Document for Operational Experience Results and Databases Trending,”online. Available: <https://nrcoe.inl.gov/resultsdb/publicdocs/Overview-and-Reference.pdf>.