

Reliability Study Update

Reactor Core Isolation Cooling

1987–2002

This report presents a performance evaluation of the reactor core isolation cooling (RCIC) system at 30 U.S. commercial boiling water reactors (BWRs). The evaluation is based on the operating experience from 1987 through 2002, as reported in Licensee Event Reports (LERs). This is the latest update to NUREG/CR 5500 Volume 7.

This report calculates two basic models for the RCIC system. The FTS model includes the start and recovery of the pump and the initial opening of the injection valve. The 8-hour mission model includes the RCIC system start and operation for 8 hours. Restart of the RCIC turbine, multiple injections, transfer from recirculation to injection, and recovery actions are included. Both models include failures due to the unavailability while in maintenance. See the RCIC Fault Tree Description document for more detail.

1 LATEST VALUES AND TRENDS

1.1 Industry-Wide Unavailability and Unreliability

The industry-wide unavailability and unreliability of the RCIC system have been estimated from operating experience. A failure to start (FTS) model and an 8-hour mission model were evaluated for each of these models, see [Table 1](#). The estimates are based on failures that occurred during unplanned demands, and cyclic and quarterly surveillance tests.

Table 1. Industry-wide values.

Model	Lower (5%)	Mean	Upper (95%)
Failure-to-Start (Unavailability)	6.21E-03	1.93E-02	3.81E-02
8-hour Mission (Unreliability)	2.39E-02	6.11E-02	1.11E-01

1.2 Fail to Start Model Results

Individual plant result unavailability has been calculated for the FTS model. The estimates of RCIC system unavailability using operating experience from LERs and fault tree analyses are plotted in [Figure 1](#) (FTS model). [Table 2](#) shows the data points for [Figure 1](#).





Figure 1. Plant-specific estimates of RCIC system unavailability for FTS model.

Table 2. RCIC plant unavailability FTS model.

Plant	Lower (5%)	Mean	Upper (95%)
Industry	6.21E-03	1.93E-02	3.81E-02
Grand Gulf	4.72E-03	1.58E-02	3.21E-02
Fitzpatrick	4.83E-03	1.61E-02	3.25E-02
Brunswick 2	4.83E-03	1.61E-02	3.25E-02
Columbia	4.84E-03	1.61E-02	3.26E-02
Nuclear 2			
Fermi 2	4.87E-03	1.62E-02	3.27E-02
Duane Arnold	4.87E-03	1.62E-02	3.27E-02
Susquehanna 2	4.91E-03	1.63E-02	3.29E-02
Susquehanna 1	4.91E-03	1.63E-02	3.29E-02
Peach Bottom 3	4.91E-03	1.63E-02	3.29E-02
Peach Bottom 2	4.91E-03	1.63E-02	3.29E-02
Limerick 1	4.91E-03	1.63E-02	3.29E-02
Clinton 1	4.91E-03	1.63E-02	3.29E-02
Monticello	4.93E-03	1.63E-02	3.30E-02
Limerick 2	5.03E-03	1.66E-02	3.34E-02

Plant	Lower (5%)	Mean	Upper (95%)
Browns Ferry 3	5.33E-03	1.74E-02	3.49E-02
Hatch 2	7.05E-03	1.94E-02	3.67E-02
Hatch 1	7.09E-03	1.95E-02	3.69E-02
Perry	7.10E-03	1.96E-02	3.70E-02
Cooper	7.16E-03	1.98E-02	3.73E-02
Hope Creek	7.21E-03	1.99E-02	3.76E-02
La Salle 2	7.24E-03	2.00E-02	3.78E-02
Brunswick 1	7.24E-03	2.00E-02	3.78E-02
River Bend	7.26E-03	2.00E-02	3.79E-02
Quad Cities 1	7.32E-03	2.02E-02	3.83E-02
Browns Ferry 2	7.50E-03	2.09E-02	3.96E-02
Nine Mile Pt. 2	9.13E-03	2.37E-02	4.38E-02
Quad Cities 2	9.17E-03	2.40E-02	4.44E-02
Vermont Yankee	9.18E-03	2.41E-02	4.45E-02
Pilgrim	1.07E-02	2.77E-02	5.10E-02
La Salle 1	1.30E-02	3.57E-02	6.73E-02

A statistically significant¹ decreasing trend within the industry estimates of RCIC system unavailability (FTS) on a per fiscal year basis was identified. [Figure 2](#) shows the trend in the FTS model unavailability. [Table 7](#) shows the data points for [Figure 2](#).

**Figure 2. Trend of RCIC system unavailability (FTS model), as a function of fiscal year.**

¹ The term “statistically significant” means that the data are too closely correlated to be attributed to chance and consequently have a systematic relationship. A p-value of less than 0.05 is generally considered statistically significant.

The leading contributor to RCIC system short-term unavailability, after the maintenance out of service, is the failure of the turbine to start. [Figure 3](#) shows the distribution of segment failure contributions for the FTS model.




Figure 3. Segment failure distribution, FTS model.

1.3 Fail to Operate for 8-Hour Model

Individual plant result unreliability has been calculated for the 8-hour mission. The estimates of RCIC system unreliability using operating experience from LERs and fault tree analyses are plotted in [Figure 4](#) (8-hour mission model). [Table 3](#) shows the data points used in [Figure 4](#).





Figure 4. Plant-specific estimates of RCIC system unreliability for an 8-hour mission.

Table 3. RCIC plant unreliability data.

Plant	Lower (5%)	Mean	Upper (95%)	Plant	Lower (5%)	Mean	Upper (95%)
Industry	2.39E-02	6.11E-02	1.11E-01	Clinton 1	2.16E-02	5.86E-02	1.09E-01
La Salle 1	3.26E-02	7.42E-02	1.28E-01	Brunswick 2	2.14E-02	5.80E-02	1.08E-01
Vermont Yankee	2.93E-02	7.00E-02	1.24E-01	Grand Gulf	2.15E-02	5.74E-02	1.06E-01
Pilgrim	2.99E-02	6.96E-02	1.21E-01	Susquehanna 1	2.08E-02	5.72E-02	1.07E-01
Duane Arnold	2.67E-02	6.90E-02	1.26E-01	Brunswick 1	2.21E-02	5.70E-02	1.04E-01
Quad Cities 2	2.53E-02	6.27E-02	1.13E-01	Hatch 2	2.20E-02	5.65E-02	1.03E-01
Nine Mile Pt. 2	2.55E-02	6.20E-02	1.10E-01	Monticello	1.98E-02	5.55E-02	1.05E-01
Hatch 1	2.53E-02	6.19E-02	1.11E-01	Peach Bottom 2	1.96E-02	5.53E-02	1.05E-01
Columbia Nuclear 2	2.42E-02	6.17E-02	1.12E-01	Peach Bottom 3	1.96E-02	5.53E-02	1.05E-01
Cooper	2.41E-02	6.08E-02	1.10E-01	La Salle 2	2.11E-02	5.53E-02	1.02E-01
Limerick 1	2.20E-02	6.03E-02	1.13E-01	Perry	2.09E-02	5.51E-02	1.01E-01
Browns Ferry 2	2.34E-02	6.02E-02	1.10E-01	Susquehanna 2	1.88E-02	5.32E-02	1.01E-01
Quad Cities 1	2.30E-02	5.96E-02	1.09E-01	Fermi 2	1.83E-02	5.24E-02	9.99E-02
Hope Creek	2.28E-02	5.92E-02	1.08E-01	Limerick 2	1.83E-02	5.21E-02	9.89E-02
River Bend	2.23E-02	5.86E-02	1.08E-01	Browns Ferry 3	1.82E-02	5.15E-02	9.78E-02
				Fitzpatrick	1.76E-02	5.06E-02	9.65E-02

No statistically significant trend within the industry estimates of RCIC system unreliability (8-hour mission) on a per fiscal year basis was identified. [Figure 5](#) displays the trend by fiscal year of the RCIC system unreliability calculated from the 1987–2002 experience. [Table 8](#) shows the data points for [Figure 5](#).

**Figure 5. Trend of RCIC system unreliability (8-hour mission), as a function of fiscal year.**

The leading segment failure contributor to the RCIC system unreliability, after the maintenance out of service, is the failure to run of the pump and turbine. [Figure 6](#) shows the distribution of segment failures for the 8-hour mission.




Figure 6. Segment failure distribution, 8-hour mission.

2 DATA TRENDS

The raw actuation and failure data were trended for event counts over time.

2.1 Unplanned Demand Trend

Trends were identified in the frequency of RCIC unplanned demands (Figure 7). When modeled as a function of fiscal year, the unplanned demand frequency exhibited a highly statistically significant decreasing trend. Table 9 shows the LERs that are represented in the figure.




Figure 7. Frequency (events per operating year) of unplanned demands, as a function of fiscal year.

2.2 Failure Trend

The frequency of all failures (unplanned demands, surveillance tests, inspections, etc.) resulting in train unavailability identified in the experience was analyzed to determine trends. When modeled as a function of fiscal year, a highly statistically significant decreasing trend was identified. The fitted frequency is plotted against fiscal year in Figure 8. Trends for RCIC failures are plotted without regard to method of detection (the trend excludes maintenance out of service and support system failures). Table 10 shows the LERs that are represented in the figure.




Figure 8. Frequency (events per operating year) of failures, as a function of fiscal year.

2.3 Failure Cause and Discovery Method Summary

The raw failure data were sliced to show the distribution of the failure causes and the discovery methods by the affected segment.

2.3.1 Leading Segment Failures.

The steam supply (35%) and the turbine and turbine control (28%) were the leading segment failures identified in the database. See [Table 4](#).

2.3.2 Leading Discovery Methods

Periodic surveillance (26%) and unplanned demand (20%) were the leading methods of discovery. See [Table 4](#).

2.3.3 Leading Causes of Failure.

Seventy five percent of the failures of the RCIC system observed in the experience were attributed to hardware-related problems. Personnel errors caused 15% of all RCIC system failures. However, 50% of these failures were immediately identified, meaning that the failures were of the nature where plant personnel were able to respond to the failures immediately after they occurred. See [Table 6](#)

Table 4. Comparison of failed segment with the method of discovery.²

Segment	Actual/unplanned demand	Alarm/indicator	I&C functional test	Inspection/review	Other (not counted) surveillance test	Periodic surveillance on system	Post-maintenance testing	Unscheduled TS required surveillance	Total	Percent
Electrical	1	2					1		4	4%
HVAC				1					1	1%
I&C	2		2	2		1			7	8%
Injection (Discharge)	5			1		3	1	1	11	12%
Injection (Suction)						1			1	1%
Lube Oil						3		1	4	4%
Service Water		1							1	1%
Steam Supply	4	5	3	5	1	2	7	5	32	35%
Turbine & Turbine Control	4			4		11	5	2	26	28%
Turbine Exhausts & drains	2					3			5	5%
Total	18	8	5	13	1	24	14	9	92	100%
	20%	9%	5%	14%	1%	26%	15%	10%	100%	

Table 5. Discovery method description.

Discovery Method	Description	Used in the Failure Calculations
Actual/unplanned demand	The demand for the system was ESF, inadvertent. If the demand was inadvertent, the demand should mimic an ESF demand.	✓
Design review	Because of a design review, a deficiency was noted in the system.	

² The discovery method is the activity that is ongoing at the time of the failure.

Discovery Method	Description	Used in the Failure Calculations
Periodic surveillance on subject system	Normally scheduled surveillance. These surveillances are to satisfy scheduled Technical Specification requirements.	✓
Maintenance on subject system	The failed condition was discovered during maintenance on the system. These include latent failures as well as maintenance-induced failures.	
Inspection/review	The failure was discovered during operator duties such as walk downs, inspections, etc.	
Alarm/indicator	The failure was evidenced by an alarm or by other indications.	
I&C functional test	The failure was discovered during testing of the instrumentation and control system for the subject system or another system.	
Post-maintenance testing	Failed condition was discovered during post-maintenance testing. The technical specification surveillance tests can be used for this testing, but cannot be counted.	
Unscheduled TS required surveillance	Failed condition was discovered during technical specification required testing. Tests are performed to show system operability per the technical specifications and are not scheduled. The technical specification surveillance tests can be used for this testing, but cannot be counted.	
Other (not counted) surveillance test	All others discovered by testing.	

Table 6. Comparison of failed segment and failure cause.³

Segment	Contamination	Design	Hardware	Personnel	Procedure	Total	Percent
Electrical		1	3			4	4%
HVAC			1			1	1%
I&C			3	4		7	8%
Injection (Discharge)		1	8	1	1	11	12%
Injection (Suction)					1	1	1%
Lube Oil	1	1		2		4	4%
Service Water			1			1	1%
Steam Supply			31	1		32	35%
Turbine & Turbine Control			20	5	1	26	28%
Turbine Exhausts & drains	1	1	2	1		5	5%
Total	2	4	69	14	3	92	100%
	2%	4%	75%	15%	3%	100%	

- Contamination—The failure was the result of foreign material affecting the component.
- Design—The failure was the result of a flawed design.
- Hardware—The failure was the result of some aspect of the equipment. Typically, this is used for normal wear of the component.
- Personnel—The failure was the result of personnel error, by either commission or omission.
- Procedure—The failure was the result of an incorrect procedure.

³ The cause of the failure is assigned to a broadly defined cause classification. The cause classifications are design, environment, hardware (e.g., aging, wear, manufacturing defects), personnel, and procedure. The cause classification assigned is based on the immediate cause of the failure and not the root cause. Generally, root cause is only determined through a detailed investigation and analysis of the failure. Specifically, the mechanism that actually resulted in the failure of the segment or component is captured as the cause.

3 DATA TABLES

3.1 Data Tables for Unreliability and Unavailability Trends

Table 7. Plot data table for RCIC system unavailability, FTS model. [Figure 5](#)

Fiscal Year	Plot Trend Error Bar Points			Regression Curve Data Points		
	Lower (5%)	Mean	Upper (95%)	Lower (5%)	Mean	Upper (95%)
1987	6.60E-03	2.32E-02	4.77E-02	1.76E-02	2.47E-02	3.18E-02
1988	1.20E-02	3.21E-02	5.99E-02	1.74E-02	2.39E-02	3.04E-02
1989	4.25E-04	1.06E-02	3.27E-02	1.73E-02	2.31E-02	2.89E-02
1990	7.72E-03	3.19E-02	6.89E-02	1.71E-02	2.23E-02	2.76E-02
1991	2.20E-03	1.53E-02	3.80E-02	1.69E-02	2.16E-02	2.63E-02
1992	6.39E-03	2.39E-02	5.01E-02	1.65E-02	2.08E-02	2.50E-02
1993	3.88E-04	1.10E-02	3.46E-02	1.61E-02	2.00E-02	2.39E-02
1994	4.98E-03	2.29E-02	5.11E-02	1.54E-02	1.92E-02	2.30E-02
1995	4.92E-03	2.12E-02	4.64E-02	1.47E-02	1.84E-02	2.22E-02
1996	4.85E-03	2.22E-02	4.96E-02	1.37E-02	1.76E-02	2.16E-02
1997	2.03E-03	1.73E-02	4.48E-02	1.26E-02	1.69E-02	2.11E-02
1998	3.75E-04	1.11E-02	3.50E-02	1.14E-02	1.61E-02	2.08E-02
1999	4.85E-03	2.24E-02	5.01E-02	1.01E-02	1.53E-02	2.05E-02
2000	9.53E-04	1.34E-02	3.80E-02	8.68E-03	1.45E-02	2.03E-02
2001	3.87E-04	1.09E-02	3.42E-02	7.25E-03	1.37E-02	2.02E-02
2002	3.44E-04	1.17E-02	3.75E-02	5.79E-03	1.29E-02	2.01E-02

Table 8. Plot data table for RCIC system unreliability, 8-hour mission. [Figure 2](#)

Fiscal Year	Plot Trend Error Bar Points			Regression Curve Data Points		
	Lower (5%)	Mean	Upper (95%)	Lower (5%)	Mean	Upper (95%)
1987	4.78E-03	5.13E-02	1.37E-01	4.70E-02	5.79E-02	6.87E-02
1988	1.06E-02	6.13E-02	1.44E-01	4.74E-02	5.73E-02	6.71E-02
1989	2.52E-03	4.03E-02	1.15E-01	4.78E-02	5.67E-02	6.55E-02
1990	1.60E-02	7.26E-02	1.59E-01	4.81E-02	5.61E-02	6.40E-02
1991	1.03E-02	5.61E-02	1.30E-01	4.83E-02	5.55E-02	6.26E-02
1992	6.58E-03	5.35E-02	1.36E-01	4.84E-02	5.49E-02	6.14E-02
1993	6.80E-03	5.12E-02	1.28E-01	4.83E-02	5.43E-02	6.03E-02
1994	8.20E-03	6.50E-02	1.63E-01	4.80E-02	5.37E-02	5.95E-02
1995	7.25E-03	6.07E-02	1.54E-01	4.74E-02	5.31E-02	5.89E-02
1996	3.34E-03	5.02E-02	1.42E-01	4.66E-02	5.25E-02	5.85E-02
1997	8.48E-04	4.31E-02	1.42E-01	4.55E-02	5.20E-02	5.84E-02
1998	4.70E-03	5.95E-02	1.63E-01	4.42E-02	5.14E-02	5.85E-02
1999	5.66E-03	5.36E-02	1.40E-01	4.28E-02	5.08E-02	5.87E-02
2000	5.43E-04	3.85E-02	1.32E-01	4.13E-02	5.02E-02	5.91E-02
2001	1.38E-03	3.82E-02	1.18E-01	3.98E-02	4.96E-02	5.94E-02
2002	1.95E-03	5.97E-02	1.85E-01	3.81E-02	4.90E-02	5.99E-02

3.2 Data Tables for Failure and Demand Trends

Table 9. LER listing for demand trend figure.
Figure 7

FY	Plant	Date	LER
1997	Browns Ferry 2	4/24/1997	2601997001
1996	Browns Ferry 2	5/10/1996	2601996005
2000	Browns Ferry 3	4/15/2000	2962000001
2000	Browns Ferry 3	5/24/2000	2962000005
1996	Browns Ferry 3	4/21/1996	2961996002
1996	Browns Ferry 3	5/1/1996	2961996003
1995	Brunswick 1	7/13/1995	3251995015
1995	Brunswick 1	9/30/1995	3251995018
1992	Brunswick 1	1/17/1992	3251992003
1992	Brunswick 1	2/29/1992	3251992005
1991	Brunswick 1	7/18/1991	3251991018
1987	Brunswick 1	7/1/1987	3251987019
1992	Brunswick 2	2/2/1992	3241992001
1991	Brunswick 2	10/12/1990	3241990016
1991	Brunswick 2	1/25/1991	3241991001
1990	Brunswick 2	8/16/1990	3241990008
1990	Brunswick 2	8/19/1990	3241990009
1990	Brunswick 2	9/27/1990	3241990015
1989	Brunswick 2	11/16/1988	3241988018
1989	Brunswick 2	6/17/1989	3241989009
1987	Brunswick 2	1/5/1987	3241987001
1987	Brunswick 2	3/11/1987	3241987004
2001	Clinton 1	12/18/2000	4612000007
2000	Clinton 1	5/17/2000	4612000001
1989	Clinton 1	7/14/1989	4611989029
1988	Clinton 1	7/12/1988	4611988019
1998	Columbia Nuclear 2	3/11/1998	3971998002
1998	Columbia Nuclear 2	3/11/1998	3971998003
1995	Columbia Nuclear 2	2/18/1995	3971995002
1993	Columbia Nuclear 2	8/3/1993	3971993027
1988	Columbia Nuclear 2	2/4/1988	3971988003
1988	Columbia Nuclear 2	2/13/1988	3971988006
1987	Columbia Nuclear 2	3/22/1987	3971987002
1987	Columbia Nuclear 2	7/2/1987	3971987020
1987	Columbia Nuclear 2	7/6/1987	3971987022
2001	Cooper	3/3/2001	2982001002
1996	Cooper	10/14/1995	2981995012
1994	Cooper	12/14/1993	2981993038

FY	Plant	Date	LER
1994	Cooper	3/2/1994	2981994004
1991	Cooper	10/17/1990	2981990011
1990	Cooper	11/25/1989	2981989026
1988	Cooper	8/25/1988	2981988021
1987	Cooper	1/7/1987	2981987003
1987	Cooper	1/10/1987	2981987006
1987	Cooper	2/18/1987	2981987009
1987	Cooper	5/17/1987	2981987011
2002	Duane Arnold	10/17/2001	3312001006
1991	Duane Arnold	10/19/1990	3311990019
1990	Duane Arnold	3/29/1990	3311990002
1989	Duane Arnold	3/5/1989	3311989008
1989	Duane Arnold	8/26/1989	3311989011
1995	Fermi 2	4/9/1995	3411995004
1993	Fermi 2	11/18/1992	3411992012
1993	Fermi 2	8/13/1993	3411993010
1988	Fermi 2	1/10/1988	3411988004
1987	Fermi 2	5/13/1987	3411987017
1987	Fermi 2	6/25/1987	3411987025
2000	Fitzpatrick	10/14/1999	3331990010
1998	Fitzpatrick	5/1/1998	3331998004
1998	Fitzpatrick	8/3/1998	3331998008
1996	Fitzpatrick	2/22/1996	3331996003
1996	Fitzpatrick	9/16/1996	3331996010
1995	Fitzpatrick	9/5/1995	3331995013
1993	Fitzpatrick	4/20/1993	3331993009
1990	Fitzpatrick	11/5/1989	3331989020
1990	Fitzpatrick	3/19/1990	3331990009
1987	Fitzpatrick	6/10/1987	3331987008
2001	Grand Gulf	8/7/2001	4162001003
2000	Grand Gulf	9/15/2000	4162000005
1999	Grand Gulf	2/21/1999	4161999003
1998	Grand Gulf	1/28/1998	4161998001
1995	Grand Gulf	7/3/1995	4161995007
1995	Grand Gulf	7/12/1995	4161995008
1992	Grand Gulf	6/18/1992	4161992013
1991	Grand Gulf	12/10/1990	4161990028
1991	Grand Gulf	12/18/1990	4161990029
1991	Grand Gulf	6/11/1991	4161991004
1991	Grand Gulf	6/17/1991	4161991005
1991	Grand Gulf	7/28/1991	4161991007
1990	Grand Gulf	11/7/1989	4161989016
1990	Grand Gulf	12/30/1989	4161989019
1990	Grand Gulf	7/24/1990	4161990011
1990	Grand Gulf	9/16/1990	4161990017
1989	Grand Gulf	5/5/1989	4161989006
1989	Grand Gulf	7/22/1989	4161989010
1989	Grand Gulf	8/14/1989	4161989012

FY	Plant	Date	LER
1988	Grand Gulf	1/20/1988	4161988006
2001	Hatch 1	3/28/2001	3212001002
2000	Hatch 1	1/26/2000	3212000002
2000	Hatch 1	9/29/2000	3212000011
1996	Hatch 1	5/26/1996	3211996009
1994	Hatch 1	10/22/1993	3211993013
1994	Hatch 1	12/7/1993	3211993016
1992	Hatch 1	8/27/1992	3211992021
1992	Hatch 1	9/30/1992	3211992024
1991	Hatch 1	10/15/1990	3211990021
1991	Hatch 1	1/18/1991	3211991001
1991	Hatch 1	9/11/1991	3211991017
1990	Hatch 1	6/20/1990	3211990013
1989	Hatch 1	12/17/1988	3211988018
1988	Hatch 1	9/4/1988	3211988013
1987	Hatch 1	7/23/1987	3211987011
1987	Hatch 1	8/3/1987	3211987013
1999	Hatch 2	6/15/1999	3661999006
1999	Hatch 2	6/28/1999	3661999007
1998	Hatch 2	11/20/1997	3661997010
1997	Hatch 2	4/22/1997	3661997007
1995	Hatch 2	4/11/1995	3661995001
1994	Hatch 2	8/30/1994	3661994007
1992	Hatch 2	6/25/1992	3661992009
1991	Hatch 2	2/14/1991	3661991004
1990	Hatch 2	1/12/1990	3661990001
1989	Hatch 2	9/3/1989	3661989005
1988	Hatch 2	3/21/1988	3661988008
1988	Hatch 2	4/17/1988	3661988011
1988	Hatch 2	5/27/1988	3661988017
1988	Hatch 2	8/5/1988	3661988020
1987	Hatch 2	1/26/1987	3661987003
1987	Hatch 2	4/22/1987	3661987008
1987	Hatch 2	7/26/1987	3661987006
1987	Hatch 2	8/3/1987	3661987009
1990	Hope Creek	3/19/1990	3541990003
1989	Hope Creek	10/15/1988	3541988027
1989	Hope Creek	11/1/1988	3541988029
1988	Hope Creek	4/30/1988	3541988012
1987	Hope Creek	2/24/1987	3541987017
1987	Hope Creek	7/30/1987	3541987034
1987	Hope Creek	8/16/1987	3541987037
1987	Hope Creek	8/29/1987	3541987039
1993	La Salle 1	9/14/1993	3731993015
1992	La Salle 1	3/1/1992	3731992003
2001	La Salle 2	4/6/2001	3742001001
2001	La Salle 2	9/3/2001	3742001003
1995	La Salle 2	10/19/1994	3741994008
1995	La Salle 2	12/14/1994	3741994010
1995	La Salle 2	1/12/1995	3741995001
1992	La Salle 2	8/27/1992	3741992012
1999	Limerick 1	4/20/1999	3521999003
1991	Limerick 1	4/12/1991	3521991009

FY	Plant	Date	LER
1987	Limerick 1	9/19/1987	3521987048
1995	Limerick 2	10/19/1994	3531994010
1995	Limerick 2	8/8/1995	3531995008
1995	Limerick 2	8/20/1995	3531995010
1990	Limerick 2	9/10/1990	3531990015
1991	Monticello	8/25/1991	2631991019
1987	Monticello	4/3/1987	2631987009
2000	Nine Mile Pt. 2	3/3/2000	4102000002
1999	Nine Mile Pt. 2	4/24/1999	4101999005
1999	Nine Mile Pt. 2	6/24/1999	4101999010
1992	Nine Mile Pt. 2	12/12/1991	4101991023
1991	Nine Mile Pt. 2	8/13/1991	4101991017
1989	Nine Mile Pt. 2	4/13/1989	4101989014
1988	Nine Mile Pt. 2	1/20/1988	4101988001
1988	Nine Mile Pt. 2	3/5/1988	4101988012
1988	Nine Mile Pt. 2	3/13/1988	4101988014
1992	Peach Bottom 2	7/4/1992	2771992010
1992	Peach Bottom 2	7/17/1992	2771992012
1990	Peach Bottom 2	12/20/1989	2771989033
1993	Peach Bottom 3	10/15/1992	2781992008
1990	Peach Bottom 3	1/28/1990	2781990002
1990	Peach Bottom 3	7/27/1990	2781990008
2001	Perry	4/29/2001	4402001001
2001	Perry	7/11/2001	4402001003
1998	Perry	7/1/1998	4401998002
1997	Perry	1/7/1997	4401997001
1995	Perry	8/31/1995	4401995005
1995	Perry	9/11/1995	4401995008
1993	Perry	3/26/1993	4401993010
1992	Perry	9/10/1992	4401992017
1990	Perry	1/7/1990	4401990002
1988	Perry	10/27/1987	4401987072
1988	Perry	4/27/1988	4401988012
1988	Perry	6/8/1988	4401988023
1987	Perry	3/2/1987	4401987012
1987	Perry	6/17/1987	4401987042
1987	Perry	9/9/1987	4401987064
2001	Pilgrim	4/21/2001	2932001003
1993	Pilgrim	3/13/1993	2931993004
1993	Pilgrim	9/10/1993	2931993022
1992	Pilgrim	10/30/1991	2931991025
1990	Pilgrim	9/2/1990	2931990013
1990	Quad Cities 1	3/10/1990	2541990004
2001	Quad Cities 2	8/2/2001	2652001001
1988	Quad Cities 2	10/19/1987	2651987013
1987	Quad Cities 2	8/1/1987	2651987009
2002	River Bend	9/18/2002	4582002001
1994	River Bend	9/8/1994	4581994023
1989	River Bend	2/25/1989	4581989008
1988	River Bend	8/25/1988	4581988018
1988	River Bend	9/6/1988	4581988021
1999	Susquehanna 1	7/1/1999	3871999003
1991	Susquehanna 1	7/31/1991	3871991008

FY	Plant	Date	LER
1987	Susquehanna 1	4/2/1987	3871987013
1996	Susquehanna 2	7/14/1996	3881996004
1990	Susquehanna 2	5/28/1990	3881990005
1987	Susquehanna 2	4/16/1987	3881987006
1998	Vermont Yankee	6/9/1998	2711998016
1991	Vermont Yankee	4/23/1991	2711991009

**Table 10. LER listing for failure trend figure.
Figure 8**

FY	Plant	Date	LER
1996	Browns Ferry 2	5/10/1996	2601996005
1988	Brunswick 1	9/15/1988	3251988020
1987	Brunswick 2	1/5/1987	3241987001
1990	Brunswick 2	8/19/1990	3241990009
1988	Columbia Nuclear 2	2/4/1988	3971988003
1999	Cooper	12/17/1998	2981998012
1995	Fitzpatrick	10/30/1994	3331994007
1990	Grand Gulf	11/7/1989	4161989016
1991	Hatch 1	1/18/1991	3211991001
1989	Hatch 1	12/17/1988	3211988018
1987	Hatch 1	7/23/1987	3211987011
1988	Hatch 2	5/27/1988	3661988017
1998	Hope Creek	12/5/1997	3541997032

FY	Plant	Date	LER
1997	Hope Creek	12/28/1996	3541996029
1993	La Salle 1	1/29/1993	3731993003
1990	La Salle 1	6/18/1990	3731990007
1991	La Salle 1	7/29/1991	3731991012
1992	La Salle 1	4/6/1992	3731992005
1992	La Salle 1	10/23/1991	3731991017
1995	La Salle 1	11/14/1994	3731994013
1992	La Salle 2	8/27/1992	3741992012
1994	La Salle 2	2/21/1994	3741994002
1999	Nine Mile Pt. 2	4/24/1999	4101999005
2000	Nine Mile Pt. 2	3/3/2000	4102000002
1987	Perry	3/2/1987	4401987012
1994	Pilgrim	8/3/1994	2931994004
1990	Pilgrim	9/2/1990	2931990013
1992	Pilgrim	10/30/1991	2931991025
1996	Pilgrim	4/3/1996	2931996003
1988	Quad Cities 1	12/23/1987	2541987032
1987	Quad Cities 2	8/1/1987	2651987009
1992	Quad Cities 2	5/12/1992	2651992015
1994	River Bend	9/8/1994	4581994023
1991	Vermont Yankee	4/23/1991	2711991009
1988	Vermont Yankee	11/14/1987	2711987018
1995	Vermont Yankee	5/2/1995	2711995006